

Ref : BD \_\_\_\_\_

Address : \_\_\_\_\_

Appendix \_\_\_\_\_ to approval dated \_\_\_\_\_

### **Prestressed Concrete Works**

In giving this approval of plans, I hereby impose the following conditions under item 6 in section 17(1) of the Buildings Ordinance:

- (a)<sup>#</sup> Sampling and testing of steel reinforcing bars should be carried out in accordance with CS2:2012<sup>#</sup>/Practice Note for Authorized Persons, Registered Structural Engineers and Registered Geotechnical Engineers (PNAP) APP-45 for compliance with CS2:1995<sup>#</sup>. Testing should be carried out by a laboratory\* accredited under the Hong Kong Laboratory Accreditation Scheme (HOKLAS) for the particular test concerned. Test results<sup>@</sup> should be submitted within 60 days of the delivery of the steel reinforcing bars to the site. The test reports should be appended with a statement signed by the Registered Structural Engineer to confirm the following:
- (i) All steel reinforcing bars used for the construction and the test specimens covered by the test reports are in accordance with the types and grades of steel shown in the approved plans.
  - (ii) Sampling and testing of steel reinforcing bars used have been carried out in accordance with CS2:2012<sup>#</sup>/PNAP APP-45 for compliance with CS2:1995<sup>#</sup>.
  - (iii) The acceptance criteria appropriate to each type and grade of steel reinforcing bars used have been complied with.
  - (iv) All steel reinforcing bars tests have been carried out by a laboratory\* accredited under the HOKLAS.
- (b) Sampling of concrete and compression testing of concrete test cubes should be carried out in accordance with the methods specified in CS1:2010. Testing should be carried out by a laboratory\* accredited under HOKLAS for the particular test concerned. Test results<sup>@</sup> should be submitted within 21 days after testing. The test reports should be appended with a summary which contains information on locations of the concerned structural elements, concrete grades and dates of cast. The summary should also include previous summary information of concrete cube test reports in chronological order. The test reports should also be appended with a statement signed by the Registered Structural Engineer to confirm the following:
- (i) All concrete used for the construction and concrete cubes covered by the test reports are in accordance with the concrete grades shown in the approved plans.

- (ii) Concrete cube sizes, rates of sampling fresh concrete for testing and acceptance criteria for compressive strength set out in Building (Construction) Regulations have been complied with.
  - (iii) All concrete cube tests have been carried out by a laboratory\* accredited under HOKLAS or by other laboratory accreditation bodies which have reached mutual recognition agreements/arrangements with HOKLAS and in accordance with the methods specified in CS1:2010.
- (c) Sampling and testing of grout should conform to the following requirements:
- (i) For each grout mix one sample of grout shall be provided from each 10 batches of grout, or every 10 m<sup>3</sup> from the amount of grout produced in a day, whichever is the lesser, to determine the crushing strength of the grout. Samples shall be provided not more than 1 hour after the grout has been mixed and shall be protected from weather before test cubes are made.
  - (ii) Compression testing of grout test cubes should be carried out in accordance with the methods specified in CS1:2010 using 100 mm size cubes. Testing should be carried out by a laboratory\* accredited under HOKLAS for the particular test concerned. Test results should be reported on a HOKLAS Endorsed Certificate and appended with a statement signed by the Registered Structural Engineer to confirm that the acceptance criteria set out in the Building (Construction) Regulation 59 have been complied with, and should be submitted within 21 days after testing.
- (d) Concrete should be obtained from concrete suppliers certified under the Quality Scheme for the Production and Supply of Concrete except for those exceptional projects permitted under clause 11.7.1 of the Code of Practice for Structural Use of Concrete 2013 where documents should be submitted by the Registered Structural Engineer at least one week prior to commencement of the works to prove that the concrete supplier is operating under an approved quality system.

2. The following conditions in respect of qualified supervision of works are imposed under item 6 in section 17(1) of the Buildings Ordinances:

- (a) Qualified site supervision of the prestressed concrete works, including sampling of concrete and cement grout and making and curing of test cubes, by experienced and competent persons as defined in (b) and (c), should be provided to ensure that the works are carried out in accordance with the plans approved and that the required standards are complied with.
- (b) The Registered Structural Engineer should assign a quality control supervisor to supervise the works, determine the necessary frequency of inspection by the quality control supervisor which should not be less than once a week, and devise inspection check lists. The minimum qualifications and experience of the quality control supervisor is to be the same as the Technically Competent

Person of grade T3, as stipulated in the Code of Practice for Site Supervision 2009.

- (c) The Registered General Building Contractor/Registered Specialist Contractor should assign a quality control co-ordinator to provide full time on site supervision of the works and devise inspection check lists. The minimum qualifications and experience of the quality control co-ordinator is to be the same as the Technically Competent Person of grade T1, as stipulated in the Code of Practice for Site Supervision 2009.
- (d) The names and qualifications of the supervisory personnel representing the Registered Structural Engineer and the Registered General Building Contractor/Registered Specialist Contractor respectively should be recorded in an inspection log book. The date, time, items inspected and inspection results should be clearly recorded in the log book. The log book should be kept on site for inspection by representatives of the Buildings Department.

3. Under Building (Administration) Regulation 10, the following documents are required to be submitted:

- (a) A copy of the mill certificate of the prestressing steel used, which should be submitted within 60 days of the delivery of the prestressing steel to the site and appended with a statement signed by the Registered Structural Engineer to confirm that the requirements of chemical composition and mechanical properties appropriate to the type of prestressing steel have been complied with.
- (b) Prestressing and grouting records, which should be submitted within 21 days after prestressing and grouting to confirm that the prestressing operations have been carried out satisfactorily.

# Delete wherever inapplicable

\* A Directory of Accredited Laboratories in Hong Kong is obtainable from the Hong Kong Accreditation Service (HKAS) Executive, Innovation and Technology Commission.

A laboratory's accreditation for an individual test or calibration may be granted, modified or withdrawn at any time. Up-to-date information on accredited laboratories and their scopes of accreditation are available on the internet at the HKAS website at <http://www.info.gov.hk/itc/hkas/>.

@ The test carried out by an accredited laboratory should be within its scope of accreditation. To ensure this, test results should be reported on a HOKLAS Endorsed Certificate or equivalent Certificate/Report issued from other laboratory accreditation bodies which have reached mutual recognition agreements/arrangements with the HOKLAS.