

**Corrigendum to the Code of Practice for Dead and Imposed Loads 2011
(7 March 2014)**

Legends:

Item	Clause	Current version	Amendments	Remarks
1.	Clause 3.3.3	<p><u>Clause 3.3.3</u> Areas accessible to fire engines shall, in addition, be checked for the effect due to a concentrated load of 230 kN uniformly distributed on plan over an area of 950 mm x 750 mm.</p>	<p><u>Clause 3.3.3</u> Area accessible to fire engines, shall, in addition, be checked for the effect due to a concentrated load of 230 kN uniformly distributed on plan over an area of 950 mm x 750 mm and a concentrated load of 100 kN uniformly distributed on plan over an area of 300 mm x 300 mm.</p>	To include the concentrated load from outrigger of other type of fire engine.

 - New phrase

- End -