

27 November 2025

To : All Registered General Building Contractors  
Registered Specialist Contractors  
Registered Minor Works Contractors

Dear Sir/Madam,

**Use of Fire Retardant Protective Net/Screen/Tarpaulin/Plastic Sheeting on  
Facade of Buildings under Construction, Demolition, Alteration and Addition,  
Repair or Minor Works**

On 26 November 2025, a No. 5 alarm fire involving bamboo scaffolds and protective nets broke out at Wang Fuk Court in Tai Po during repair works, resulting in multiple fatalities.

2. To safeguard public safety, you are required to review the fire retardant properties of the protective nets, screens, tarpaulins and plastic sheeting installed at the facades of buildings with works under your charge (including any sites under construction, demolition, alteration and addition, repair or minor works), and submit a report to the Buildings Department (BD), together with the relevant certificates, test reports or assessment reports by accredited laboratories, to certify that they comply with the recognised standards<sup>1</sup> of fire retardant properties and are in good condition.

3. Each project should be submitted with one report, clearly indicating the site address, description of works and BD file reference number, if any. You are required to submit the report **by hand** to the receipt counter of the BD Headquarters at *G/F, North Tower, West Kowloon Government Offices, 11 Hoi Ting Road, Yau Ma Tei, Kowloon*, or by **email** to the designated email address [*frm\_submission@bd.gov.hk*] **within 7 days** from the date of this letter, i.e. **on or before 4 December 2025**.

4. You are reminded of your duties and responsibilities under the Buildings Ordinance (BO) to ensure that the building works carried out by you are in compliance with the provisions of the BO and that all building works are carried out in a safe manner.

/5. ...

<sup>1</sup> Circular Letter dated 21 October 2025 ([https://www.bd.gov.hk/doc/en/resources/codes-and-references/practice-notes-and-circular-letters/circular/2025/CL\\_UFRPNSTPSFBCDRMW2025e.pdf](https://www.bd.gov.hk/doc/en/resources/codes-and-references/practice-notes-and-circular-letters/circular/2025/CL_UFRPNSTPSFBCDRMW2025e.pdf)) is relevant.

5. BD will conduct audit checks on the fire-retardant properties of the protective nets, screens, tarpaulins and plastic sheeting, and will take appropriate action against any contraventions/non-conformities in accordance with the provisions of the BO.

Yours faithfully,



( PANG Yuk-lung, Michael )  
Assistant Director/Corporate Services  
for Director of Buildings

c.c. The Real Estate Developers Association of Hong Kong