

**Permanent Water Supply to Fire Service Installations
Buildings Ordinance section 21(6)(d)**

Where a permanent supply of water for a fire service installation in a building is required under the provisions of the Code of Practice (Minimum Fire Service Installations and Equipment), it is essential that a permanent connection is made prior to occupation of the building.

2. For the issue of an occupation permit, the following arrangements will apply :
- (a) Where water supply to a fire service installation is **either** not required at all **or** has already been permanently connected, the Fire Service certificate required under Buildings Ordinance section 21(6)(d) will be issued in the normal way;
 - (b) Where a fire service installation is considered by the Director of Fire Services to be satisfactory **but** a permanent water supply connection has not been made, the Fire Service certificate will be issued **with a rider** that it shall be valid only when the permanent water supply has been connected; and
 - (c) In the case above, an occupation permit will not be issued until the terms of any such rider have been fulfilled.

(Helen C P Lai YU)
Building Authority

Ref. : BD GP/BOP/6
BD GP/BORD/10 II
BD GP/BREG/SF/4

First issued July 1982
This revision May 1994 (AD/D)

Index under : BO s21(6)(d) - Permanent Water Supply to Fire Service Installations
Fire Service Installations - Permanent Water Supply
Occupation Permits - Permanent Water Supply
Water Supply - Fire Service Installations