## **Notes to Owners/Occupants**

# General Procedures for Investigating Water Seepage in Districts on Trial<sup>1</sup> Joint Office of the Buildings Department and the Food and Environmental Hygiene Department

# **Responsibilities of Owners and Occupants**

- 1. Water seepage in buildings is generally caused by defective building fabric or installations and lack of proper maintenance. Proper management, maintenance and repair of buildings, including resolving water seepage problems, are the responsibilities of building owners and occupants. The co-operation of owners and occupants concerned is essential for resolving water seepage problems. In general, if water seepage occurs in private buildings, owners should first arrange their own investigation into the cause of seepage and, as appropriate, co-ordinate with the occupants and other owners concerned for repair works.
- 2. Under normal circumstances, seepage originated from penetration of rainwater through roofs, flat roofs, balconies, external walls or windows of a building or from leaking water pipes will not cause any public health implications and is not nuisance actionable by the Joint Office (JO) under the Public Health and Municipal Services Ordinance (PHMSO)(Cap. 132).

# **Objective of the Joint Office**

- 3. The objective of JO is to identify the source of seepage by means of systematic investigation through the powers conferred by the PHMSO and the professional expertise of the relevant government departments, as well as the co-operation of the owners and occupants, with a view to requiring the owners concerned to carry out repair in order to abate the nuisance arising from water seepage actionable under the PHMSO.
- 4. Reinstatement or repair of the affected premises or areas will not be undertaken by JO. Owner may make reference to the guidelines in Chapter 4.1.3 of the Building Maintenance Guidebook uploaded on Buildings Department (BD)'s website for carrying out the repair works.

https://www.bd.gov.hk/en/resources/codes-and-references/codes-and-design-manuals/bmg.html

The District Matters Co-ordination Task Force led by the Deputy Chief Secretary for Administration has putting an emphasis on handling the water seepage problems in buildings as one of the "long-standing, big and difficult" inter-departmental district-based environmental hygiene problems. In order to streamline the procedures at different stages of water seepage investigation and speed up the handling of water seepage problems in buildings, the Joint Office piloted four districts on trial (i.e. Wong Tai Sin, North, Yuen Long, and Islands) in mid-September 2023 and will add two more pilot districts (i.e. Tai Po and Kwai Tsing) in December 2024. After completing the Stage I investigation, the Stage II – Initial Investigation (by JO staff) and the Stage III – Professional Investigation (by JO's consultants) will be carried out concurrently, which were originally carried out sequentially, to expedite the water seepage investigation. This arrangement not only shortens the time for handling water seepage cases but also reduces the number of visits to the relevant premises, minimizes inconvenience to them and enhances the efficiency of handling water seepage cases with the cooperation of occupants.

## **General Procedures**

- 5. Within 6 working days upon receipt of a report, JO staff will contact the informant to arrange an inspection to the affected premises. The informant should assist JO staff in arranging access to the affected premises or area, and remove any obstruction (e.g. false ceiling, personal belongings, etc.) that tends to conceal the seepage location in order to facilitate investigation.
- 6. If water seepage nuisance is identified, JO staff will carry out investigation and non-destructive tests systematically at the premises suspected to have caused the seepage (suspected premises) so as to identify the source of seepage. For simple and straightforward cases with the co-operation of the owners and occupants concerned, JO normally will complete the investigation and tests and inform the informant of the outcome within 64 working days. If the investigation cannot be completed within 64 working days, JO will notify the informant in writing of the investigation progress.
- 7. In general, if JO staff visit the suspected premises and are unable to gain entry, a "Notice of Intended Entry" will be issued to arrange a follow-up investigation, specifying the date of the next visit. The owner or occupier of the suspected premises is requested to cooperate. Failing to comply with a "Notice of Intended Entry" without reasonable excuse constitutes an offence. In the case that access to the suspected premises for investigation is denied, JO may apply for a warrant to effect entry into premises from the Court in order to proceed with the investigation and tests.
- 8. If the source of seepage causing nuisance is identified during the investigation, JO will issue a nuisance notice to the person concerned under the PHMSO, requiring the abatement of nuisance within a specified period of time. JO will consider instigating prosecution against non-compliance with the nuisance notice. The person concerned may consider consulting building professionals / building contractors on the proper ways of repair works, if required. The person concerned may also contact JO for enquiries or request for obtaining a copy of water seepage investigation report to assist the person concerned to comply with the nuisance notice.
- 9. If the seepage becomes mild or improves significantly during investigation or the source of seepage cannot be identified after tests, the investigation of JO will cease. If there is no substantive evidence to prove any contravention of the provisions of the PHMSO, JO will have no legal basis to take any enforcement action.
- 10. If building / drainage pipe defects or wastage of water<sup>2</sup> caused by a defective water supply pipe is found during the investigation, JO will refer the case to BD or the Water Supplies Department (WSD), for follow-up and enforcement action in accordance with the Buildings Ordinance (Cap. 123) or the Waterworks Ordinance (Cap. 102) respectively.

WSD will not intervene in a private dispute arising from a mild water seepage nuisance where there is no evidence of wastage of water.

# **Investigating Water Seepage Problems**

11. In general, water seepage investigation by JO will be conducted in 3 stages.

# Stage I – Confirmation of Water Seepage Condition (by JO staff)

12. JO staff will visit the informant's premises to record the condition of the seepage location and other relevant information. If the moisture content of the seepage area is found equal to or exceeding 35% and the seepage problem is suspected to have been caused by other premises, Stage II – Initial Investigation and III – Professional Investigation will be carried out concurrently.

# Stage II – Initial Investigation (normally by JO staff)

13. One or several of the following tests will be conducted, depending on the circumstances of the case:

Test method	Test location	Premises involved	Time required <sup>4</sup>	
Moisture Content	Wall surface/ceiling	Informant's premises	About 0.5 hour	
Monitoring <sup>3</sup> (using				
moisture meter)				
Colour Water Test <sup>5</sup>	Design as outlet	Cyanastad mamisas	About 1 hour	
(using colour water <sup>6</sup> )	Drainage outlet	Suspected premises	About 1 hour	
Reversible Pressure	Water supply pipe	Suspected premises and	A h a y t 2 t a 5 h a y y a	
Test <sup>7</sup>	and seepage area	informant's premises	About 3 to 5 hours	

14. Normally, JO staff will visit the premises concerned once or twice for investigation and tests. For complicated cases (e.g. involving several bathrooms or seepage locations), multiple visits to the informant's premises and the suspected premises may be required for investigation, tests, reviews of test results or monitoring any changes in the seepage condition.

## Stage III – Professional Investigation (normally by JO's consultants)

15. One or several of the following tests will be conducted, depending on the circumstances of the case<sup>8</sup>:

<sup>&</sup>lt;sup>3</sup> JO will not investigate water seepage reports with moisture content below 35%. If the moisture content at the seepage area is below 35% during stage II or III investigation, JO will cease to follow up the water seepage investigation in accordance with the established procedures.

<sup>&</sup>lt;sup>4</sup> Time required for each test may vary according to site condition.

<sup>&</sup>lt;sup>5</sup> Colour water will be poured into the drainage outlets. The seepage area in the informant's premises will be reviewed for any seepage of colour water.

Appropriate precautionary measures will be taken according to site circumstances and needs to avoid spillage of colour water outside the testing areas. In case, any person accidentally comes into direct contact with the colour water, general hygiene practices should be observed. If feeling unwell, please seek medical attention properly.

Applicable to suspected leakage from water supply pipes and continuous water dripping in the seepage area. The rate of water dripping or moisture content will first be recorded. Then, the water supply mains at the suspected premises will be turned off and all taps will be turned on to drain off the water and release the pressure inside the pipes. The change in water dripping or moisture content will be monitored and recorded afterwards. The water supply mains at the suspected premises will then be turned on and all taps will be turned off to resume the pressure inside the pipes. The change in water dripping or moisture content will then be monitored and recorded again.

In general case, if Microwave Tomography has already been conducted, no further ponding test and spraying test would be conducted and vice versa.

Test method	<b>Test location</b>	Premises involved	Time required <sup>9</sup>
Moisture Content	Wall surface/ceiling	Informant's premises	About 0.5 hour
Monitoring <sup>3</sup> (using			
moisture meter)			
Ponding Test for	Floor slab of	Suspected premises	About 1 to 2
Floor <sup>10</sup> (using colour	bathroom/shower		hours
water <sup>11</sup> )	compartment/kitchen		
Spray Test for Wall <sup>12</sup>	Wall surface of bath	Suspected premises	About 15 minutes
(using colour water <sup>11</sup> )	tub/shower tray/shower		
	compartment		
Reversible Pressure	Water supply pipe and	Suspected premises	About 3 to 5
Test (if not carried out	seepage area	and informant's	hours
in Stage II)		premises	
Microwave	Seepage area (normally	Informant's premises	About 2 to 4
Tomography <sup>13</sup>	for ceiling)		hours
Infrared	Seepage area (normally	Informant's premises	About 0.5 hour
Thermography <sup>14</sup>	for ceiling)		

16. Normally, JO's consultants will visit the premises concerned once or twice for investigation and tests during Stage III – Professional Investigation<sup>15</sup>. For complicated cases (e.g. involving several bathrooms or seepage locations), multiple visits to the informant's premises and the suspected premises may be required for investigation, tests, reviews of test results or monitoring any changes in the seepage condition.

<sup>9</sup> Time required for each test may vary according to site condition.

The drainage outlet will be plugged before the test. The test area will be flooded with colour water and cleaned with clear water after the test. Upon completion of the test, the seepage area in the informant's premises will be reviewed for any seepage of colour water.

Appropriate precautionary measures will be taken according to site circumstances and needs to avoid spillage of colour water outside the testing areas. In case, any person accidentally comes into direct contact with the colour water, general hygiene practices should be observed. If feeling unwell, please seek medical attention properly.

<sup>&</sup>lt;sup>12</sup> Colour water will be sprayed on the walls of bath tub, shower tray or shower compartment. Upon completion of the test, the seepage area in the informant's premises will be reviewed for any seepage of colour water.

If the site circumstances are considered suitable, microwave moisture sensing device may be used to measure the referenced moisture content data of the sub-layers of the concrete floor slab for analysing the source of seepage. However, the test cannot be effectively applied under the following circumstances. a) The affected area (i.e. the moisture content of the seepage area is found equal to or exceeding 35%) is small; b) The area with the most severe seepage problem has concrete spalling or other obstructions for carrying out the test, such as drainage pipes /ceilings with tile finishes /false ceiling; c) There is no water supply point above the affected area; d)The affected area is mainly at wall or beam side/soffit; e) The seepage area is close to pipe duct and the pipe duct at suspected premises is inaccessible for inspection; f) Cases with multiple suspected premises; g) Cases without record of slab thickness.

<sup>&</sup>lt;sup>14</sup> If considered necessary and the site circumstances are considered suitable, infrared thermographic imagers may be used to record infrared images of the seepage areas for investigating the location and extent of seepage.

If the site circumstances are suitable for using microwave moisture sensing device, generally only one visit to the relevant premises is required for investigation and tests. However, if the site circumstances are not suitable for using microwave moisture sensing device, conventional testing methods such as ponding test and spray test need to be applied. If there is suspicion of leakage in the water supply pipe, reverse pressure test will be conducted. In these cases, multiple visits to the informant's premises and the suspected premises may be required by JO's consultants for investigation and tests.

17. Before the visit, JO will issue a letter to inform the occupants of the premises concerned of the appointment of the consultant, the names and contact telephone numbers of the staff of JO and the consultant, and a sample of the consultant's staff card issued by JO. When visiting the premises concerned, the consultant's staff should bring along their staff cards for identification and verification by the public. The public may also contact JO and the consultant to verify the identification of the consultant's staff.

Names and contact telephone numbers of consultants employed by JO for water seepage investigation can be downloaded from the website below:

https://www.bd.gov.hk/doc/en/resources/faq/Water\_Seepage\_Problem\_Consultants\_List\_e.pdf



# **Request for Copy of Investigation Report**

18. If the owners / occupants concerned wish to obtain a copy of the water seepage investigation report, request may be made under the Code on Access to Information. The applicant should submit an application form to JO through mail or facsimile.

The procedures for Access to Information and application form can be referred to the Thematic Water Seepage webpage below:

https://www.waterseepage.gov.hk/en/information/investigation\_report.html

The office hours, addresses, e-mail addresses, contact and facsimile numbers of 4 Regional JO are available at the Thematic Water Seepage webpage below:

https://www.waterseepage.gov.hk/en/about us/joint office.html



## **Resolving Seepage Problems by Owners**

19. Apart from seeking assistance from JO, owners or occupants may cooperate among each other to engage professionals/consultants for carrying out investigation to identify the source of seepage and conducting necessary repair works to resolve the water seepage problems. Consultants/professionals are available in the market to provide services for investigating and resolving water seepage problems. The following hyperlinks are provided by the Hong Kong

Institute of Surveyors (HKIS)<sup>16</sup>:

List of Consultancy Firms providing Advice on Water Seepage Problems: <a href="https://www.hkis.org.hk/en/company\_list.html?division=BSD&keywor">https://www.hkis.org.hk/en/company\_list.html?division=BSD&keywor</a> d=&print=



List of Experts on Water Seepage Investigation:

https://www.hkis.org.hk/en/experts.html?category=1



20. If water seepage problems involve the water supply system, owners may appoint a plumber licensed under the Waterworks Regulations (Cap. 102A) for checking the system and carrying out the necessary repair works. The Licensed Plumber Directory is available on WSD's webpage below:

http://www.wsd.gov.hk/en/plumbing-engineering/licensed-plumbers/index.html




21. If necessary, owners may consider seeking legal advice from your lawyer or mediation for resolving water seepage problems. Relevant information can refer to the website below.

https://www.hklawsoc.org.hk/en/Serve-the-Public/Everyday-Life-Legal-Issues/Law-Society-Leaflets



22. The Pro-bono Online Mediation Scheme for Water Seepage Disputes (the Scheme) is a collaborative initiative operated by Agency for Volunteer Service and eBRAM International Online Dispute Resolution Centre Limited. The Scheme aims to foster a harmonious community by offering probono online mediation services to property owners and occupants encountering water seepage issues, facilitating effective and timely dispute resolution. The Scheme commenced on 2 December 2024 and will run for one year. Please refer to the webpage below for relevant information:

Owners are responsible for making their own assessment of all information in the Lists. The HKIS should be contacted should there be any queries on any matters regarding the Lists. The Lists are compiled, maintained and provided by the HKIS. The Government of the HKSAR plays no part in the compilation of the Lists and shall not be responsible for any inaccuracies in the Lists nor any errors/incomplete information arising from the hyperlinks nor any loss or damage whatsoever arising out of or in connection with any information or the performance of the service providers in the Lists. The service providers in the Lists should not be regarded as endorsed or recommended by the BD or the Government of the HKSAR nor imply that the Government of the HKSAR promotes their expertise or their business.



Moreover, they can also consider seeking the help of Building Affairs Expert Determination Centre. Relevant informant can be downloaded from the website below.

https://www.hkis.org.hk/en/division\_bsd.html?id=196

#### **Assistance Schemes**

24. The Integrated Building Rehabilitation Assistance Scheme (IBRAS) is a one-stop service coordinated by the Urban Renewal Authority, providing financial assistance and technical support to building owners. Building Maintenance Grant Scheme for Needy Owners and Building Safety Loan Scheme under IBRAS are applicable to water seepage related repair works. Eligible persons may apply for a loan or subsidy for carrying out water seepage related repair works. Details are available on the webpage below:

<u>https://brplatform.org.hk/en/subsidy-and-assistance/integrated-building-rehabilitation-assistance-scheme</u>



## **Thematic Water Seepage Webpage**

25. The JO has set up a one-stop thematic webpage on water seepage, so as to facilitate the public to obtain information for water seepage and related issues. Details are available on the webpage below:

https://www.waterseepage.gov.hk/en/home/index.html



Joint Office of Buildings Department and Food and Environmental Hygiene Department