

Central Data Bank List of Building Components
--

A. General

Department:	Buildings
Type of building component:	Fire Resisting Lift Landing Doors
Applications:	Application of fire resisting lift landing doors refers to para. 11.2 of the Code of Practice for Fire Resisting Construction 1996.

B. Acceptance criteria**Testing standards:**

Testing of fire resisting lift landing doors shall be carried out in accordance with BS 476 : Parts 20 to 24 : 1987. Other standards or technical criteria may be accepted if the fire resisting lift landing door can be shown to comply with the necessary performance requirements.

Conditions of Acceptance:

NA

BD's Reference List under Central Data Bank

(B) Fire Resisting Lift Landing Door

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-B001	KONE AMDL/Z fire resistant lift landing entrances	KONE	120	-	-	Building Research Establishment (BRE)	CC9189B	30/7/2002	30/7/2007	8/9/2005	
BD-B002	Lift Door	Elex Elevator Ltd	60	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C124822	14/5/2002	1/6/2007	8/9/2005	
BD-B003	Lift Door	OTIS PLC	60	-	-	-	F/95/L528	29/1/1996	8/5/2010	8/9/2005	
BD-B004	Lift landing doorset (25S0005475/CYW)	Chevalier (HK) Ltd.	60	-	UKAS	Warrington Fire Research Centre Ltd.	WFRS No.SC2661.1	15/12/2003 21/2/2003	31/12/2008 31/1/2008	31/1/2007	
BD-B005	-	Wittur Spa	60	60	HOKLAS + UKAS	Warrington Fire Research Centre Ltd.	WRFC No. 135623	6/11/2003	1/12/2008	31/1/2007	
BD-B006	Knauf Fireshield Partition system 12.5mm Fire resistant Plaster board	Knauf Insulation Ltd.	120	120	UKAS	Building Research Establishment (BRE)	CC 82221	26/6/2003	26/6/2008	31/1/2007	
BD-B007	Lift Landing doorset	Chevalier	90	-	UKAS	Warrington Fire Research Centre Ltd.	WFRS No. SC2261	21/1/2000	28/2/2008	31/1/2007	
BD-B008	-	Chevalier Singapore Holdings Ltd.	90	-	UKAS	Warrington Fire Research Centre Ltd.	WFRS SC 2261	21/2/2003	28/2/2008	31/1/2007	
BD-B009	Fully insulated lift landing door type AMD1	KONE Oyj	132	66	FINAS (Finland)	VTT Building Technology	RTE408/00	5/4/2000	-	31/1/2007	
BD-B010	Kone AMDL/Z'	Kone Lifts Ltd.	120	-	HOKLAS	Building Research Establishment (BRE)	CT-03.01.155B	30/7/2002	30/7/2007	31/1/2007	
BD-B011	Insulated lift landing door	KONE Oyj	132	66	FINAS (Finland)	VTT Building Technology	RTE408/00	1/2/2000	Indefinite	31/1/2007	

BD's Reference List under Central Data Bank

(B) Fire Resisting Lift Landing Door

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-B012	Door	Selcom S.p.A.	120	-	Selcom S.p.A.	Warrington Fire Research Centre Ltd.	C109702	29/5/1998	1/3/2008	31/1/2007	
BD-B013	AMDLI	KONE	120	-	UKAS	Building Research Establishment (BRE)	CC92527	18/1/2002	16/1/2007	31/1/2007	
BD-B014	-	China Tianjin Otis Elevator Co., Ltd.	120	-	National Association of Testing Authorities. Australia	Building Research Association of New Zealand (BRANZ)	FR3418	3/6/2005	-	31/1/2007	
BD-B015	Lift Landing Doorset	China Tianjin Otis Elevator Company Ltd.	135	-	IANZ	Building Research Association of New Zealand (BRANZ)	FR 3429	24/8/2005	Indefinite	30/4/2007	
BD-B016	-	Hitachi Elevator Eng. Ltd.	65	-	FSSB (Singapore), HKAS	PSB Corporation (Singapore)	G48355/TSM	13/6/1998	-	30/4/2007	
BD-B017	-	Hyundai elevator Co. Ltd.	60	60	HOKLAS	Fire Insures Lab. Of Korea (FILK)	20011333	3/12/2001	-	30/4/2007	
BD-B018	Landing door sets	Shanghai Bst-Fermator Door System Co. Ltd.	60	60	-	Warrington Fire-Global Safety	148144	22/7/2005	1/8/2010	30/4/2007	
BD-B019	-	OTIS Elevator Co.(HK) Ltd.	60	60	UKAS	Warrington Fire Research Limited	135623	11/6/2003	12/1/2008	22/11/2007	
BD-B020	Timber door	Kwok Shing	60	60	HOKLAS	RED	R05L15A	20/3/2006	19/3/2008	22/11/2007	
BD-B021	Timber door	Yiu Kee Construction Material Co. Kin Hing Door & Wood Co., Ltd.	62 60	62 60	UKAS	Warrington Fire Research Centre Chiltern International Fire Ltd.	WARRES No. C63174 WFRC No. C114773 WFRC No. C113975B WFRC No. C125693 FEA/F00020 Revision C	21/3/1996 27/7/2000 1/5/2000 1/7/2002 25/5/2002	21/3/2001 1/8/2002 1/6/2005 1/8/2007 25/5/2007	22/11/2007	
BD-B022	Hitachi	-	120	-	UKAS	Warrington Fire Research	WFRS No. SC 2735	30/6/1998	30/11/2008	22/11/2007	

BD's Reference List under Central Data Bank

(B) Fire Resisting Lift Landing Door

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-B023	3201-HYDRA 01C	Suzhou Selcom Elevator Components Co., Ltd.	60	60	UKAS	Warrington Fire Research Ltd.	WFRC No. C12700	27/9/2002	1/10/2007	22/11/2007	
BD-B024	AMD1	Kone Oyj	132	66	FINAS (Finland)	VTT	RTE 408/00	1/2/2000	Indefinite	22/11/2007	
BD-B025	Lift Landing Door	Schindler Lifts	120	-	IANZ	Building Research Association of New Zealand (BRANZ)	-	-	-	7/1/2008	
BD-B026	Landing Door	Kone	132	66	Finas (Finland)	Vtt	RTE408/00	1/2/2000	5/4/2010	7/1/2008	
BD-B027	Durasteel	Intumex	120	-	UKAS	Building Research Establishment (BRE)	CC203964 Rev 1	8/4/2003	8/4/2008	7/1/2008	
BD-B028	Varidor 50 C2	Schindler Elevator Ltd	210	-	IANZ	Building Research Association of New Zealand (BRANZ)	FR2951	8/10/2001	-	7/1/2008	
BD-B029	AMD Lift landing entrance door	Kone	132	66	FINAS AKKREDITOINTI	VTT Building Technology Fire Technology	RIE408/00	1/2/2000	Indefinite	20/8/2008	
BD-B030	Fire rated lift landing door (L3)	Fujitec Co. Ltd.	60	60	UKAS	Warrington Fire Research Centre Ltd.	WFRC Report No. 135623	6/11/2003	1/12/2008	20/8/2008	
BD-B031	Fully insulated lift landing door type AMD1	Kone Oyj	132	66	VTT Technical Research Centre of Finland	VTT Building Technology	RTE 408100	1/2/2000	indefinite	20/8/2008	
BD-B032	YTONG Autoclaved Aerated Concrete Block	Daido Home International Limited	240	240	UKAS	Warrington Fire Research Centre	WFRC No. 135393	20/10/2003	1/11/2008	20/8/2008	
BD-B033	Fully Insulated Lift Landing Door	WITTUR SpA	60	60	UKAS	Warrington Fire Research Centre	WFRC No. 135623	6/11/2003	1/12/2008	20/8/2008	

BD's Reference List under Central Data Bank

(B) Fire Resisting Lift Landing Door

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-B034	Lift landing door	Mitsubishi Elevator Hong Kong Co., Ltd.	60	60	CNACL	Far East Fire Testing Centre	Report no. FT07053	13/3/2007	Indefinite	20/8/2008	
BD-B035	Door for Lift	Elex Lift Landing Door	120	-	UKAS	Warrington Fire Research	WFRC C130447/A 149198B	24/2/2003 8/12/2005	1/3/2008 1/12/2010	20/8/2008	
BD-B036	Varidor V50 Insulated Lift Landing Doors	Schindler Lifts Ltd.	120	60	PNAP 251	International Fire Consultants Ltd.	IFCA/02241 Revision B	1/4/2005	1/4/2010	20/8/2008	
BD-B037	2-panel, side opening landing doorset	Technolama S.A.	120	-	UKAS	Warrington Fire Search	11700.1 135426A	20/10/2003	1/11/2008	20/8/2008	
BD-B038	Lift Door	Thyssenkrupp Elevator	132	-	UKAS	Warrington Research Centre Ltd.	WFRC No. 140693	13/7/2004	1/8/2009	20/8/2008	
BD-B039	-	-	60	60	UKAS	Warrington Fire Research Ltd.	135623	6/11/2003	1/12/2008	24/2/2009	
BD-B040	Durasteel	Gelec (HK) Ltd.	60	60	UKAS	Warrington Fire	WF Assessment No. 174500	1/7/2008	1/7/2013	24/2/2009	
BD-B041	Insulated Lift Landing Door Type AMD1	KONE	60	60	FINAS	VTT Building Technology	RTE408/00	1/2/2000	Indefinite	24/2/2009	
BD-B042	Durasteel	Intumex Asia Pacific Pte Ltd	240	-	UKAS	WFRC	CC132908	28/10/2003	1/11/2008	24/2/2009	
BD-B043	Door	Q7K13	120	120	HOKLAS	RED	R07K26	1/11/2007 4/12/2007	-	24/2/2009	
BD-B044	WITTUR	WITTUR SpA	60	60	UKAS	Warrington Fire Research Centre Ltd.	WFRC Report No. 135623	6/11/2003	1/12/2008	24/2/2009	
BD-B045	Kone Lift Door	Kone OYJ.	60	60	FINAS	VTT Building Technology	RTE 408/00	5/4/2000	-	24/2/2009	
BD-B046	'Otis' Lift Landing Door	Otis Ltd	60	60	UKAS	Warrington Fire Research Ltd	WFRC 135623	6/11/2003	1/12/2008	24/2/2009	

BD's Reference List under Central Data Bank

(B) Fire Resisting Lift Landing Door

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-B047	"2P-CO" Insulation Lift Landing Doorset	Hitachi Elevator Engineering Co. (HK) Ltd.	60	60	SAC-SINGLAS	PSB Corporation	54S033647/YAS	25/7/2003	-	24/2/2009	
BD-B048	AMDLIC Package HKG	KONE	117	-	HOKLAS	Research Engineering Development	R06F06	18/9/2006	-	24/2/2009	
BD-B049	Lift Door	Hitachi Elevator Engineering(s) Pte Ltd	60	60	Singapore Accreditation Council	PSB	54S033647/YAS	25/7/2003	Indefinite	2/11/2009	
BD-B050	Durasteel loaded floor assemblies	Intumex Asia Pacific Pte. Ltd	120	120	UKAS	Warrington Fire Research Centre, Ltd	136396	22/3/2004	1/4/2009	2/11/2009	
BD-B051	Lift Landing Doorset	China Tianjin Otis Elevator Company Ltd.	120	-	IANZ	BRANZ	FR 3418	18 & 19/4/2005	Indefinite	2/11/2009	
BD-B052	Stainless Steel Lift Landing Door	KONE Elevator (HK) Ltd.	60	-	HOKLAS	Research Engineering Development Facade Consultants Limited	R07C15A	2/4/2007	1/4/2009	2/11/2009	
BD-B053	Lift Landing door (HAS 2 CO) for L1 ~ L6	Fujitec (UK) Co., Ltd.	120	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC no. C101131	15/12/1997	1/1/2000	16/12/2009	
					UKAS	Bodycote Warringtonfire	166852/C	6/9/2007	1/9/2012		
BD-B054	Fully Insulated Lift Landing Door	Thyssen Krupp Elevator (HK) Limited	60	60	UKAS	Warrington Fire Research Centre Limited	135623	6/11/2003	1/12/2008	16/12/2009	
BD-B055	3210-Hydraty.01/C	Wittur S.p.A	120	-	UKAS	Bodycote Warringtonfire Testing, U.K	163926	8/5/2007	1/5/2012	23/2/2010	
BD-B056	Lift Landing Door	Mitsubishi Electric Corporation	132	-	UKAS	Bodycote	120020 (Issue 6)	31/10/2005	1/5/2012	23/2/2010	

BD's Reference List under Central Data Bank

(B) Fire Resisting Lift Landing Door

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-B057	Lift Landing Door	Xizitrust	60	60	CNAS	NETEC	PG NET 09-03	3/7/2009	3/7/2011	23/2/2010	
BD-B058	3201-HYDRA series lift landing doorsets incorporating insulating materials	Wittur S.p.A	60	60	UKAS	Warringtonfire Warrington Fire Research Consultancy	WF 167201B WFRC No.C127000	13/09/2007 27/09/2002	1/10/2012 1/10/2007	23/2/2010	
BD-B059	AMD DOOR	KONE	120	-	UKAS	BRE Global	CC91891B Review 3	18/11/2008	18/11/2013	25/5/2010	
BD-B060	Insulated Lift Landing Doors	Hitachi Elevator Engineering	60	60	SAC	PSB Corporation	54S033647/YAS	16/7/2003	-	25/5/2010	
BD-B061	Lift landing door	KONE, Oyj	132	66	FINAS	VTT Building Technology VTT Technical Research Centre of Finland	RIE408/00 729/28/05/RIE	1.2.2000 3.5.2005	5.4.2005 Indefinite	25/5/2010	
BD-B062	Lift Landing Door Set	Chevalier (HK) Ltd.	60	60	HOKLAS	Research Engineering Development	R09H09	29 Dec 2009	28 Dec 2011	29/12/2011	
BD-B063	Varidor 30 AP C2 lift landing doorset	Schindler Elevator Technology Service Co. Ltd.	60	-	IANZ (New Zealand)	BRANZ Ltd.	FR 2945/issue3	03.09.2004	Indefinite	17/9/2012	
BD-B064	Lift Landing Door Assemblies with Insulation Materials for Lifts	Chevalier (HK) Ltd.	60	60	Hong Kong Laboratory Accreditation Scheme (HOKLAS)	Research Engineering Development Façade Consultants Limited	R11K04	12.12.2011	11.12.2013	28/12/2012	

BD's Reference List under Central Data Bank

(B) Fire Resisting Lift Landing Door

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-B065	Lift landing door	Fujitec (Hong Kong) Company Limited	60	60	HOKLAS	Research Engineering Development Facade Consultants Limited	Assessment Report No. R12F20	26/7/2012	27/7/2015	19/2/2013	
BD-B066	L2-3N-CO Type lift landing door	Mitsubishi Elevator Hong Kong Company Ltd.	120	0	CNAS	Far East Fire Testing Centre	Test Report No. FT12053	15.3.2012	-	8/3/2019	
BD-B067	Two Panel, Centre-opening, Lift Landing doorset	Fujitec (Hong Kong) Company Limited	120 120	- -	UKAS UKAS	Exova Warringtonfire Warrington Fire Research Consultancy Testing	Assessment Report WF Report No. 394298/A Test Report WFRFC No. C101129	17.1.2018 15.12.1997	1.2.2023 1.1.2000	8/3/2019	
BD-B068	2 hours integrity lift landing door L2-3N-CO type	Mitsubishi Elevator Hong Kong Company Limited	120	-	CNAS L1412	Far East Fire Testing Centre	FT12053	1. 15.03.2012 2. 19.03.2012	Indefinite	8/3/2019	
BD-B069	Control Cabinet for Elenessa Lift	Guangdong Ryoden Lift & Escalator Co. Ltd.	120	-	CNAS	Far East Fire Testing Centre	No. FT10245	23.8.2010	-	8/3/2019	
BD-B070	Lift Landing Door	Toshiba Elevator and Building Systems Corporation	120	-	HOKLAS SAC	RED Façade Consultants Limited TUV SUD PSB Singapore	R17G34-1A 7191101036-MEC14-RAH	17.10.2017 10.2.2015	17.10.2019 -	8/3/2019	

BD's Reference List under Central Data Bank

(B) Fire Resisting Lift Landing Door

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-B071	Lift landing doorset	Hitachi Elevator(China) Co., Ltd.	121	-	CNAS	Guangzhou Building Material Research Institute Co., Ltd.	V03-1700692 (E)	12.10.2017	-	13.07.2020	
						TUV SUD Certification and Testing (China) Co., Ltd.	64.664.17.161.01	20.11.2017	-		
BD-B072	L3N-CO Type Fully-insulated Lift Landing Door	Guandong Ryoden Lift & Escalator Co., Ltd.	120	120	CNAS	Far East Fire Testing Centre	FT10075	17.03.2010	-	13.07.2020	
BD-B073	Hydra Lift Landing Doorsets - Series 3201	Selcom S.p.A	120	-	UKAS	Warringtonfire Fire Research Centre	C109702	16.09.1999	01.10.2001	26.02.2021	
						Exova Warringtonfire Consultants Limited	398775/A	19.04.2018	01.05.2023		
BD-B074	Lift Landing Doorsets	SELCOM S.p.A.	120	-	UKAS	Warrington Fire Research Ltd.	WFRC No. C109702	16.09.1999	01.10.2001	26.02.2021	
						Exova Warringtonfire	WF Report No. 398775/A	19.04.2018	01.05.2023		
BD-B075	Lift Landing Doorset	Hitachi Elevatoer Engineering Co., (Hong Kong) Ltd.	120	-	HOKLAS	RED Fire & Façade Consultants	R09H11	28.09.2009	-	26.02.2021	
BD-B076	Lift Landing Doorset	Hitachi Elevator Asia Pte Ltd	120	-	UKAS	Warrington Fire Research Centre	C80333	10.11.1992	-	04.05.2021	
						Exova Warringtonfire	23278-21	28.03.2018	29.11.2021		

BD's Reference List under Central Data Bank

(B) Fire Resisting Lift Landing Door

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-B077	Lift Landing Door	Guangdong Ryoden Lift & Escalator Co., Ltd.	120	-	CNAS	Far East Fire Testing Centre	FT12118	21.06.2012	-	04.05.2021	
BD-B078	Lift landing doorset	Chevalier Singapore Holdings Pte Ltd.	120	-	SAC-SINGLAS HOKLAS	PSB Corporation RED Façade Consultants Ltd.	54S055592/RAH R13F07 R17K28-1A R19M11-1A	28.10.2005 29.10.2013 25.10.2017 23.12.2019	- 28.10.2015 15.11.2019 22.12.2021	04.05.2021	
BD-B079	Stainless Steel Lift Landing Doorset	KONE Elevator (HK) Ltd.	120	-	HOKLAS	Research Engineering Development Façade Consultants	R06F06A R07C15A R09D01A R18L15-1A	15.08.2006 02.04.2007 01.04.2009 21.11.2018	- 31.03.2009 30.03.2012 20.11.2021	04.05.2021	
BD-B080	Lift Landing Doorset	Wittur Holding GmbH / Sematic Italia SpA	120	-	UKAS	Exova Warringtonfire Warrington Fire Research Centre Ltd	383134D C81904 issue 4 102781	12.05.2017 11.01.2002 07.08.1998	01.06.2022 01.07.2007 -	23.08.2021	
BD-B081	Lift Landing Door	Wittur Elevator Components (Suzhou) Co., Ltd.	120	-	SAC	TUV SUD PSB Pte. Ltd.	7191125380-MEC15-RAH	07.12.2015	-	23.12.2022	

BD's Reference List under Central Data Bank

(B) Fire Resisting Lift Landing Door

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-B082	Lift Landing Doorset	Otis Electric Elevator Co., Limited Otis Elevator (China) Company Limited Sigma and Express Elevator Company Limited Express Elevator Co., Limited	120	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R16L14-1A	18.01.2017	-	23.12.2022	
BD-B083	Lift Landing Door (Model: TKP161-14)	NBSL Elevator Components Co., Ltd.	120	-	CNAS	China Academy of Building Research Co., Ltd.	CABR-NH-2019-01204	08.11.2019	-	23.12.2022	
BD-B084	Stainless Steel Lift Landing Doorset (Model: M2ZS8)	ThyssenKrupp Elevator (HK) Limited Thyssen Elevators Co., Ltd.	125	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R07E05	25.07.2007	-	23.12.2022	

BD's Reference List under Central Data Bank

(B) Fire Resisting Lift Landing Door

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-B085	Lift Landing Doorset	Selcom S.p.A. Wittur S.p.A.	120	-	UKAS	SGS Yarsley Ltd.	J87885/5	26.09.1991	-	23.12.2022	
						Warrington Fire Research Centre Ltd.	C102916	18.05.1998	01.06.2000		
							C109702	16.09.1999	01.10.2001		
							110358	21.10.1999	01.11.2001		
							C130447/A	24.02.2003	01.03.2008		
						Bodycote Warringtonfire	C130447/B	24.02.2003	01.03.2008		
							160145	19.12.2006	01.01.2012		
						Exova Warringtonfire	171312/A	17.03.2008	01.04.2013		
							171312/C	17.03.2008	01.04.2013		
							316900B	16.03.2012	01.04.2017		
					327977/A	16.04.2013	01.05.2018				
					327977/C	16.04.2013	01.05.2018				
					381535B	17.03.2017	01.04.2022				
BD-B086	Lift landing doorset	Chevalier Singapore Holdings Pte Ltd.	120	-	SAC-SINGLAS	TUV SUD PSB Pte. Ltd.	7191113507-MEC15-RAH	26.05.2015	-	23.08.2024	
		Toshiba Elevator and Building Systems Corporation			HOKLAS	Research Engineering Development Façade Consultants Limited	R17G34-1A	17.10.2017	16.10.2019		
BD-B087	Lift Landing Doorset	ThyssenKrupp Elevator (HK) Limited	120	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R06G06	08.02.2007	-	23.08.2024	
		Thyssen Elevators Co., Ltd.					R17E23-1A	20.06.2017	18.06.2019		
							R19F22-1A	20.06.2019	19.06.2021		
BD-B088	L3N-2S (1.5mm) Type Fire Resisting Lift Landing Door	Mitsubishi Elevator Hong Kong Co., Ltd.	120	-	CNAS	Far East Fire Testing Centre	FT15292	09.10.2015	-	23.08.2024	

BD's Reference List under Central Data Bank

(B) Fire Resisting Lift Landing Door

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-B089	KONE AMDL/Z lift-landing entrance doorset	Kone Ascensori Spa KONE Corporation	132	-	UKAS	BRE Global Limited	208703	06.09.2002	-	23.08.2024	
			120	-			P100579-1012 Issue 1	30.05.2018	29.05.2023		
BD-B090	KONE AMDL/Z lift-landing entrance doorset	Kone Ascensori Spa KONE Corporation	132	-	UKAS	Building Research Establishment Ltd BRE Global Ltd	208703	06.09.2002	-	31.10.2024	
			120	-			P100579-1012 Issue 1	30.05.2018	29.05.2023		
BD-B091	Lift Fire-resistance Landing Door	Otis Electric Elevator Co., Ltd.	121	-	CNAS	China Academy of Building Research Co., Ltd.	CABR-NH-2019-01447	08.01.2020	-	31.10.2024	
BD-B092	Un-insulated Centre-opening Mild Steel Lift Landing Doorset	Otis Elevator Company (H.K.) Limited	126	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R18A12-1A	07.05.2018	-	31.10.2024	
BD-B093	Un-insulated Centre-opening Mild Steel Lift Landing Door Sets (for Lift No. L1 to L10)	Otis Elevator Co., (HK) Ltd.	120	--	HOKLAS	Research Engineering Development Façade Consultants Limited	R18A12-1A	7/5/2018	-	31.10.2024	
BD-B094	Stainless Steel Lift Landing Doorset	Wittur Holding GmbH	120	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R16G27-1A R17B12-1A R19D06-1A	30.12.2016 10.02.2017 23.04.2019	- 08.02.2019 24.04.2022	31.10.2024	

BD's Reference List under Central Data Bank

(B) Fire Resisting Lift Landing Door

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-B095	Lift Landing Doorset	Wittur Holding GmbH	120	0	UKAS	Exova Warringtonfire	400142A	03.09.2018	01.09.2023	03.04.2025	
			150	-	SAC	TUV SUD PSB Pte. Ltd.	7191125380-MEC15-RAH	07.12.2015	-		
BD-B096	Lift fire-resistance landing door	GUANGDONG RYODEN LIFT & ESCALATOR CO., LTD (China)	121	-	CNAS	China Academy of Building Research Co., Ltd	CABR-NH-2021-00401	24.06.2021	08.06.2026	03.04.2025	