

Central Data Bank List of Building Components
--

A. General

Department:	Buildings
Type of building component:	Other Fire Resisting Products

B. Acceptance criteria**Testing standards:**

Testing of fire resisting products (e.g. shutters) shall be carried out in accordance with BS 476 : Parts 20 to 24 : 1987. Other standards or technical criteria may be accepted if the fire resisting products can be shown to comply with the necessary performance requirements.

Conditions of Acceptance:

NA

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E001	Ytong autoclaved aerated concrete block	Daido Home Int. Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	Warres no.68302 WFRC 135393	3/10/1996 20/10/2003	3/10/2001 1/11/2008	23/5/2005	
BD-E002	Fire shutter	Suzuki	240	-	UKAS	Warrington Fire Research Ltd (HK)	C43912 132999/A	24/6/2003	1/7/2008	23/5/2005	
BD-E003	80 mm thick, "AUGREEN" Gypsum Block	Jinan Jin Lu Yuan New Building Material Company Limited	120	120	HOKLAS	RED Research Engineering Development Façade Consultants Limited	I4L18	3/12/2004	2/12/2007	23/5/2005	
BD-E004	Fire Roller Shutter	Finetec Shutter Company Limited	120	-	International Accreditation New Zealand	Building Research Association of New Zealand (BRANZ)	FAR 1968	27/9/2002	Indefinite	23/5/2005	
BD-E005	Y Tong AAC	Y Tong (Hong Kong) Limited	120	120	UKAS	Warrington Fire Research Consultancy testing	Warres No. 68302 WFRC Report No. 135393	3/10/1996	1/11/2008	23/5/2005	
BD-E006	"Promat" Board 9mm thick	Promat Int. Asia Pacific Ltd.	120	-	Building Research Establishment Ltd.	UK Fire Test Study Group Resolution	CC83299	21/2/2002	21/2/2007	23/5/2005	
BD-E007	Promatect S & Promatect H	Promat Fire Protection Ltd.	120/ 240	- -	UKAS	Building Research Establishment (BRE)	CC83299 CC86559	21/2/2002 1/2/2002	21/2/2007 1/2/2007	23/5/2005	
BD-E008	PROMATECT-H	Promat Int. (Asia Pacific) Ltd.	120	120	UKAS	Building Research Establishment (BRE)	CC83071	21/2/2002	21/2/2007	8/9/2005	
BD-E009	USGC, Sheetrock Firecode C gypsum plasterboard	USGC	60	60	UKAS	WFRC	C123081/B Report Ref.: WFRC C80411, warres 37254	1/2/2002	1/3/2007	8/9/2005	
BD-E010	Suzuki Shutter	Suzuki Shutter Co. (HK) Ltd.	120	-	UKAS	Warrington Fire Research Service Ltd	WFRC No. C124741 Supplement to WFRC No 120584	20/6/2002	1/7/2007	8/9/2005	
BD-E011	Fibreglass Reinforced Plastic (FRP) Panel	Architectural Precast GRC Ltd.	30	-	The Singapore Accreditation Service	PSB Corporation	PSB Test Report Ref. 54S040951/1/OKH	10/3/2004	10/3/2009	8/9/2005	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E012	Firetherm Intumescent Sealant	-	60	60	-	-	-	-	-	8/9/2005	
BD-E013	Nullifire S607	Nullifire Ltd.	60	-	Building Research Establishment Ltd.	Building Research Establishment (BRE)	CC93856	12/11/1999	6/12/2006	8/9/2005	
BD-E014	Promat Internal Partitions	-	120	120	UKAS	Building Research Establishment (BRE)	BRE Assessment report No. CC8158A	-	25/2/2008	8/9/2005	
BD-E015	Fire Damper	Honestice Engineering Co. Ltd.	120	-	UKAS	Warrington Fire Research Consultancy (UK)	WFRS No. SC 2513	16/5/2002	1/6/2006	8/9/2005	
BD-E016	Promatect H Boards	Promat Int. Asia Pacific Ltd.	120	120	-	Building Research Establishment (BRE)	CC 83299	21/2/2002	21/2/2007	8/9/2005	
BD-E017	Durasteel Insulated Access	Intumex Asia Pacific Pte Ltd.	60	60	UKAS	Warrington Fire Research	C131669	29/5/2003	1/6/2008	8/9/2005	
BD-E018	Durasteel Dura Flush Singe Leaf Trap Door	Gelec (HK) Ltd.	240	-	UKAS	Warrington Fire Research Centre Ltd.	C132910	-	1/7/2008	8/9/2005	
BD-E019	Y-Tong block	"Daido" Concrete (H.K.) Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	WARRES No. 68302 WFRC Report No. 135393	3/10/1996 20/10/2003	1/11/2008	8/9/2005	
BD-E020	"Opal" fire protection pipe wrap sealing system	Opal Sleeve-it Fire System Ltd.	120	-	UKAS	Building Research Establishment (BRE)	C220500B	19/7/2001	19/7/2006	8/9/2005	
BD-E021	Monokote Mk6	W.R. Grace Ltd.	60	-	-	WFRC (UK)	C127373 51843	30/9/2002 21/6/1991	1/10/2007	8/9/2005	
BD-E022	Roller shutters	Sanwa Shutter (HK) Ltd.	240	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C80427	10/12/1992	-	8/9/2005	
BD-E023	SUZUKI	SUZUKI	120	-	WFRC	WFRC	C81766	14/7/1995	1/6/2008	8/9/2005	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E024	"Durasteel"	Intumex Asia Pacific	60	60	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C141176	1/8/2004	1/9/2009	8/9/2005	
BD-E025	Flame Retardant	Flamebar Limited	-	-	NAMAS	Test	BTC5440F	11/7/1995	-	8/9/2005	
BD-E026	C. Caswell Steel ventilation duct	C. Caswell	240	240	UKAS	WFRC	C135052	27/11/2003	1/12/2008	8/9/2005	
BD-E027	Promatect H smoke barrier	Promat International Asia Pacific Ltd.	60	-	UK Fire Test Study Group Resolution No. 82:2001	Building Research Establishment (BRE)	CC84607	21/2/2002	21/2/2007	8/9/2005	
BD-E028	MONOKOTE MK-6	AMPERO (HK) LTD.	60	-	WFRC SL	WFRC WFRC	No. C127373 WARRES No. 51843	30/9/2002 21/6/1991	1/10/2007 -	8/9/2005	
BD-E029	K W Fusible Link	K-WIN	60	-	HOKLAS	The H.K. Standards & Testing Centre Ltd.	HT169581	5/9/2005	-	31/1/2007	
BD-E030	IBOfire damper	Joint Billion International Ltd.	120	-	International Accreditation New Zealand of New Zealand	Building Research Association of New Zealand (BRANZ)	FR2230	16/7/1996	-	31/1/2007	
BD-E031	Firecut FM-900	Yung Chi Paint & Varnish Mfg Co. Ltd.	120	-	IANZ	Warrington Fire Research Centre Ltd.	WFRC No. C125252	19/6/2002	1/7/2007	31/1/2007	
BD-E032	Firex Board	Polygon Building Materials Ltd.	240	240	BRE	Building Research Establishment (BRE)	CC212613	11/8/2004	11/8/2008	31/1/2007	
BD-E033	Ruskin IBD Dampers	Tak Woo Engineering (Hong Kong) Limited	240	-	IANZ (New Zealand)	Building Research Association of New Zealand (BRANZ)	FAR 1713	3/9/2001	indefinite	31/1/2007	
BD-E034	Firetherm Fire Steel Classic	Firetherm Intum Escent & Insulation Supplies Ltd.	60	-	UKAS	WFRC	WFRC No. 123080 WFRC No. 100784	28/1/2001 22/10/1997	1/2/2007	31/1/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E035	Fire cut FM-900 intumescent coating	Yung Chi paint & Varnish Mfg. Co. Ltd. (supplied from Hop Kwan Engg. Co. Ltd.)	60	-	UKAS	Warrington Fire Research Centre Ltd.	C123992 & C110854	8/4/2002 1/11/1999	1/4/2007	31/1/2007	
BD-E036	9mm Promatect -H Board	PROMAT Int. (Asia Pacific) Ltd.	120	-	UKAS	Warrington Fire Research Centre Ltd.	WC80082	17/11/1992	31/3/2008	31/1/2007	
BD-E037	Nulifire S605 fire rated intumescent paint	Nullifire	60	-	UKAS	Building Research Establishment (BRE)	CC93309 Review 2	21/7/2003	21/7/2008	31/1/2007	
BD-E038	Durasteel	Gelec (HK) Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd.	C132908	28/10/2003	1/11/2008	31/1/2007	
BD-E039	Fire Shutter	Fire Shutter-Chung Tai Roller Shutter Co. Ltd.	240	-	IANZ	Building Research Association of New Zealand (BRANZ)	Far 2291 Issue 2	1/4/2005	1/4/2007	31/1/2007	
BD-E040	Chung Tai Fire Rated Roller Shutter	Chung Tai Roller Shutters Company Limited	120	-	IANZ	Building Research Association of New Zealand (BRANZ)	FAR 2291	1/4/2005	1/4/2007	31/1/2007	
BD-E041	'Monokote MK6' cementitious fire-proofing plaster	Standard Fire Protection Co.	242	242	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C127373	30/9/2002	1/10/2007	31/1/2007	
BD-E042	Light weight block wall	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	135393	15/8/1996	1/11/2008	31/1/2007	
BD-E043	Precast Concrete Block	K. Wah Construction Products Limited	240	233	UKAS	Warrington Fire Research Centre Ltd.	WFAssessment Report No. C114792 63257 146805	14/7/2000 14/3/1995 9/6/2005	1/8/2005 14/3/2000 1/6/2010	31/1/2007	
BD-E044	Durasteel	Intumen	240	240	UKAS	Building Research Establishment (BRE)	CC208842	28/5/2002	28/5/2007	31/1/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E045	Monokote MK6	Grace construction Products	120	120	UKAS	Warrington Fire Research Centre Ltd.	Assessment Report WFRC No. C127373 and Warres No. 51843	10/5/1991	1/10/2007	31/1/2007	
BD-E046	"Firecut FM-900" Fire Intumescent Paint	Yung Chi Paint & Varnish Mfg. Company Limited	60	60	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C110854	1/11/1999	1/4/2007	31/1/2007	
BD-E047	Durasteel 3DF2 Panel	Intumen Asia Pacific Pte Ltd.	60	60	UKAS	Building Research Establishment (BRE)	CC89388C	28/8/2001	28/8/2006	31/1/2007	
BD-E048	Promatect H for spandrel Wall Promatect H for Steel	Promat Int. asia Pacific Ltd.	120 60	- -	UKAS	Building Research Establishment (BRE)	CC90190A CC82518	21/2/2002	21/2/2007	31/1/2007	
BD-E049	Pyrok CV25 cementitious plaster	Pyrok Building Products Ltd.	120	120	UKAS	The Loss Prevention Council (BRE) Laboratory	TE7002	31/8/2004	-	31/1/2007	
BD-E050	Promatect-H 9mm thick enclosures	Promat Int. (Asia Pacific) Ltd.	120	-	UKAS	Building Research Establishment (BRE)	Assessment report no. CC83299	21/2/2002	21/2/2007	31/1/2007	
BD-E051	Y Tong Block	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	135393	15/8/1996	1/11/2008	31/1/2007	
BD-E052	Cafco Sprayfilm WB3	Cafco International	60	-	UKAS	Warrington Fire Research Centre Ltd.	139822	16/6/2004	1/7/2009	31/1/2007	
BD-E053	FRP Concrete Blockwork Wall	K.Wah Construction Products Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. SC 133194-Issue 2	17/12/2004	1/8/2008	31/1/2007	
BD-E054	S-605 Intumescent paint	Nullifire Ltd.	60	-	UKAS	Building Research Establishment (BRE)	BRE Assessment Report No. CC 93309 Review 2	21/7/2003	21/7/2008	31/1/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E055	Fire Shutter	Finetec.	240	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C111940	9/6/1999	1/3/2007	31/1/2007	
BD-E056	Fire Rated Roller Shutter	Chung Tai Roller Shutter Co., Ltd	180	-	IANZ	Building Research Association of New Zealand (BRANZ)	FAR 2291-Issue 2	1/4/2005	1/4/2007	31/1/2007	
BD-E057	Supalux Services Enclosure System	Cape Asia Pacific Ltd.	120	120	UKAS	Building Research Establishment (BRE)	CC94289	8/2/2002	8/2/2007	31/1/2007	
BD-E058	75mm Autoclaved Aerated Concrete Block	Daido Home International Limited	240	240	UKAS	Warrington Fire Research Centre Ltd.	C123262 Warres No. 54272	19/02/2002 16/08/1991	1/3/2007	31/1/2007	
BD-E059	(KINSUN) light-weight block	HUIZHOU XINYE Building Material Co. Ltd.	240	240	HOKLAS	Research Engineering Development Façade Consultants Ltd.	Test Report No. R05H02A1	14/09/2005	-	31/1/2007	
BD-E060	Autoclaved Aerated Concrete Block	Wealth Bridge Trading Co. Ltd	125	125	CNACL	Building Engineering Testing Centre China Academy Building Research	BETC-2001-F-036 BETC-NHPG-2003-8	24/7/2004	17/3/2003	30/4/2007	
BD-E061	Fire Shutter	Chung Tai	120	-	IANZ	Building Research Association of New Zealand (BRANZ)	BRANZ-FAR-2347 CC84607 & CC 91456A	7/10/2004	21/2/2007	30/4/2007	
BD-E062	Symmetrical non-load bearing block wall assembly	Daido Concrete (HK) Ltd. Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd	WARRES No. 68302 WFRC No. 135393	3/10/1996 20/10/2003	3/10/2001 1/11/2008	30/4/2007	
BD-E063	Flrecut FM 900	Yung Chi Paint & Varnish Mfg Co. Ltd.	60	-	UKAS	Warrington Fire Research Centre Ltd	WFRC No. C123992, C110854, C125331, C126749 & C115007	8/4/2002 21/6/2002 27/8/2002	1/4/2007 1/7/2007 1/9/2007	30/4/2007	
BD-E064	Y-Tong Block Wall	Y-Tong Ag	360	360	UKAS	Warrington Fire Research Centre Ltd.	WARRES NO. 54273	2/9/1991	1/8/2008	30/4/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E065	Sanwa shutter	Sanwa Shutter HK Ltd.	240	-	HOKLAS	Warrington Fire Research Centre Ltd	WFRC No. C80427 WFRC No. C80351	10/12/1992	1/2/2008	30/4/2007	
BD-E066	Nullifire 5605 Intumescent coating	Nullifire Ltd.	120	120	UKAS	Building Research Establishment (BRE)	CC93309 Rev.2	21/7/2003	21/7/2008	30/4/2007	
BD-E067	Fire resisting glass	Shenzhen Shekou Longdian Safety Technology Research Co Ltd.	60	60	CNACL	Building Engineering Testing Center	BETC-2001-F-002	17/1/2004	-	30/4/2007	
BD-E068	Supalux board	Cape Calsil Systems Ltd.	145	-	UKAS	Building Research Establishment (BRE)	CC10623	6/9/2002	6/9/2007	30/4/2007	
BD-E069	1) Promatect H Enclosure System	Promatect Int'l (Asia Pacific) Ltd.	120	120	UKAS	Building Research Establishment (BRE)	CC204567B	12/6/2003	12/6/2008	30/4/2007	
BD-E070	Promatect-H System	Promat International (Asia Pacific Ltd.)	240	240	UKAS	Building Research Establishment (BRE)	CC204567A	15/5/2003	15/5/2008	30/4/2007	
BD-E071	Steel Studs Promatect H smoke barrier system	Promat Int. Asia Pacific Ltd.	60	-	UKAS	Building Research Establishment (BRE)	CC84607	21/2/2002	21/2/2007	30/4/2007	
BD-E072	Roller Shutter for Loading & Unloading Area at G/F	Chung Tai	120	-	HOKLAS	BRANZ	FAR2296 FAR 2291	29/4/2004 19/4/2004	29/4/2006 19/4/2006	30/4/2007	
BD-E073	Pronatect 'H'	Promat Int'l (Asia Pacific) Ltd.	60	-	UKAS	Building Research Establishment (BRE)	CC 82518	21/2/2002	20/2/2007	30/4/2007	
BD-E074	Fireproofing coating to RC slab Cafco 280	Cafco International	120	120	UKAS	Warrington Fire Research Centre Ltd	WFRC No. 144066	20/12/2004	1/1/2007	30/4/2007	
BD-E075	"Y-tong" block	DAIDO HOME International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd	135393	20/10/2003	1/11/2008	30/4/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E076	Supalux Board	Cape Asia Pacific Ltd	120	-	HOKLAS	Building Research Establishment Ltd.	CC208228	2/4/2002	2/4/2007	30/4/2007	
BD-E078	Pire Rated Paint	Nullifire Ltd.	60	-	UKAS	Building Research Establishment (BRE)	CC92856B	10/4/2003	10/4/2008	30/4/2007	
BD-E079	Promastop -Unicollar	Promat Fyreguard Pty Ltd.	120	-	UKAS	Warrington Fire Research Consultancy	C81611b	8/8/2001	31/7/2006	30/4/2007	
BD-E080	Firecut FM-900	Yung Chi Paint & Varnish Mfg. Co. Ltd.	60	-	UKAS	Warrington Fire Research Centre Ltd	WFRC No. C123992 C110854 C126749 C115007	8/4/2002 1/11/1999 27/8/2002 31/7/2000	1/4/2007 1/12/2001 1/9/2007 1/8/2002	30/4/2007	
BD-E081	Vertical barrier	Promatect H smoke barrier	60	-	UKAS	Building Research Establishment (BRE)	CC84607	21/2/2002	21/2/2007	30/4/2007	
BD-E082	Nullifier S605 Intumescent Paint	Nullifire Ltd.	120	-	UKAS	Building Research Establishment (BRE)	CC93309	21/7/2003	21/7/2008	30/4/2007	
BD-E083	Mandolite CP2	Mandoval Ltd.	120	-	UKAS	Warrington Fire Research Consultant	WFRC No. C52252/ No.C132081B	31/10/2001	1/11/2006	30/4/2007	
BD-E084	Promastop UniCollar	Promat Fyreguard Pty Ltd.	120	120	NATA Australia	Warrington Fire Research (Aust.) PTY. Ltd.	WFRC No. SFC91611b-F	8/8/2001	31/7/2006	30/4/2007	
BD-E085	Durasteel Partition System	Intumex Asia Pacific Pte Ltd.	240	240	UKAS	Building Research Establishment (BRE)	CC87733	10/12/2002	10/12/2007	30/4/2007	
BD-E086	Performance of Promatect H insulated encloses	Promat Int. (Asia Pacific) Ltd.	60	60	UKAS	Building Research Establishment (BRE)	CC204567C	31/8/2001	31/8/2006	30/4/2007	
BD-E087	MONOKOTE MK-6	Grace Construction Products	240	-	UKAS	Warrington Fire Research Centre Ltd	C127373 & 51843	21/6/1991 30/9/2002	1/10/2007	30/4/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E088	Ruskin Curtain Type Fire Damper	Delta Pyramax Co. Ltd.	240	-	IANZ	Branz, The Resource Centre for Building Excellence	97/1057	18/4/1997	-	30/4/2007	
BD-E089	"Promat-H" Fired Rated Board for ducts & pipes	Cheung Wah Building Material Limited	120	-	UKAS	Building Research Establishment (BRE)	TE 89437	7/1/1998	-	30/4/2007	
BD-E090	Dura-steel Sheet	Cape Calsic Systems Limited	120	-	UKAS	Building Research Establishment (BRE)	CC 94333	22/3/2002	22/3/2007	30/4/2007	
BD-E091	Firetherm Fire Steel Classic	UK Firetherm Ltd.	60	60	UKAS	Warrington Fire Research Centre Ltd	WFRC 123080	28/1/2001	1/2/2007	30/4/2007	
BD-E092	S606	Nullfire	120	-	UKAS	Building Research Establishment (BRE)	CC92856A	10/4/2003	10/4/2008	30/4/2007	
BD-E093	Promatech-H	Promat Intl. (Asia Pacific) Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd	WFRS No. SC2641 WFRC No. C80082	7/3/2003 16/11/1992	31/3/2008 1/12/1994	30/4/2007	
BD-E094	Promatech-H' Fire Rated Board	-	60	-	UKAS	Building Research Establishment (BRE)	CC84607	21/2/2002	21/2/2007	30/4/2007	
BD-E095	Nullfire -S606	-	60	-	UKAS	Building Research Establishment (BRE)	BRE Assessment Report No.: CC92856A Rev. 2	-	10/4/2008	30/4/2007	
BD-E096	Y-Tong Block (600x200x100 thk)	DAIDO HOME International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd	WFRC No. 68302 WFRC No. 135393	3/10/1996 20/10/03	1/11/2008	30/4/2007	
BD-E097	Fire Rated Vertical Sliding Roller Shutter FRZ760	Chung Tai Roller Shutters Co. Ltd.	347	-	IANZ	Building Research Association of New Zealand (BRANZ)	FAR 2291 - Issue 2	1/4/2005	1/4/2007	30/4/2007	
BD-E098	Fire Shutter	Chung Tai Roller Shutter Co. Ltd.	120	-	IANZ	Building Research Association of New Zealand (BRANZ)	FAR 2291 - Issue 2	1/4/2005	1/4/2007	30/4/2007	
BD-E099	30 mm thick "Mandolite CP-2" spray (to structural steel)	Cafco International	-	120	UKAS	Warrington Fire Research Centre Ltd	WFRC No.C52252, WFRC No. C132081B	19/5/2003	1/6/2008	30/4/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E100	Dura-steel Rockwool	-	60	60	UKAS	Warrington Fire Research Loss Prevention Council	WFRC No. 136396 TE 6399	4/2/1993 25/9/1987	1/4/2009 -	30/4/2007	
BD-E101	Promatect H 20mm thk.	Promat International (Asia Pacific) Ltd.	120	-	UKAS	Warrington Fire Research Centre Ltd	WFRC No. C80092 WFRS No. SC2604	3/4/1992 17/11/2002	5/1994 1/12/2007	30/4/2007	
BD-E102	Sprayfilm WB3	Cafco International	120	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. 139822	16/6/2004	1/7/2009	30/4/2007	
BD-E103	Ytong	Daido Home Int'l Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	135393 & 68302	15/8/1996	1/11/2008	30/4/2007	
BD-E104	Y-Tong Block	Daido Home Int'l Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	68302	3/11/2001	1/11/2008	30/4/2007	
BD-E105	Firecut FM-900	Yung Chi Paint & Varnish Manufacturing Co., Ltd.	60	-	UKAS	Warrington Fire Research Consultancy	WFRC No. C110854, C123992	1/11/1999 8/4/2002	1/4/2007	30/4/2007	
BD-E106	Meilux - Fire Rated Louvre with GMS Louvre Blade	Keenven Limited	198	-	HOKLAS	Research Engineering Development Facade Consultants Limited	14H03B	26/8/2004	-	30/4/2007	
BD-E107	Mandolite CP2 Spray on fire proof Coating.	Mandoval Ltd.	240	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. CP92117, C118989, C132081A	5/3/1992 10/5/2001 19/5/2003	1/4/1994 1/6/2003 1/6/2008	30/4/2007	
BD-E108	Promatect H	Promat Int. (Asia Pacific) Ltd.	60	-	HOKLAS	Building Research Establishment (BRE)	CC91456A	24/2/2003	24/2/2008	30/4/2007	
BD-E109	'Monokote' FireproofingMK6	W. R. Grace & Co.-Conn.	60	-	UKAS	Warrington Fire Research Centre Ltd.	Warres No. 51843 WFRC No. C127373	10/5/1991 30/9/2002	- 1/10/2007	30/4/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E110	Promastop Unicollar	Promat Int. (Asia Pacific) Ltd.	120	120	HOKLAS	Warrington Fire Research Consultancy	WFRA No. CB8161b	8/8/2001	31/7/2006	30/4/2007	
BD-E111	Durasteel Board	Intumex Asia Pacific Pte Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd.	WFRS No. C132908 Test Report - CDL No. 659	28/10/2003	1/11/2008	30/4/2007	
BD-E112	"Long Dian"	-	32	32	CNACL	Building Engineering Testing Center	No. BETC-NH-2002-69BC(1)	2/12/2002	-	30/4/2007	
BD-E113	Promatect H Partition Flying Fish F500	Promatint (Asia Pacific) Ltd. Y Lee Chemicals Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd.	CC91456A 146137 112427	24/2/2003 7/4/2005 29/2/2000	24/2/2008 28/2/2010	30/4/2007	
BD-E114	Monokote MK-6 (FRP coating for steelworks)	Grace Limited	120	-	HOKLAS	Warrington Fire Research Consultants (UK)	WARRES No. 51843	10/5/1991	-	30/4/2007	
BD-E115	Performance of Promatect-"H" insulated enclosures	Promat International (Asia Pacific) Ltd.	174	174	UKAS	Building Research Establishment (BRE)	CC83299	21/2/2002	21/2/2007	30/4/2007	
BD-E116	Mandolite CP2 (9.5mm) Mandolite CP2 (18mm)	Mandoval Ltd. "Ceilina" "Wall"	120 120 240	- - -	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. CP92117, C118989, C132081A, C80520, C118491 & 132081C	5/3/1992 10/5/2001 19/5/2003 15/12/1992 10/5/2001 19/5/2003	1/6/2008	30/4/2007	
BD-E117	Ytong block wall	Daido Home International Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd.	Warres No. 68302	20/10/2003	1/11/2008	30/4/2007	
BD-E118	Cafco SparyFilm WB3	Cafco International	60	60	UKAS	Warrington Fire Research Centre Ltd.	WFRC C139823 & WFRC 139822	27/5/2004 16/6/2004	1/6/2009 1/7/2009	30/4/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E119	Vermitem AF - Fire Proof Plaster 22 mm.	L&A Fazzini Manufacturing Pty. Ltd.	120	-	-	CSIRO	FCO-1299	29/7/2002	31/7/2007	30/4/2007	
BD-E120	Ytong Autoclaved Aerated Concrete Block	Ytong	240	240	UKAS	Warrington Fire Research Centre Ltd.	WFRL Report No. 13593	20/10/2003	1/11/2008	30/4/2007	
BD-E121	Monokote MK6	Grace	242	-	UKAS	Warrington Fire Research Centre Ltd.	C127373	30/9/2002	1/10/2007	30/4/2007	
BD-E122	"Nulifire S605" Intumescent paint Coating	"Nulifire Ltd.	60	60	FRS	Building Research Establishment (BRE)	CC93309 Rev.2	21/7/2003	21/7/2008	30/4/2007	
BD-E123	Durasteel insulated ceiling membrane system	GELEC(HK) Limited	240	240	UKAS	Building Research Establishment (BRE)	WFRC CC 208842	28/5/2002	28/5/2007	30/4/2007	
BD-E124	Nullifire' S605 Intumescent paint	Nullifire Ltd.	60	-	UKAS	Building Research Establishment (BRE)	CC93309	21/7/2003	20/7/2008	30/4/2007	
BD-E125	Durasteel fire rated board	Intumex Asia Pacific Pte. Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. 141176	31/8/2004	1/9/2009	30/4/2007	
BD-E126	IBD Fire Damper	Delta Pyramax Company Ltd.	240	-	IANZ	Building Research Association of New Zealand (BRANZ)	97/1057	18/04/1997	Indefinite	30/4/2007	
BD-E127	Durasteel System	Intumex Asia Pacific Pte Ltd .	240	-	UKAS	Warrington Fire Research Centre Building Research Establishment (BRE)	WFRC No. 137687 WFRC No.C 132908 BRE Assessment Report No. CC87734	18/3/2004 28/10/2003 22/3/2002	1/3/2009 1/11/2008 22/3/2007	30/4/2007	
BD-E128	Cape Durasteel 4-sided Single-skin duct. system	Cape	120	-	UKAS	Building Research Establishment (BRE)	- CC87459	- 22/3/2002	- 22/3/2007	30/4/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E129	"Pyroplex" Fire Rated Silicone Sealant	Reddiplex Group	280	94	UKAS	Warrington Fire Research Centre Ltd.	Assessment Report no: C103808	2/9/2003	1/10/2008	30/4/2007	
BD-E130	Y-Tong	Daido Concrete (HK) Limited	120	120	UKAS	Warrington Fire Research Centre Ltd.	a) No.68302 b) No.135393	15/8/1996 20/10/2003	15/8/2001 1/11/2008	30/4/2007	
BD-E131	Monokote' Fireproofing Plaster to Structural Steel	W.R. Grace (HK) Ltd.	60	-	UKAS	Warrington Fire Research Centre Ltd.	C127373 51843	30/9/2002 21/6/1991	1/10/2007	30/4/2007	
BD-E132	fire shutter	SANWA SHUTTER (HK) LTD.	120	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. 129301	-	1/2/2008	30/4/2007	
BD-E133	Promat H	Promat Int. Asia Pacific Ltd.	120	-	UKAS	Building Research Establishment (BRE)	CC83299	21/2/2002	21/2/2007	30/4/2007	
BD-E134	Acrylic based gap sealing systems	Abesco Limited	240	-	UKAS	WFRC	C123723 C112894	6/3/2002 3/7/2000	1/4/2007 1/4/2002	30/4/2007	
BD-E135	Intumescent Coating	Nullifire Ltd.	60	-	UKAS	Building Research Establishment (BRE)	CC93058B	21/7/2003	21/7/2008	30/4/2007	
BD-E136	Promat H FRC Enclosure	Promat Int. Asia Pacific Ltd.	120	-	UKAS	Building Research Establishment (BRE)	CC83299	21/2/2002	21/2/2007	30/4/2007	
BD-E137	Y Tong (100mm thick blockwall)	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. 135393 WFRC No. 68302	20/10/2003 15/08/1996	01/11/2008 14/08/2001	30/4/2007	
BD-E138	Cafco SprayFilm WB3 Intumescent Coating	Cafco International	120	-	UKAS	Warrington Fire Research Consulting Testing	WFRC 144500	25/4/2005	1/5/2010	30/4/2007	
BD-E139	"Promatect-H" board	Brisky Limited	120	-	Promat Int. Asia Pacific Ltd.	BRE Fire and Risk Sciences Division	CC82518	21/2/2002	21/2/2007	30/4/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E140	Block wall	Y-Tong 675x200x100mm	240	240	UKAS	Warrington Fire Research Centre Ltd.	WFRC no. 135393	20/10/2003	1/11/2008	30/4/2007	
BD-E141	Promat	Promat International (Asia Pacific Ltd)	60	60	IANZ	Building Research Association of New Zealand (BRANZ)	99/1514-2	13/1/2000	Indefinite	30/4/2007	
BD-E142	Promatect	Promat Int. Asia Pacific Ltd.	120	-	UKAS	Building Research Establishment (BRE)	CC 83299	21/2/2002	21/2/2004	8/9/2005	
BD-E143	Promatect-S	Promat	120	-	UKAS	Building Research Establishment (BRE)	CC86559	1/2/2002	1/2/2007	31/1/2007	
BD-E144	9mm thk Promatect-fire rated Board	Promat Intl. (Asia Pacific) Ltd.	60	-	UKAS	Building Research Establishment (BRE)	CC84607	21/2/2002	21/2/2007	30/4/2007	
BD-E145	Ytong Wall 75 mm thk	DAIDO (H.K.) LTD.	150	150	UKAS	Warrington Fire Research Centre Ltd.	Warres No. 54272 & SFRC No. C123262	16/8/1991 19/2/2002	1/3/2007	30/4/2007	
BD-E146	Supalux board	Cape Asia Pacific Ltd.	120	-	UKAS	Building Research Establishment (BRE)	CC-208228	2/4/2002	2/4/2007	30/4/2007	-
BD-E147	Ytong Block Wall 75mm thk	Daido Home International Ltd.	150	150	UKAS	Warrington Fire Research Centre Ltd.	Warres No. 54272 & WFRC No. C123262	17/9/1991 19/2/2002	1/3/2007	30/4/2007	-
BD-E148	Promatect H (9 mm thk.)	Promat Int'l Asia Pacific Ltd.	60	60	INAZ	Building Research Association of New Zealand (BRANZ)	99/1514-2	13/1/2000	Indefinite	31/1/2007	
BD-E149	Promatect H Partition	Promat Int.(Asia Pacific) Ltd.	120	-	HOKLAS	Building Research Establishment (BRE)	CC91456A	24/2/2003	24/2/2008	8/9/2005	
BD-E150	Promatect H	Promat Intl. (Asia Pacific) Ltd.	240	240	-	Building Research Establishment (BRE)	CC204567A (review 1) CC87907	15/5/2003	15/5/2008	31/1/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E151	Proma-TECT-H	Promat Int' (Asia Pacific) Ltd.	120	-	-	Building Research Establishment (BRE)	CC91456A	24/2/2003	24/2/2008	31/1/2007	
BD-E152	Promate-H board	Promat	120	120	-	Building Research Establishment (BRE)	BRE CC 83701	21/2/2002	21/2/2007	31/1/2007	
BD-E153	Concrete block	Kin Lee Building Materials Ltd	180	180	UKAS	Warrington fire global safety research	121901 issue 4	2/5/2006	1/9/2008	31/1/2007	
BD-E154	Y-Tong Block Wall	Daido Home Int'l Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd	WFRC Report No. 135393 Test Report WARRES No. 68302	20/10/2003 3/10/1996	1/11/2008	30/4/2007	
BD-E155	Light Weight Concrete Blocks	HUIZHOU XINYE Building Material Co. Ltd.	120	120	HOKLAS	Research engineering Development Façade Consultants Limited	R05H02B1	24/8/2005	-	30/4/2007	
BD-E156	PROMATECT-H BOARD	Promat International (Asia Pacific) Ltd.	120	120	UKAS	Building Research Establishment (BRE)	CC89274	8/8/2003	8/8/2008	30/4/2007	
BD-E157	Promatect H Board	Promat Int. (Asia Pacific) Ltd.	240	10	UKAS	LPC (BRE) Laboratory	TE 89437 Supplement & Original Report TE 89437	26/2/2003 7/1/1998	Indefinite	30/4/2007	
BD-E158	Promatect-H Fire Rated Board	Promat Int. Asia Pacific Ltd.	60	-	UKAS	Building Research Establishment (BRE)	CC84607	21/2/2002	21/2/2007	30/4/2007	
BD-E159	Fire Shutter	Finetec Shutter Co. Ltd.	120	-	UKAS	Warrington Fire Research Centre Ltd.	WARRES No. C111940	2/3/2000	1/3/2007	30/4/2007	
BD-E160	Promatect H Fire Rated Board	Promat Int. (Asia Pacific) Ltd.	120	-	LPC (BRE) Laboratory	The Loss Prevention Council	TE 89437	26/2/2003	-	30/4/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E161	Fire Rated Roller Shutter	Chung Tai Roller Shutters Co. Ltd.	120	-	IANZ	Building Research Association of New Zealand (BRANZ)	FAR2291 Issue 2	1/4/2005	1/4/2007	30/4/2007	
BD-E162	Firecut FM-900	Yung Chi Paint & Varnish Manufacturing Co., Ltd.	60	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C110854, C123992	1/11/1999 8/4/2002	1/4/2007	22/11/2007	
BD-E163	Firecut FM900	Yung Chi Paint & Varnish Mfg. Co., Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C126749	27/8/2002	1/9/2007	22/11/2007	
BD-E164	Cape Durasteel 4-sided Single-skin duct. system	Cape	120	-	UKAS	Building Research Establishment (BRE)	CC87459	22/3/2002	22/3/2007	22/11/2007	
BD-E165	(2) Monokote MK-6 (FRP coating for steelworks)	Grace Limited	120	-	UKAS	Warrington Fire Research Consultants (UK)	WARRES No. 51843	10/5/1991	-	22/11/2007	
BD-E166	Fire Shutter	Finetec Shutter Co. Ltd.	120	-	UKAS	Warrington Fire Research Centre Ltd.	WARRES No. C111940	2/3/2000	1/3/2007	22/11/2007	
BD-E167	9mm Promatect -H Board	PROMAT Int. (Asia Pacific) Ltd.	120	-	UKAS	Warrington Fire Research Consultancy - Testing	WC80082	17/11/2002	31/3/2008	22/11/2007	
BD-E168	Fire Shutter	Fire Shutter-Chung Tai Roller Shutter Co. Ltd.	240	-	IANZ	Building Research Association of New Zealand (BRANZ)	Far 2291 Issue 2	1/4/2005	1/4/2007	22/11/2007	
BD-E169	Aerated concrete Blockwork Wall	(China) Zhanyi Light-Weight wall Material Co., Ltd.	240	240	UKAS	Warrington Fire Research Centre	WOO136	28/10/1999	-	22/11/2007	
BD-E170	Y-Tong Block 150mm thk	Daido Home International Ltd.	360	360	UKAS	Warrington Fire Research Centre Ltd.	WARRES No. 54273	2/9/1991	1/8/2008	22/11/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E171	Y Tong	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	Warress No. 68302 No. 135393	3/10/1996 20/10/2003	1/11/2008 1/11/2008	22/11/2007	
BD-E172	Supalux	Cape Asia Pacific Ltd.	120 240	- -	UKAS	Building Research Establishment Ltd. (BRE)	C208228	2/4/2002	2/4/2007	22/11/2007	
BD-E173	Vermitexaf Promatect Enclosure System	L&A Fazzini Man. Pty Ltd. Australia Promat Fire Pro. Ltd.	120 240	- -	NATA BRE	CSIRO Building Research Establishment (BRE)	FSH0007 CC88299	5/1989 2/2002	31/7/2007 21/2/2007	22/11/2007	
BD-E174	100mm Autoclaved Aerated Concrete Block	Daido Home International Limited	240	240	UKAS	Warrington Fire Research Centre Ltd.	WFRC Report No. 135393 Warres No. 68302	20/10/2003 3/10/1996	1/11/2008 3/10/2001	22/11/2007	
BD-E175	Y-tong Autoclaved Aerated Concrete Block	Daido Home International Limited	240	-	UKAS	Warrington Fire Research Centre Ltd.	WARRE No. 68302, WARRE No. 135393 review of 68032	15/8/1996 3/10/1996 20/10/2003	1/11/2008	22/11/2007	
BD-E176	Monokote MK6	WR Grace Ltd.	60	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C1273739 WARRES No. 51843 CC220133	10/5/1991	1/10/2007	22/11/2007	
BD-E177	Solid Concrete Block 390x125x190 (LxWxH)	K. Wah	240	233	UKAS	Warrington Fire Research Centre Ltd.	WARRES No. 63257 (Test Report)	6/2/1995	6/2/2000	22/11/2007	
BD-E178	PROMATECT H (9mm THK)	PROMAT IN. ASIA PACIFIC LTD.	120	120	UKAS	Building Research Establishment Ltd. (BRE)	CC 83299	21/2/2002	21/2/2007	22/11/2007	
BD-E179	Wins-mo9 MAGNESIUM OXIDE BOARD (PAISE CEILING)	好夫曼建材有限公司	122	95	CNACL	Building Engineering Testing Center China Academy of Buildings research	-	28/3/2003	-	22/11/2007	
BD-E180	Promatect-H Enclosures System	Promat	120 240	- -	UKAS	Building research and establishment Ltd.	BRE CC83299	21/2/2002	21/2/2007	22/11/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E181	Sprayed "Mandolite CP2" fire coating	Simon & Au Engineering Specialist Ltd. Report for Mandoval Limited	240	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C52252	19/11/1990	1/6/2008	22/11/2007	
BD-E182	Promat H 21mm Thick	Promat International Asia Pacific Limited)	240	240	IANZ	Building Research Association of New Zealand (BRANZ)	96/876 ISSUE2	14/8/2002	Indefinite	22/11/2007	
BD-E183	Fire Rate rolling shutters	Finetec Shutter Company Limited	120	-	UKAS	Warrington Fire Research Centre Ltd.	C111940 WFRC 111940	9/6/1999	1/3/2007	22/11/2007	
BD-E184	System S606	Nullfire	60	60	UKAS	Building research Establishment Ltd.	CC92856B CC92856A	10/4/2003	10/4/2008	22/11/2007	
BD-E185	100mm Autoclaved Aerated Concrete Block	Daido Home International Limited	240	240	UKAS	Warrington Fire Research	WFRC Report No. 135393 Warres No. 68302	1/11/2008	-	22/11/2007	
BD-E186	Promat Board	Promat Int. (Asia Pacific) Ltd.	120	120	BRE LTD	Building Research Establishment Ltd.	CC81468A	24/2/2002	24/2/2008	22/11/2007	
BD-E187	'Durasteel' Sheet	Brisky Limited	120	60	UKAS	Building Research Establishment Ltd.	BRE CC87459	22/3/2002	22/3/2007	22/11/2007	
BD-E188	75mm thick Y-Tong Block (Location, please see attachment)	Wing Heng Bldg. National Co.	160	160	UKAS	Warrington Fire Research Centre	WFRC No. 54272 WFRC No. 123262	16/8/1991 19/2/2002	1/3/2007	22/11/2007	
BD-E189	Monokote MK-6 Spray applied coating system	Grace Construction Products	60	60	UKAS	Warrington Fire Research Centre	Test Report No. 51843	21/6/1991	1/10/2007	22/11/2007	
BD-E190	A3, "Promat-H" fire rated partition & ceiling	Promat International (Asia Pacific) Ltd.	120	120	LPC/UKAS	BRE/Warrington Fire Research	BRE CC81584A rev 2, CC83071 WFRC C80001	25/2/2003 21/2/2002 10/9/2003	25/2/2008 21/2/2007 1/9/2008	22/11/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E191	Firecut FM 900	Yung Chi Paint & Varnish Mfg. Co., Ltd.	60	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C123992 (review to report WFRC No. C110854 as attached)	8/4/2002	1/4/2007	22/11/2007	
BD-E192	"Vermitec AF" Proof Plaster	L&A Fazzini Manufacturing Pty. Ltd.	60	-	NATA	C.S.I.R.O.	FCO1504	2/6/2000	30/6/2010	22/11/2007	
BD-E193	CAFCO 300 Dry thickness in 30 mm	CAFCO Internal	120	120	UKAS	Building Research Establishment Ltd.	CC20699/8	17/4/2004	4/3/2007	22/11/2007	
BD-E194	"Ytong " Brand 100x200x675mm AAC Blocks	Daido Concrete (HK) Limited	240	240	UKAS	Warrington Fire Research Centre Ltd.	(1) Warres No. 68302 (2) WFRC Report No. 135393	15/8/1996 20/10/2003	15/8/2001 1/11/2008	22/11/2007	
BD-E195	Promatect H board 9mm	Promat International (Asia Pacific) Ltd.	120	120	UKAS	Warrington Fire Research Centre	135602	28/10/2003	1/11/2008	22/11/2007	
BD-E196	"Promatect- H" 2 hr. F.R.P. Fire Rated Ceiling System	Promat Int. (Asia Pacific) Ltd.	240	10	UKAS	BRE Limited	TE 89437 (Supplement)	26/2/2003	-	22/11/2007	
BD-E197	Fire Resistance Board	Promat Int. Asia Pacific Ltd.	120	-	The Loss Prevention Council	Warrington Fire Research Centre	TE 89437	7/1/1998	-	22/11/2007	
BD-E198	Y-Tong	Daido Home Int'l Ltd.	360	360	UKAS	Warrington Fire Research Centre	WFRC No.54273	2/9/1991	1/8/2008	22/11/2007	
BD-E199	Durasteel Floor Assembly	Intumex Asia Pacific Pte Ltd.	120	120	UKAS	Warrington Fire Research	136396	22/3/2004	1/4/2009	22/11/2007	
BD-E201	Monokote MK6	W.R. Grace Ltd.	120	-	UKAS	Warrington Fire Research Centre	C127373 & 51843	30/9/2002 10/5/1991	1/10/2007	22/11/2007	
BD-E202	Rainbow Fire Cut FM-900	Yung Chi Paint & Vanish Mfg.Co. Ltd.	60	60	UKAS	Warrington Fire Research Centre	WFRC No. C123992 WFRC No. C110854 WFRC No.C125252	8/4/2002 1/11/1999 19/6/2002	1/4/2007 1/12/2001 1/7/2007	22/11/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E203	Monokote MK5	-	240	240	UKAS	Warrington Fire Research Centre Ltd.	Assessment Report No. WFRC No. C127373	-	1/10/2007	22/11/2007	
BD-E204	"Firecut" FM 900 Intumescent Coating	Yung Chi Paint & Vanish Mfg.Co. Ltd.	60	-	UKAS	Warrington Fire Research Centre	WFRC No. C123992, C110854, C126749, C115007 & C125331	8/4/2002 1/11/1999 27/8/2002 31/7/2000 19/6/2002	1/4/2007 1/12/2001 1/9/2007 1/8/2002 1/7/2007	22/11/2007	
BD-E205	Promatech H Board	Delta Pyramax Co. Ltd.	174	174	UKAS	BRE & LPC Testing	BRE No. CC 83299	21/2/2002	21/2/2007	22/11/2007	
BD-E206	Monokote MK6	Sherex Engineering Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C111709	11/1/2000	1/2/2009	22/11/2007	
BD-E207	SprayFilm WB3 Intumescent Coating	Cafco Europe Group SA (Trading as) Cafco International	120	120	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. 152624	29/3/2006	1/3/2011	22/11/2007	
BD-E208	Mandolite CPZ	Cafco International	240	240	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C132081B/ WFRC No. C52252	19/5/2003	1/6/2008	22/11/2007	
BD-E209	Rolling Shutter	Finetec Shutter Co. Ltd.	120	-	UKAS	Warrington Fire Research Centre	WFRC No. C123370	19/2/2002	1/3/2007	22/11/2007	
BD-E210	"YTONG" Autoclaved Aerated Concrete Block	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre	135393	20/10/2003	1/11/2008	22/11/2007	
BD-E211	Nullifire S605	Nullifire Ltd.	60	-	HOKLAS	Building Research Establishment Ltd.	CC93058B Review 2	13/7/1999	21/7/2008	22/11/2007	
BD-E212	Sanwa	Sanwa Shutter (HK) Ltd. HK	120	-	HOKLAS	Warrington Fire Research Centre	C80427 C129301 C80351 C129303	10/11/1992 6/1/2003 15/4/1993 6/1/2003	- 1/2/2008 - 1/2/2008	22/11/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E213	Promatect H Insulated Enclosure	Promat Int. (Asia Pacific) Ltd.	120	120	HOKLAS	Building Research Establishment Ltd	CC 204567B Rev.1	12/6/2003	12/6/2008	22/11/2007	
BD-E214	Pyroplex Intumescent Sealant	Henry Engineering & Supplies O/B Good Stride	-	-	UKAS	Warrington Fire Research	WFRC No.C103808	20/1/1998 2/9/2003	1/10/2008	22/11/2007	
BD-E215	Unitherm 38091	Permatex GmbH	-	120	UKAS	Warrington Fire Research Centre	WFRC No. 133394, C117433, 128560, C105561 & C125126	10/7/2003 13/2/2001 27/11/2002 8/2/1999 3/7/2002	- 1/3/2003 1/12/2007 1/3/2001 1/8/2007	22/11/2007	
BD-E216	Y -tong blocks	Daido Home International Limited	240	240	UKAS	Warrington Fire Research Ltd.	135393	20/10/2003	8/11/2008	22/11/2007	
BD-E217	Precast concrete solid brick	K. Wah Construction Products Ltd.	120	-	UKAS	Warrington Fire Research Consultants (UK)	WARRES No. 63257, 114792 & 146805	6/2/1995	1/6/2010	22/11/2007	
BD-E218	Fireproofing Plaster	PYROK	120	120	UKAS	Warrington Fire Research Centre	147474	22/6/2005	1/7/2010	22/11/2007	
BD-E219	Promat S board 6mm thickness	Promat Fire Protection Ltd. Promat Int' (Asia Pacific) Ltd.	120	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC Report No. 133193	28/7/2003	1/8/2008	22/11/2007	
BD-E220	"Promatect H" fire-rated board	Promat International Asia Pacific Ltd.	60	-	UKAS	Building Research Establishment (BRE)	BRE No. CC84607	21/2/2007	21/2/2007	22/11/2007	
BD-E221	1 Hr. FRP Promat Board Smoke Barrier	Promat International (Asia Pacific) Ltd.	60	-	UKAS	Building Research Establishment (BRE)/LPC	TE89437	26/2/2003	25/2/2008	22/11/2007	
BD-E222	Pyrok CV25 Cementitious Plaster	Pilot Fire Rated Company	326	-	UKAS	LPC Laboratories/Building Research Establishment (BRE)	TE 7002 (Supplement)	24/8/1989 31/8/2004	-	22/11/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E223	Promatech H insulated enclosure	Promat Int. (Asia Pacific) Ltd.	120	120	UKAS	Building Research Establishment (BRE)	CC 204567B	12/6/2003	12/6/2008	22/11/2007	
BD-E224	Ytong Autoclaved Aerated Concrete Block	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre	68302 135393	15/8/1996	1/11/2008	22/11/2007	
BD-E225	Monokote MK6 Fire Proofing Plaster	W.R. Grace Ltd.	242	242	UKAS	Warrington Fire Research Centre	C127373 51843	30/9/2002 21/6/1991	1/10/2007	22/11/2007	
BD-E226	Augreen Gypsum Blocks	Ca SO(HK) Eng. Co. Ltd.	240	240	HOKLAS	Research Engineering Development Façade Consultants Ltd.	I4L19	3/12/2004	21/2/2007	22/11/2007	
BD-E227	Fire Roller Shutter	Bostwick Bo-Shan Shutter Co.	240	-	UKAS	Warrington Fire Research Centre	WFRC No. C124737	6/9/2002	1/9/2007	22/11/2007	
BD-E228	2hr FRP Ytong Blocks	Davido Concrete (HK) Ltd.	240	240	UKAS	Warrington Fire Research Centre	WFRC 135393 Warres 68302	15/8/1996 20/1/2003	1/11/2008	22/11/2007	
BD-E229	Monokote MK6 Fire Proof Plastic	Grace Cnstruction Product - W.R. Grace & Co	240	240	UKAS	Warrington Fire Research Centre	WFRC No. C111709	12/1/2004	1/2/2009	22/11/2007	
BD-E230	Lightweight Concrete Blocks	Jiangmen Nanjian New Walling Materials Co. Ltd.	120	-	NATA	Warrington Fire Research Centre Ltd. & Warrington Fire Research (Aust) Pty Ltd.	WFRC No. C127854 WFRA No. 40924	24/10/2002 5/9/2002	-	22/11/2007	
BD-E231	"Ytong" Aerated Concrete Block	Dadio Home International Ltd.	158	158	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C123262	19/2/2002	1/3/2007	22/11/2007	
BD-E232	Vertical Fire Rated Roller Shutter	Chung Tai Roller Shutters Co., Ltd	180	-	IANZ	Building Research Association of New Zealand (BRANZ)	FAR 2291- Issue 2	1/4/2005	1/4/2007	22/11/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E233	Nullifire S606	Nullifire Limited	60	60	UKAS	Building Research Establishment (BRE)	CC92856A CC92856B	10/4/2003	10/4/2008	22/11/2007	
BD-E234	Cafco 300	Cafco International	60	60	UKAS	Building Research Establishment (BRE)	CC206998	17/4/2002	4/3/2007	22/11/2007	
BD-E235	Nullifire S606 Intumescent Coating	Nullifire Ltd.	120	-	UKAS	Building Research Establishment (BRE)	CC92856A	10/4/2003	10/4/2008	22/11/2007	
BD-E236	Firex Board	Nullifire Ltd.	60	60	UKAS	Building Research Establishment (BRE)	CC212613	19/10/2004	11/8/2008	22/11/2007	
BD-E237	Promatect H.	Promat Int'l (Asia Pacific Ltd.)	120	-	UKAS	Building Research Establishment (BRE)	CC84975	9/1/2007	9/1/2012	22/11/2007	
BD-E238	Fire Shutter (Vertical Type)	Suzuki Shutter Co (HK) Ltd.	240	-	UKAS	Warrington Fire Research	WFRC No. C81766 WFRC No. C132345 WFRC No. C43912	20/5/2003 13/7/1995 30/9/1988	1/6/2008 1/8/1997 30/9/1990	22/11/2007	
BD-E239	Grace Monokate Fireproofing System-Z146	Grace Construction Products	120	120	UKAS	Warrington Fire Research Centre	C81831 C101088 C111709 134446	30/8/1995 4/11/1997 11/1/2000 9/9/2003	1/10/1997 1/12/1999 1/1/2002 1/1/2008	22/11/2007	
BD-E240	Phoenix 270 Intumescent Coating	Phoenix Fire Protection (Asia) Ltd.	120	120	UKAS	International Fire Consultants Ltd.	IFCA 05196 IFCA 05199	7/1/1990	1/7/2010	22/11/2007	
BD-E241	Vnitherm 38091	Dupont Protective Coatings GmbH & Co. Kg.	60	-	UKAS	Warrington Fire Research Centre	WFRC No. 133394	10/7/2003	-	22/11/2007	
BD-E243	Fire Shutter	Choi Hung Roller Gate & Blacksmith Fty. Ltd.	120	-	HOKLAS	Research Eng. Development Facade Consultants Ltd.	13G16	27/8/2003	-	22/11/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E244	Fire Shutter	Finetec Shutter Company Limited	240	-	UKAS	Warrington Fire Research Centre	WFRC No. C111940 WF Report No. 162611	2/3/2000 12/3/2007	1/4/2012	22/11/2007	
BD-E245	Promatect H Board	Promat Int. (Asia Pacific) Ltd.	-	-	UKAS	Building Research Establishment (BRE)	CC 82518	21/2/2002	21/2/2007	22/11/2007	
BD-E246	Nullifire S605 intumescent coating	Knauf	60	60	UKAS	Building Research Establishment Ltd.	CC93058B Review 2	21/7/2003	21/7/2008	22/11/2007	for hollow sections
BD-E247	Durasteel	Delec (HK) Ltd.	240	-	UKAS	Building Research Establishment (BRE)	CC 90131	22/3/2002	22/3/2007	22/11/2007	
BD-E248	YTONG Block	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Ltd.	WRFC No.135393	20/10/2003	1/11/2008	22/11/2007	
BD-E249	Fire cut FM-900 intumescent coating	Yung Chi Paint & Varnish Mfg. Co. Ltd. (supplied from Hop Kwan Engg. Co. Ltd.)	60	-	UKAS	Warrington Fire Research Centre Ltd.	C123992 C110854	8/4/2002 1/11/1999	1/4/2007	22/11/2007	
BD-E250	Nullifine S606	Nullifine Limited	60	-	HOKLAS	Building Research Establishment (BRE)	CC92856A	10/4/2003	10/4/2008	22/11/2007	BD-FD 061
BD-E251	Promatect H Board 9mm thk.	Promat International (Asia Pacific) Ltd.	120	120	UKAS	Building Research Establishment (BRE)	CC83299	21/2/2002	21/2/2007	22/11/2007	
BD-E252	Y TONG BLOCK	daido Home International Ltd.	158	158	UKAS	Warrington Fire Research Centre Ltd.	54272	16/8/1991	-	22/11/2007	
BD-E253	Firecut FM-900	Yung Chi Paint & Varnish MFG. Co. Ltd,	120	-	UKAS	Warrington Fire Research Centre Ltd	WFRC No. C125252 & C125331	19/6/2002	-	22/11/2007	
BD-E254	Y-Tong AAC Block 75mm	Daido Building Materials Ltd.	158	158	UKAS	Warrington Fire Research Centre	WARRES No.: 54272, WFRC No.: C123262	16/8/1991	1/3/2007	22/11/2007	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E255	Durasteel	-	240	240	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C132908	28/10/2003	1/11/2008	7/1/2008	
BD-E256	Nullfire S605	Nullfire Limited	60	60	UKAS	Building Research Establishment (BRE)	CC903588	21/7/2003	21/7/2008	7/1/2008	
BD-E257	Durasteel	Intume Asia Pacific Pte Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. 141176	4/2/1993	1/9/2009	7/1/2008	
BD-E258	Firecut FM-900	Yung Chi Paint & varnish Mfg Co Ltd.	120	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C125252	19/6/2002	1/7/2007	7/1/2008	
BD-E259	Nullfire S605 intumescent coating	Nullfire Limited	120	-	UKAS	Building Research Establishment (BRE)	CC93309 Review 2	21/7/2003	21/7/2008	7/1/2008	
BD-E260	"VERMIT EXAF" Fire Proof Plaster	Sherex Eng. Ltd.	240	240	NATA	CSIRO Manufacturing & Infrastructure Technology	FCO-1299	29/7/2002	31/7/2007	7/1/2008	
BD-E261	Y Tong Block wall	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	WFRC Report No. 135393 WARRES No. 68302	20/10/2003 3/10/1996	1/11/2008	7/1/2008	
BD-E262	Firetherm Firesteel Classic 120	Firetherm Intumescent and Insulation Supplies Ltd.	60	60	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C130414	6/3/2003	1/4/2008	7/1/2008	
BD-E263	Fire Shutter	Suzuki Shutter Company (Hong Kong) Ltd.	240	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No.:C81766, C132345	20/5/2003	1/6/2008	7/1/2008	
BD-E264	Promat	Promat Int. (Asia Pacific) Ltd.	120	-	UKAS	Building Research Establishment (BRE)	CC91456A	23/10/1998	24/2/2008	7/1/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E265	Firexboard	Polygon Building Materials Ltd.	60	-	UKAS	Building Research Establishment (BRE)	CC223535	1/6/2005	1/6/2010	7/1/2008	For smoke barrier
BD-E266	Y-Tong Block	Daido Home International Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd.	WARRES No. 54272 WR Report No. 161791	16/8/1991 13/2/2007	1/3/2012	7/1/2008	
BD-E267	Promatech-H Spandrel Wall System	Promat International (Asia Pacific) Ltd.	120	-	UKAS	Building Research Establishment (BRE)	CC 90190A Review 3	14/2/2007	21/2/2012	7/1/2008	
BD-E268	Monokote MK6	Wing Kai Fire Protection Engineering Ltd.	120	120	UKAS	Warrington Fire Research Ltd.	WFRC 127373 WARRES 51843	21/6/1991	1/10/2007	7/1/2008	
BD-E269	Promatect H Partition	Promat Int. (Asia Pacific) Ltd.	120	-	UKAS	Building Research Establishment (BRE)	91456A	24/2/2003	24/2/2008	7/1/2008	
BD-E270	Fire Shutter	Chung Tai Roller Shutters Co. Ltd.	240	-	IANZ	Building Research Association of New Zealand (BRANZ)	FAR 1659-1	7/11/2000	-	7/1/2008	
BD-E271	Fire Shutter	Sanwa Shutter (HK) Ltd.	60	-	UKAS	Warrington Fire Research Consultancy	C80427	10/12/1992	1/2/2008	7/1/2008	
BD-E272	Promatect H	Promat International (Asia Pacific) Ltd.	120	120	UKAS	Building Research Establishment (BRE)	BRE CC 83300 Review 4	12/1/2007	12/1/2012	7/1/2008	
BD-E273	Fire Shutter	Sanwa Shutter (HK) Limited	120	-	UKAS	Warrington Fire Research Consultancy	WFRC No. C129303 C80351 C80427 C129303	15/4/1993	1/2/2008	7/1/2008	
BD-E274	"Firex" FRP Ceiling	New City Resources Inc.	300	-	UKAS	Building Research Establishment (BRE)	CC212613 review 1	29/4/2005	29/4/2010	7/1/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E275	Fibertex - 350 Rockwool	CSR, BUILDING MATERIALS (HK) LTD.	-	-	SAC	PSB Corporation	545034 137/C/LGJ	26/8/2003 27/8/2003	1/8/2008	7/1/2008	
BD-E276	100mm Autoclaved Aerated Concrete	深圳市宏開輕質牆體材料有限公司	260	260	HKAS	HOKLAS	PA935	21/5/2007	-	7/1/2008	
BD-E277	Wins - M09 board	Hong Kong Wins consultants Limited	60	60	HOKLAS	Research Engineering Development Facade Consultants Limited (RED)	13804A	17/2/2003	-	7/1/2008	
BD-E278	Unitherm 38091 : intumescent paint	Gold Hero Engineering Ltd.	60	60	UKAS	Warrington Fire Research Centre Ltd.	No. C1263392 Issue 3	22/7/2004	-	7/1/2008	
BD-E279	Mandolite CP2 Fire Proection Materials	Mandoval Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C52252	19/11/1990	-	7/1/2008	
BD-E280	Pyroswiss Extra Glazed Suspended Smoke Screen	Vetrotech Saint-Gobain (International) AG	60	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C116968	16/10/1997	1/6/2008	7/1/2008	
BD-E281	"Y-Tong" Autoclaved Aerated Concrete Block	Daido Home International Limited	240	240	UKAS	Warrington Fire Research Centre Ltd	Warres No. 68302 & WFRC Report No. 135393	15/8/1996	1/11/2008	7/1/2008	
BD-E282	Promatect H (9mm)	Promat Int. (Asia Pacific) Ltd.	240	10	UKAS	LPC Laboritics BRE	TE89437	7/1/2003	7/1/2008	7/1/2008	
BD-E283	Promat H	Promat Int. (Asia Pacific) Ltd.	60	-	UKAS	Building Research Establishment (BRE)	CC91456A	24/2/2003	24/2/2008	7/1/2008	
BD-E284	Nullifire S605	Nullifire Limited	60	-	UKAS	Building Research Establishment (BRE)	CC93058B Review 2	21/7/2003	21/7/2008	7/1/2008	
BD-E285	Firecut FM-900 Fire Intumescent Paint	Sherex Engineering Ltd	60	60	CNACL	Yung Chi Paint & Varnish Mtg. Co. Ltd.	145918	1/7/2001	18/4/2007	7/1/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E286	Durasteel SOF2	Intumex Asia Pacific Ltd.	120	120	UKAS	Building Research Establishment (BRE)	CC 89388 C Review 3	12/9/2006	12/9/2011	39454	
BD-E287	Non-loadbearing Blockwall Assembly	daido Concrete (H.K.) Limited	240	240	UKAS	Warrington Fire Research Centre Ltd.	Warrington No. 68302	15/8/1996	1/11/2008	7/1/2008	
BD-E288	Monokote MK-6	W.R. GRACE	60	-	UKAS	Warrington Fire Research Consultancy	Warres No. 51843	30/9/2002	1/10/2007	7/1/2008	
BD-E289	Firecut FM900	Yung Chi Paint & Varmish Mfg Co., Ltd	60	-	UKAS	Warrington Fire Research Centre	WFRC No. 145918	27/7/2006	1/7/2011	7/1/2008	
BD-E290	YTONG autoclaved aerated concrete block (100mm)	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre	WFRC No. 135393	20/10/2003	1/11/2008	7/1/2008	
BD-E291	F.R.P. enclosure	Firex Board	120	120	IANZ	Building Research Association of New Zealand (BRANZ)	2707	10/1/2000	-	7/1/2008	
BD-E292	Knauf	Knauf HK Ltd.	60	-	UKAS	Building Research Establishment (BRE)	CC220133	17/11/2004	17/11/2009	7/1/2008	
BD-E293	Firecut FM-900 Fire Intumescent	Yung Chi Paint & Varnish Mtg. Co. Ltd.	60	-	UKAS	Warrington Fire Research Consultancy	145918	27/7/2006	1/7/2006	7/1/2008	
BD-E294	Firecut FM900	Yung Chi Paint & Varnish Mfg	60	-	UKAS	Warrington Fire Research Centre Ltd.	EFRC No. C110854/145918	27/7/2006	1/7/2011	7/1/2008	
BD-E295	Mandolite CP2	Mandoval Coatings Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C52252 WFRC No. C132081B	19/11/1990 19/05/2003	- 1/06/2008	7/1/2008	
BD-E296	Promatect H 12mm thick	Promat International(Asia Pacific) Ltd.	120	-	UKAS	Building Research Establishment (BRE)	BRE cc 84975 review 5	9/1/2007	8/1/2012	7/1/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E297	YTONG Block	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	WFRC Report No. 135393 & 134167	20/10/2003 18/08/2003	1/11/2008 1/08/2008	7/1/2008	
BD-E298	Firecut FM900 Intumescent Paint	Yung Chi Paint & Varnish Mfg. Co. Ltd.	-	-	UKAS	Warrington Fire Research Centre Ltd.	145918	17/7/2006	1/7/2011	7/1/2008	
BD-E299	CAFCO 300 Fire Proof Plaster	Cafco Europe Group SA	120	120	UKAS	Building Research Establishment (BRE)	CC 206998 review	30/4/2007	30/4/2012	7/1/2008	
BD-E300	Nullfire S605 Fire Intumescent Paint	Sherex Engineering Ltd	60	60	UKAS	Building Research Establishment (BRE)	CC93309 CC93058B	10/8/1999 21/7/2003	21/7/2003 21/7/2008	7/1/2008	
BD-E301	Kinsun Lightweight Concrete Block	East Trend Engineering Co., Ltd.	240	240	HOKLAS	Research Engineering Development Facade Consultants Limited (RED)	Test : R05H02A1 Assessment: R06B12	Test: 22/82005 Assessment: 24/3/2006	23/3/2008	7/1/2008	
BD-E302	Nullfire S605 Intumescent Coating for Columns	Nullfire Limited	60	60	UKAS	Building Research Establishment (BRE)	CC93309 review 2	21/7/2003	20/7/2008	7/1/2008	
BD-E303	Mnonkote MK6	W.R. Grace 7 Co.	240	-	UKAS	Warrington Fire Research Centre Ltd.	51843	21/6/1991	-	7/1/2008	
BD-E304	Firex Board	New City Resources Inc.	60	-	-	FEFTC	FT04091	25/6/2004	-	7/1/2008	
BD-E305	Duite Steel floor system	Yung Kee Wing Cheung Metal Co. Ltd.	60	60	UKAS	Warrington Fire Research Centre Ltd.	C132908	-	1/11/2008	7/1/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E306	Firecut FM900 Pyrok CV25	Yung Chi Paint & Varnish Mfg. Co. Ltd. Pyrok Bldg Products Ltd.	>156 326	- -	UKAS	Warrington Fire Research Centre Ltd.	C125331 164159 TE7002	19/6/2002 13/6/1989	31/8/2004 8/5/2007	7/1/2008	
BD-E307	Rock Wool 80mm thick	GELEC (HK) Limited	120	-	UKAS	Warrington Fire Research Centre Ltd.	C132908	28/10/2003	1/11/2008	7/1/2008	
BD-E308	YTong Block	Daido Home International Ltd.	158	158	UKAS	Warrington Fire Research Centre Ltd.	Warres No. 54272	16/8/1991	1/3/2007	7/1/2008	
BD-E309	Promatect H Partition System	Promat International (Asia Pacific) Ltd.	120	-	UKAS	Building Research Establishment (BRE)	CC91456A	23/10/1998 24/02/2003 (Review)	24/2/2008	7/1/2008	
BD-E310	"YTONG Autoclaved Aerated Concrete Block	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	Warres No. 68302 WFRC Report No. 135393	15/08/1996 20/10/2003	01/11/2008 01/11/2008	7/1/2008	
BD-E311	Durasteel Board	Intumax Asia Pacific Ltd.	60	-	UKAS	Warrington Fire Research Ltd.	WFRC Assessment Report No. 138676	19/5/2004	1/6/2009	20/8/2008	
BD-E312	2 HRS FRP Mandolite CP2 cementitious fire coating	Mandoval Coatings Limited	120	120	UKAS	Warrington Fire Research Consultants	WFRC No. C52252	1/11/1990	Indefinite	20/8/2008	
BD-E313	Firecut FM-900 Intumescent Coating	Yung Chi paint & Varnish Mfg Co Ltd.	60	60	UKAS	Warrington fire Research Centre	WFRC No. C110854 WF No. 145918	1/11/1999 27/7/2006	1/7/2011	20/8/2008	
BD-E314	YTONG Autoclaved Aerated Concrete Block	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	Warres No. 68302 WFRC No. 135393	3/10/1996 22/10/2003	3/10/2001 1/11/2008	20/8/2008	
BD-E315	Promatact H partition	Promat Int. (Asia Pacific) Ltd.	120	-	UKAS	BRE	CC91456A	24/2/2003	24/2/2008	20/8/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E316	1. Fireproofing coating to steel- "Mandolite CP2"	-	120	120	UKAS	Warrington Fire Research Centre WFRC no. C52252	-	-	-	20/8/2008	
BD-E317	Promatect H partition	Promat Int. (Asia Pacific) Ltd.	120	-	HOKLAS	BRE 2003	CC91456A	23/10/1998 24/2/2003	24/2/2008	20/8/2008	--
BD-E318	YTONG CONCRETE BLOCK	DAIDO CONCRETE(HK) LTD.	240	240	UKAS	Warrington Fire Research Ltd.	68302 135393	15/8/1996	1/11/2008	20/8/2008	--
BD-E319	Firetherm Firesteel	Firetherm Intumescent and Insulation Supplies Ltd.	60	-	UKAS	Warrington Fire Research	C130413	6/3/2003	1/4/2008	20/8/2008	--
BD-E320	Durasteel ceiling membrane	Cape durasteel Limited	240	17	UKAS	Loss Prevention Council	TE83248	1/12/2006	-	20/8/2008	
BD-E321	Monokote MK6	Grace construction Products	2 hr.	120	UKAS	Warrington fire Research Centre Ltd.	Assessment Report WFRC No. C127373 and Warres No. 51843	-	1/10/2007	20/8/2008	
BD-E322	Sprayed Limpet Vermiculite	Thermica	120	120	UKAS	Warrington Fire Research	WFRC No. C80641 & C130154	13/2/2003	1/3/2008	20/8/2008	
BD-E323	Pyroplex Intumescent Acylic	Reddiplex Group Plc	-	-	UKAS	WFRC	C103808 Issue 3	2/9/2003	1/10/2008	20/8/2008	
BD-E324	Y Tong Concrete	Dadio Home International Ltd.	-	-	UKAS	Warrington Fire Research Centre	WFRC135393 & WARRES 68302	20/10/2003	1/11/2008	20/8/2008	
BD-E325	100mm TR. Y-Tong Light Weight Block Wall	Daido Concrete (H.K.) Ltd.	240	240	UKAS	Warrington Fire Research	Warres No. 68302	15/8/1996	1/11/2008	20/8/2008	
BD-E326	Fire Protection Board	Lyrids	153	13	HOKLAS	Research Engineering Development Façade Consultants Ltd.	R06H13	22/9/2006	-	20/8/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E327	Halspan TM 70 Prima Doorsets	Power Creation Engineering Ltd.	60	-	UKAS	Chiltern Int'l Fire Ltd.	FEA/F96103 Rev.F.	1/7/2003	1/7/2008	20/8/2008	
BD-E328	Nullifire S605	Grace Construction Products	120	-	UKAS	BRE Testing	CC 93309 Review 2	21/7/2003	20/7/2008	20/8/2008	
BD-E329	Coopers Fire Master Fire Curtain	Coopers Blinds Ltd.	240	-	UKAS	BRE	CC92945 Review 1	3/3/2004	3/3/2009	20/8/2008	
BD-E330	Durasteel panel	Hunh Team (China) Limited	240	240	UKAS	BRE	CC83683A Review 4	28/5/1993	24/9/2008	20/8/2008	
BD-E331	Supalux spandrel wall system	Intumex Asia Pacific Pte. Ltd. Nullifire Limited	120	120	UKAS	BRE	CC91384 Review 1	15/3/2004	15/3/2009	20/8/2008	
BD-E332	Ytong Acc Block	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	68302 135393	15/8/1996 20/10/2003	N-A 1/11/2008	20/8/2008	
BD-E333	Fire Shutter	Sanwa Shutter (HK) Ltd.	60	-	UKAS	Warrington Fire Research Centr	WFRC No. C129301	6/1/2003	1/2/2008	20/8/2008	
BD-E334	Promatect H fire rated board	BRANZ	120	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C80082 9911414-2	13/1/2007	13/1/2007	20/8/2008	
BD-E335	Durasteel	Intumex Asia Pacific Pte Ltd.	120	-	UKAS	Warrington Fire Research Centre	WFRC C132908	-	1/11/2008	20/8/2008	
BD-E336	Promatect H Board	Promat International (Asia Pacific Ltd)	-	120	UKAS	BRE	CC82518	21/2/2002	-	20/8/2008	
BD-E337	Promatect Board	Promat Int. (Asia Pacific) Ltd.	120	-	-	BRE	CC 91456A	24/2/2003	24/2/2008	20/8/2008	
BD-E338	Ytong	Daido Home International Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd.	WARRES No. 68302 & WFRC No. 135393	15/8/1996 20/10/2003	20/10/2006 1/11/2008	20/8/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E339	Monokote MK6	W.R. Grace & Co. Construction Products Division	60	-	UKAS	Warrington	51843 C127373	21/6/1991 30/9/2002	- 1/10/2007	20/8/2008	
BD-E340	Y-tong block	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research	WFRC No. 135393	20/10/2003	1/11/2008	20/8/2008	
BD-E341	Y-tong block	Ytong Hong Kong Ltd.	120	120	UKAS	Warrington	WFRC C123262	19/2/2002	1/3/2007	20/8/2008	
BD-E342	Remitherm PMA1200	Audax	120	-	UKAS	Warrington Fire Research Centre	WFRC No. 156366	12/7/2006	1/8/2011	20/8/2008	
BD-E343	Light Weight Concrete Block Partition	Jiangmen Nanjian New Walling Materials Co., Ltd.	202	202	NATA Australia	Warrington Fire Research (Aust.) PTY Ltd.	WFRA No. 40924	29/8/2002	Indefinite	20/8/2008	
BD-E344	Light Weight Concrete Block Size: 600 x 200 x 100mm	Shenzhen Hong Kai Lightly Wall Material Co., Ltd.	260	260	HOKLAS	Research Engineering Development Façade Consultants Ltd.	R06K15	1/12/2006	-	20/8/2008	
BD-E345	Promatect-H Board	Promat Int. (Asia Pacific) Ltd.	240	-	BRE	LPC Laboratories	TE 89437	26/2/2003	-	20/8/2008	
BD-E346	Promatech partition system and steel stud	Promat Int. (Asia Pacific) Ltd.	240	-	UKAS	Building Research Establishment Ltd. 2002	CC 83071	29/1/1993	21/2/2007	20/8/2008	
BD-E347	Y-tong	Daido Home International Ltd.	240	240	UKAS+HOKLAS	Warrington Fire Research Ltd.	68302 135393	20/10/2003	1/11/2008	20/8/2008	
BD-E348	Y-tong	Daido Home International Ltd.	240	240	UKAS+HOKLAS	Warrington Fire Research Ltd.	68302 135393	20/10/2003	1/11/2008	20/8/2008	
BD-E349	WINS M-09 board partition	Wins Consultants Ltd.	60	60	HOKLAS	RED Façade Consultants Ltd.	13B04A	18/3/2003	-	20/8/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E350	Suzuki Shutter Company (H.K.) Ltd.	-	240	-	UKAS	Warrington Fire Research Ltd.	C81766 & C132345	20/5/2003	1/6/2008	20/8/2008	
BD-E351	Fire Access Panel	New City Resources Inc.	240	-	IANZ	BRANZ LTD	FAR 2306	2/6/2004	-	20/8/2008	
BD-E352	Promatech H Board (9mm thick)	Promat International (Asia Pacific) Ltd	120	120	UKAS	BRE	CC 83071 CC 83071 review 2	21/2/2002 23/2/2007	21/2/2002 23/2/2007	20/8/2008	
BD-E353	"Monokote MK6" Spray on Fireproof Coating	"Grace Construction Products"	60	-	UKAS	Warrington Fire Research	WARRES No. 51843 WFRC No. C101583 & C127373	21/6/1991 10/12/1997 30/9/2002	01/1/2003 1/10/2007	20/8/2008	
BD-E354	Fire Resistance Fire Shutter	Chung Tai Roller Shutters Co. Ltd.	120 120	-	IANZ	Building Research Association of New Zealand (BRANZ)	FAR 1659-1 FAR 2296-Issue 2	7/11/2000 29/4/2006	Indefinite 29/4/2011	20/8/2008	
BD-E355	"Spray Film WB3" intumescent paint	Cafco International	120	120	UKAS	Warrington Fire Research Centre	WFRC 139822 & 139823	16/6/2004 27/5/2004	1/7/2009	20/8/2008	
BD-E356	9mm Thick "Promatect H" Board	Promat	120	-	UKAS - U.K.	BRE	BRE Assessment Report No. CC 83300 Review 4	12/1/2007	12/1/2012	20/8/2008	
BD-E357	Fire Proof Glass	深圳市龍電科技實業有限公司	60	-	CNAC	Building Engineering Test Center China Academy of Building Research	BETC-NH-2006-201	7/4/2006	6/4/2011	20/8/2008	
BD-E358	Fire Proof Plastic Mandolite	Mandoval CP2" Ltd.	120	-	UKAS	Warrington Fire Research Centre Ltd.	C132081B NFRC No. C52252	19/5/2003	1/6/2008	20/8/2008	
BD-E359	Mandolite CP2	Cafco International	120	-	UKAS	Warrington Fire Research Consultancy Testing	WFRC CP92117 WFRC C1/8989 WFRC C132081A	5/3/1992 10/5/2001 19/5/2003	1/4/1994 1/6/2003 1/6/2008	20/8/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E360	Nullifire S605 Intumescent: Coating	Nullifire Ltd.	60	60	UKAS	BRE	CC 93309	21/7/2003	21/7/2008	20/8/2008	
BD-E361	Light Weight Concrete Block Size: 600 x 200 x 100mm	Shenzhen Hong Kai Lightly Wall Material Co., Ltd.	240	240	HOKLAS	Research Engineering Development Façade Consultants Ltd.	R06K15	1/12/2006	indefinite	20/8/2008	
BD-E362	Firetherm Firesteel Classic 120	Firetherm Intumescent Insulation Supplies Ltd.	60	60	UKAS	Warrington Fire Research Centre	WFRC No. C130414	6/3/2003	1/4/2008	20/8/2008	
BD-E363	Lightweight concrete block (600mm x 200mm x 100mm)	Jiangmen Nanjian New Walling Materials Co. Ltd.	202	202	UKAS	Warrington Fire Research Centre	WFRC 40924	24/10/2002	1/11/2007	20/8/2008	
BD-E364	Fire Door	R&R Fire Material Co.	60	60	HOKLAS	RED.	R07J17	2/10/2007	1/10/2007	20/8/2008	
BD-E365	YTONG Autoclaved Aerated Concrete Block	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Consultancy	Warres No. 68302 WFRC No. 135393	3/10/1996 20/10/2003	1/11/2008	20/8/2008	
BD-E366	Promatect-H fire rated board	Cheung Wah Building Material Limited	120	120	UKAS	Warrington Fire research	WFRC No. C80092 WFRC No. 117970/A WFRC No. SC2604	30/5/1992 5/3/2001 17/11/2002	5/1994 1/4/2003 1/12/2007	20/8/2008	
BD-E367	Firecut FM-900 Intumescent Coating	Yung chi paint & varnish Mtg. Co. Ltd	60	-	UKAS	Warrington-fire global safety	WF Report No. 145918	27/7/2006	1/7/2011	20/8/2008	
BD-E368	Monokote Fire Proofing MK 6	GRACE	242	-	UKAS	Warrington Fire Research	51843	-	1/10/2007	20/8/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E369	Nullifire' S605 Intumescent paint 1 Hr. Fireproofing Paint	Nullifire Ltd.	N/A	-	UKAS	Building Research Establishment Ltd.	CC93309	21/7/2003	20/7/2008	20/8/2008	
BD-E370	6mm Durasteel access panels	Intumex Asia Pacific Pte Ltd.	120	-	UKAS	BRE	CC 203964	8/4/2003	8/4/2008	20/8/2008	
BD-E371	9mm thk. Promatect-H	Promat International (Asia Pacific) Ltd.	60	-	UKAS	BRE	CC84607 Review 4	13/2/2007	21/2/2012	20/8/2008	
BD-E372	Locally made blade type fire damper	Wing Shing Air-flow Co. Ltd. (supplied by Chevalier (HK) Ltd.)	240	-	HOKLAS	Research Engineering Development Façade Consultants Ltd.	R07K29	20/11/2007	indefinite	20/8/2008	
BD-E373	Nullifire S606	Nullifire Limited	60	60	UKAS	BRE	CC92856A CC92856B	10/4/2003	10/4/2008	20/8/2008	
BD-E374	-	Permatex GmbH	120	120	UKAS	Warrington Fire Research Centre	b)WFRC No. 133394	10/7/2003	1/6/2007	20/8/2008	
BD-E375	"Promatect H" enclosure for building services	Promat International (Asia Pacific) Ltd.	121 240	-	UKAS	BRE	CC83299 Review 4	23/2/2007	23/2/2008	20/8/2008	
BD-E376	Pyrok CV25	Pyrok Building Products Limited	120	-	UKAS	BRE testing	TE7002	31/8/2004	-	20/8/2008	
BD-E377	Pyrok CV25	Pyrok Building Products Limited	120	-	UKAS	WFRC WRC	147474 23300	22/6/2005	1/7/2010	20/8/2008	
BD-E378	Phoenix 168	Phoenix Fire Protection (Asia) Ltd.	60	-	UKAS	Warringtonfire	WFRC No. 160031 WFRC No. 126964	1/12/2006 30/9/2002	1/12/2011	20/8/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E379	TANDA Vertical Curtain Damper	TANDA International Company Ltd.	240	-	IANZ	BRANZ Limited	FR3400	22/2/2005	Indefinite	20/8/2008	
BD-E380	Fire Shutter	Suzuki Shutter (HK) Ltd.	120	-	HOKLAS	Warrington Fire Research Consultancy Testing	WFRC No. C132 345 WFRC No. 136 742	20/5/2003 13/1/2004	1/6/2008 1/2/2009	20/8/2008	
BD-E381	Steelcraft	Jardine Engineering Corporation Ltd.	240	-	UKAS	Warrington Fire Research Centre	C102262/ C81279	12/5/2003 12/9/2003	31/5/2008 30/9/2008	20/8/2008	
BD-E382	Finetec Shutter Company Ltd (HK)	Finetec Shutter Company Ltd.	120	-	China National Accreditation Board for Laboratories	Building Engineering Testing Centre, China Academy of Building Research	BETC-NHPG-2005-14	20/6/2005	20/6/2008	20/8/2008	
BD-E383	Firecut FM-90B	Yung Chi Paint & Varnish Mtg. Co., Ltd.	60	-	UKAS	Warrington Fire Global Safety Testing	WF No. 145918	27/7/2006	1/7/2011	20/8/2008	
BD-E384	Y-Tong block	Daido	60	-	UKAS	WFRC	54772 151791	17/9/1991	1/3/2012	20/8/2008	
BD-E385	Monokote MK6	W.R. Grace & Co.	60	60	HOKLAS	Warrington Fire Research Centre Ltd.	WFRC No. C111709 WFRC No. 122550 WFRC No. 136861	11/1/2000 18/12/2001 12/1/2004	1/2/2002 1/1/2004 1/2/2009	20/8/2008	
BD-E386	Y Tong (Light wt come blak)	Daido Home International Ltd	60	60	UKAS	Warrington Fire Research Consultancy-Testing	No. 68302	15/9/1996	1/11/2008	20/8/2008	
BD-E387	Firecut FM900	Yung Chi Paint & Varnish Mfg	60	-	UKAS	Warrington Fire Research Ltd.	WFRC No. C110854 WFAR No. 145918	1/11/1999 17/7/2006	1/7/2011	20/8/2008	
BD-E388	"Durasteel 3DF2" fire-rated panel	Intumex Asia Pacific Pte Ltd	120	120	UKAS	BRE Testing	CC89388C	12/9/2006	12/9/2011	20/8/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E389	"Mandolite CP2" fireproofing coating	Univic Engineering Ltd.	120	-	UKAS	Warrington Fire Research Centre	WFRC No. C52252, WFRC No. C132081B	19/5/2003	1/6/2008	20/8/2008	
BD-E390	AAC Block GMS Fire Fam Eng. Shutter Ltd.	Wealth Bridge	120	120	HOKLAS UKAS	Research Eng. Dev. Façade Consl. Bre Cert. Ltd.	R07J09A CC026122	20/9/2007 2/1/2002	indefinite 17/5/2012	20/8/2008	
BD-E391	Promatect-H Board for Smoke Barriers	Promat International (Asia Pacific) Ltd.	120	-	UKAS	Warringtonfire global safety	WF Report No.: 156468 (Test Report: TE89437, TE6371A)	29/8/2006	1/8/2011	20/8/2008	
BD-E392	Cafco 300 Superpanel	Cafco Knauf	60	-	Less Prevention Certification Board	BRE	CC206998 Review 1 CC229949	30/4/2007 6/6/2006	29/4/2012 5/6/2011	20/8/2008	
BD-E393	Firecut FM 900	Yung Chi Paint & Varnish Mtg. Co. Limited	60	-	UKAS	Warrington Fire Research Ltd. Warringtonfire Global Safety	WFRC Report No. C110854 WF Assessment Report No. 145918	1/11/1999 17/7/2006	1/12/2001 1/7/2011	20/8/2008	
BD-E394	Firecut FM 900	Yung Chi Paint & Varnish Mtg. Co. Limited	60	-	UKAS	Warrington Fire Research Ltd. Warringtonfire Global Safety	WFRC Report No. C110854 WF Assessment Report No. 145918	1/11/1999 27/7/2006	1/12/2001 1/7/2011	20/8/2008	
BD-E395	Autoclaved Aerated concrete Block	Shenzhen Hong Kai Lightly Wall Material Company Limited	195	195	HOKLAS	Red Research Engineering Development Façade Consultants Limited	R06K15B	1/12/2006	-	20/8/2008	
BD-E396	Autoclaved Aerated concrete Block	Shenzhen Hong Kai Lightly Wall Material Company Limited	195	195	HOKLAS	Red Research Engineering Development Façade Consultants Limited	R06K15B	1/12/2006	-	20/8/2008	
BD-E397	Ytong' block wall	Daido Concrete (H.K.) Ltd.	240	240	UKAS	Warrington Fire Research Ltd.	135393	20/10/2003	1/11/2008	20/8/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E398	Concrete Brick (100mm thick)	Wealth Bridge Trading Company Limited	245	213	UKAS	Warrington Fire Research Ltd	W00030B	3/12/1998	-	20/8/2008	
BD-E399	Concrete Brick (100mm thick)	Wealth Bridge Trading Company Limited	245	213	UKAS	Warrington Fire Research Ltd	W00030B	3/12/1998	-	20/8/2008	
BD-E400	9mm thk Promatect-H fire rated Partition system	Promat Intl. (Asia Pacific) Ltd.	120	120	UKAS	BRE	CC 83071 Review 2 CC 83071	23/2/2007 21/2/2002	23/2/2008 21/2/2007	20/8/2008	
BD-E401	Promat Partition System	Promat Int. Asia Pacific Ltd	120	120	UKAS	BRE	CC 83071	29/1/1993	23/2/2008	20/8/2008	
BD-E402	2 hour Promatect-H enclosure to general building services	Promat Int. (Asia Pacific) Ltd.	120	120	UKAS	BRE Testing	CC83299 review 4	21/2/2002	23/2/2008	20/8/2008	
BD-E403	2 hour FRP intumescent paint Firecut FM-900	Yung Chi Paint & Varnish Mfg. Company Limited	120	120	UKAS	Warrington Research Centre Ltd.	WFRC No. C125252 WFRC No. 164158	8/5/2007	1/6/2012	20/8/2008	
BD-E404	75mm Thk. Autoclaved Aerated Concrete Block Wall System	Shengzhen Hong Kai Lightly Wall Material Company Limited	195	195	HOKLAS	Research Engineering Development Façade Consultants Ltd.	R06K15B	1/12/2006	-	20/8/2008	
BD-E405	Autoclaved Acrated Concrete Block	Daido Home International Limited	360 240	360 240	UKAS	Warrington Fire Research Centre Limited	54273 134167 135393 68302	3/10/1991 18/8/2003 20/10/2003 3/10/1996	1/8/2008 1/11/2008	20/8/2008	
BD-E406	Promat H	Promat International (Asia Pacific) Ltd	181	130	UKAS	BRE	CC 224611	19/5/2006	18/5/2011	20/8/2008	
BD-E407	Y-Tong Block	Dai Do Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	Warres No. 68302 WFRC - 135393	3/10/1996 20/10/2003	3/10/2001 1/11/2008	20/8/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E408	Durasteel 3DF2 Vent Duct	Intumex Asia Pacific Pte Ltd	120	-	UKAS	BRE	CC 86889 Rev. 3	14/6/2007	14/6/2012	20/8/2008	
BD-E409	Suzuki Fire Shutter	Suzuki Shutter Company (HK) Ltd	240	-	HOKLAS	Research Engineering Development Façade Consultants Ltd	R07E08 (Review to R05C23)	15/5/2007	14/5/2009	20/8/2008	
BD-E410	Pyrok CV25 cementitious plaster	Easy Smart Engineering Ltd.	60	-	UKAS	LPC (BRE)	TE7002	31/8/2004	-	20/8/2008	
BD-E411	75 mm thick Ytong block	Daido Home International Ltd.	158	158	UKAS	Bodycote Warrington Fire	WF Report No. 161791	16/8/1991 13/2/2007	1/3/2012	20/8/2008	
BD-E412	Cafco Sprayfilm WB3	Cafco Europe Group SA	120	120	UKAS	Warrington Fire Research Centre	WF Assessment Report No. 144500 Issue 3	25/4/2005	1/4/2010	20/8/2008	
BD-E413	Durasteel Floor System	Intumex Asia Pacific Pte. Ltd.	240	240	UKAS	Building Research Establishment Ltd	CC 83683A Review 4	24/10/2003	24/9/2008	20/8/2008	
BD-E414	Promatech H Ventilation and smoke vent outlet duct systems (20mm thk)	Promat International (Asia Pacific) Ltd.	180	90	UKAS	BRE	CC88388 Rev 3	14/9/2007	14/9/2012	20/8/2008	
BD-E415	Durasteel Services Enclosures	Intumex Asia Pacific Pte Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C132908	28/10/2003	1/11/2008	20/8/2008	
BD-E416	Promatect H	Promat International (Asia) Pacific Ltd	60	-	UKAS	BRE	CC84975 Review 5	18/4/2002	9/1/2012	20/8/2008	
BD-E417	FRP S.S. Door	Honestice Engineering Co. Ltd.	120	-	UKAS	Warrington Fire Research	WFRA No. 45987	23/5/2006	31/5/2011	20/8/2008	
BD-E418	Fire Shutter	SUZUKI	120	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C81766 & C136742	13/1/2004	1/2/2009	20/8/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E419	2 hrs. FRP "Promina 60 smoke barrier"	Promat Int. Asia Pacific Ltd.	-	-	UKAS	BRE	CC 206010 Review	4/10/2006	30/10/2011	20/8/2008	
BD-E420	Firetherm Firesteel Classic 120	Firetherm Intumescent & Insulation Suppliers Ltd.	60	-	UKAS	Warrington Fire Research Centre	WFRC no. C130414	6/3/2003	1/4/2008	20/8/2008	
BD-E421	Lightweight YTONG blockwall	Daido Concrete (HK) Ltd.	240	240	UKAS	Warrington	WARRES No. 68302 WFRC Report No. 135393	15/8/1996 20/10/2003	- -	20/8/2008	
BD-E422	Promatect H Partition	Promet International (Asia Pacific) Ltd.	120	-	UKAS	BRE	CC91456A	24/2/2003	24/2/2008	20/8/2008	
BD-E423	Supalux	Intumex Asia Pacific Pte Ltd	120	120	UKAS	Warrington Fire Research Consultancy	WFRC No. C131668	21/5/2003	1/6/2008	20/8/2008	
BD-E424	Knauf Superpanel Partition	Knauf H.K. Limited	120	120	UKAS	BRE	CC215829	21/1/2004	21/1/2009	20/8/2008	
BD-E425	Pyroplex Intumescent acrylic sealant	Reddiplex Group Plc.	240	-	UKAS	Warrington Fire Research centre Ltd.	EFRC No. C103808	20/1/1998	1/10/2008	20/8/2008	
BD-E426	Suzuki fire Shutter	Suzuki Shutter Co. (HK) Ltd.	120	-	UKAS	Bodycote Warringtonfire Testing	EF Report No. 165264 WFRC Report No. 132345 No. C81766	26/6/2007 20/5/2003 14/7/1995	1/7/2012 1/6/2008	20/8/2008	
BD-E427	Roller Shutter	Suzuki Shutter Company (HK) Limited	240	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C81766	14/7/1995	1/8/1997	20/8/2008	
BD-E428	Firecut FM-900 Intumescent Coating	Yung Chi paint & Varnish Mfg Co Ltd.	120	120	UKAS	Warrington Fire Research Centre	WFRC No. C125331 and WF No. 164159	19/6/2002 8/5/2008	19/6/2002 1/6/2012	20/8/2008	
BD-E429	Nullifire S605	Pyrotech	120	-	UKAS	BRE 2003	CC93309 CC93058B	10/8/1999 13/7/1999	21/7/2008 21/7/2008	20/8/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E430	Mandolite CP2	Cafo International	60	60	UKAS	Warrington Fire Research consultants	WARC No. C52252	19/5/2003	1/6/2008	20/8/2008	
BD-E431	Pyroplex fire seal For joint of fireseal board	Henry Engineering & Supplies	280	-	UKAS	Warrington fire research	WFRC No. C103808	2/9/2003	1/10/2008	20/8/2008	
BD-E432	Firesteel Classic	Firetherm Intumescent nand Insulation Supplies Ltd.	60	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C130414	6/3/2003	1/4/2008	20/8/2008	
BD-E433	Phoenix 167	Phonenix Fire Protection (Asia) Ltd.	60	-	UKAS	Warrington fire Research Centre	WFRC Report no. 143912	20/12/2004	1/1/2010	20/8/2008	
BD-E434	Firecut FM-900	Tai Hing Hong	60	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C115007 WF No. 164160	31/7/2000 8/5/2007	1/8/2002 1/6/2012	20/8/2008	
BD-E435	Firecut FM-900	Wing Chi Paint & Varnish Mfg. Company Limited	60	-	UKAS	Warrington fire Research Centre	WFRC No. C115007 WF No. 164160	31/7/2000 8/5/2007	1/08/2002 1/6/2012	20/8/2008	
BD-E436	Firecut intumescent Paint	I.R.E. Corporation (HK) LTD.	60	-	UKAS	Warrington Fire Research	WFRC No. C115007	19/7/2000	1/6/2012	20/8/2008	
BD-E437	Nullifire	Nullifire Ltd.	60	-	UKAS	BRE	CC 92856A	11/4/2003	10/4/2008	20/8/2008	
BD-E438	Nullifire S606	Nullifire Ltd.	60	-	UKAS	BRE	CC 92856A	11/4/2003	10/4/2008	20/8/2008	
BD-E439	Fire Rated Door	New Century Engineering Co.	78	64	HOKLAS	Research Engineering Development Façade Consultants Ltd.	I2J18B	10/12/2002	indefinite	20/8/2008	
BD-E440	Y Tong Block	Daido Home International Ltd.	158	158	UKAS	Warrington fire Research Centre	54272	16/8/1991	1/3/2012	20/8/2008	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E441	Lightweight concrete blockwork wall (Y-tong Block-wall)	Daido Home International Limited	240	240	UKAS	Warrington Fire Research Centre Ltd.	WFRA No. 68302	15/8/1996	1/11/2008	20/8/2008	
BD-E442	9mm thk Promatech H	Promat Int (asia Pacific) Ltd	60	-	UKAS	BRE	CC 91456A	24/2/2003	24/2/2008	20/8/2008	
BD-E443	Fire Shutter	Sun Shing Engineering Co.	120	-	IANZ	Branz Limited	FAR 3044	13/8/2007	13/8/2012	20/8/2008	
BD-E444	Concrete Brick (101mm thick)	Wealth Bridge Trading Company Limited [Shunde, China]	245	213	UKAS	Warrington Fire Research Ltd	135199	7/10/2003	1/11/2008	20/8/2008	
BD-E445	Concrete Brick (101mm thick)	Wealth Bridge Trading Company Limited	245	213	UKAS	Warrington Fire Research Ltd	135199	7/10/2003	1/11/2008	20/8/2008	
BD-E446	Falk Country Limited	Falk Country Limited	245	213	UKAS	Warrington Fire Research Centre Ltd.	C135119 for 100x150x300m	7/10/2003	1/11/2008	24/2/2009	
BD-E447	Supaluz enclosures to Building Services	Intumex (Asia Pacific) Ltd.	240	240	UK Fire Test Study Group Resolution No. 82:2001	Warrington Fire research Consultancy	WF Report No. 169326	5/12/2007	1/1/2012	24/2/2009	
BD-E448	Fire Proofing Plaster (1HR FRP)	PYROK CV25 Cementitions/ Vermiculite	60	-	UKAS	Warrington Fire Research Ltd.	WF Report No.147474	22/6/2005	1/7/2010	24/2/2009	
BD-E449	Y Tong Block	Daido Home International Limited	240	240	UKAS	Warrington Fire Research Ltd.	68302/135393	15/8/1996 3/10/1996	1/11/2008	24/2/2009	
BD-E450	YTong	Daido Concrete (H.K.) Ltd.	240	240	UKAS	Warrington Fire Research Ctr.	135393 68302	20/10/2005 15/8/1996	1/11/2008 15/8/2001	24/2/2009	
BD-E451	Monokote MK6	WR Grace Limited	120	120	UKAS	Warrington Fire Research Centre Ltd.	Warres No. 51843 WFRC No. C127373 WF Report No. 165722	10/5/1991 30/9/2002 12/7/2007	- 1/10/2007 1/8/2012	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E452	Tanda Vertical Curtain Dampers	Branz Ltd.	244	-	INAS	Branz	FR3400	22/2/2005	-	24/2/2009	
BD-E453	Pyrok CV25	Greatec Eng. Ltd	120	-	UKAS	Warrington Fire Research Centre Ltd.	WF Report No. 147474	22/6/2005	1/7/2010	24/2/2009	
BD-E454	Nullifire S606 Intumescent Coating	-	60	-	UKAS	BRE	CC92856A Review 3	19/3/2008	10/4/2013	24/2/2009	
BD-E455	Fire proof plaster - Mandolite CP2	Mandoval	120	-	UK Fire Test Study Group	Warrington Fire Research Centre	Nam On Engineering Certificate KL/RPH/070710/L WFRC No. C52252	7/2007 11/ 1990	- -	24/2/2009	
BD-E456	Firecut FM-900	Yung Chi Paint & Varnish Mfg Co. Ltd.	120	-	UKAS	Warrington Fire Research Centre Bodycote Warringtonfire Testing	WFRC No. C125252, C115007 WF No. 164158, C164160	19/6/2002 8/5/2007 31/7/2000 8/5/2007	1/7/2007 1/6/2012 1/8/2002 1/6/2012	24/2/2009	
BD-E457	Nullifire S606	Nullifire Ltd.	120	-	UKAS	Building Research Establishment	CC 92856A Review3	19/3/2008	10/4/2013	24/2/2009	
BD-E458	Pyrok CV25 cementitious plaster	Pyrok Building Products Ltd.	120	120	UKAS	The Loss Prevention Council (BRE) Supplement Report to TE 7002	TE 7002	7/1989 31/8/2004	-	24/2/2009	
BD-E459	Promatect H (~9mm thk in 1 layer)	Promat Int. (Asia Pacific) Ltd.	120	-	UKAS	-LPC -Bodycote Warrington Fire - BRE	Test Report TE89437; WF Assessment Report No.169576 Supplementary Report to TE89437	7/1/1998 16/12/2007 26/2/2003	- 1/1/2013	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E460	FIRE RATED CEILING SYSTEM "LYRIDS"	GOLDEN LYRIDS CONSTRUCTION MATERIALS LTD.	240	227	CNACL	BUILDING ENGINEERING TESTING CENTER CHINA ACADEMY OF BUILDING RESEARCH	BETC-NH-2007-335(A)	8/6/2007	-	24/2/2009	
BD-E461	Firecut FM900	Yungchi Paint & Varnish Mt.9 Co Ltd.	30	-	UKAS	Warrington Fire Research Centre	WF No. 145918	17/7/2006	1/7/2011	24/2/2009	
BD-E462	Promatest - H Board	Promat (International Asia Pacific) Ltd.	120	120	UKAS	Warrington Fire Research Centre	169576	19/12/2007	1/1/2013	24/2/2009	
BD-E463	Promatect Int. Asia pacific Ltd.	-	60	-	UKAS	Building Research Establishment (BRE)	CC84975	9/1/2007	9/1/2012	24/2/2009	
BD-E464	Firecut FM-900	Yuing Chi Paint & Varish Mfg Co. Ltd.	60	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C110854 WF Assessment report no. 145918	1/11/1999 27/7/2006	1/12/2001 1/7/2011	24/2/2009	
BD-E465	Ytong	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Consultant	WFRC No. 135393	20/10/2003	1/11/2008	24/2/2009	
BD-E467	Durasteel Fire Rated Board	Intumex Asia Pacific Pte Ltd	120	120	UKAS	Warrington fire Research Centre Ltd	WFRS No. 141176	10/11/1992	1/9/2009	24/2/2009	
BD-E468	Y-Tong Block, 100mm	Daido Conc. (HK) Ltd.	240	240	UKAS	Warrington fire Research Centre	WARRES 68302 WFRC135393	21/10/2003	1/11/2008	24/2/2009	
BD-E469	Dura-Steel	Intumex Asia Pacific Pte Ltd.	120 240	120 240	UKAS	Warrington Fire Research Centre	WFRC 136396	22/3/2004	1/4/2009	24/2/2009	
BD-E470	Pyrok CV25	Pyrok Building Products Limited	120	-	UKAS	The Loss Prevention Council (BRE) Laboratory	Supplement Report to TE 7002	31/8/2004	-	24/2/2009	(BD-E049)
BD-E471	Nullifire S605	Nullifire Ltd.	120	120	UKAS	BRE	CC93058B (Review 2)	21/7/2003	21/7/2008	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E472	Nullifire S606 Intumescent Coating	-	60	-	UKAS	BRE	CC92856A Review 3	19/3/2008	10/4/2013	24/2/2009	
BD-E473	FIRECUT FM-900	Yung Chi Paints & Varnish Mfg. Co. Limited	60	-	UKAS	Warrington Fire Research Centre	145918 125331 164159	19/3/2008	1/7/2011 1/7/2007 1/6/2012	24/2/2009	
BD-E474	Nullifire S606 Intumescent Coating	-	60	-	UKAS	BRE	CC92856A Review 3	27/7/2006 19/6/2002 8/5/2007	10/4/2013	24/2/2009	
BD-E475	"Wins-M09" Fire Protection Partition Wall Panel System	Wins Consultants Ltd.	243	185	HKAS	Research Engineering Development Façade Consultants Ltd.	13E10	19/3/2008	-	24/2/2009	
BD-E476	Durasteel panel	Intumex Asia Pacific Pte. Ltd.	240	-	UKAS	Building Research Establishment Ltd.	CC83683A Review 4	2/7/2003	24/9/2008	24/2/2009	
BD-E477	Fire rated Enclosure FRP Promat System (Promatect - H)	Promat International (Asia Pacific Ltd.)	240 60	240 60	EA	BRE	Assessment report CC 242335 Review 1 Assessment report CC 242335 Review 1	4/4/2008	4/4/2013	24/2/2009	
BD-E478	Monokote MK5 Spray-applied Fireproofing Plaster for Structural Steelwork.	Monokote	242	-	UKAS	Warrington Fire Research Centre	WFRC No.C127373, dated 30/9/2002	30/9/2002	1/10/2007	24/2/2009	
BD-E479	Cafco 300	Isolatek International	120	-	UKAS	Building Research Establishment	CC 206998	30/4/2005	30/4/2012	24/2/2009	
BD-E480	Durasteel Fire Rated Board. 6.3mm thk. (for single skin barrier system)	Intumex Asia Pacific Pte. Ltd.	60	-	UKAS (United Kingdom)	Warrington Fire Research Ltd.	WF Report No. 156469	14/8/2006	1/8/2011	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E481	Mardolite CP2	Cafco Europe Group SA	60	-	UKAS	Warrington Fire Research Consultants	WFRC No.C52252	1/11/1990	-	24/2/2009	
BD-E482	FIRECUT FM900	Tai Hing Hong	60	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C110854	27/7/2006	1/7/2011	24/2/2009	
BD-E483	Firecut FM900	Yung Chi Paint & Varnish Mfg.Co.Ltd.	120	-	UKAS	Bodycote Warrington Fire	WF No. 164158	8/5/2007	1/6/2012	24/2/2009	
BD-E484	Ytong Block	Daido Home International Limited	240	240	UKAS	Warrington Fire Research Centre Ltd	Warres No. 68302 WFRC Assessment No. 135393	3/10/1996 20/10/2003	- 1/11/2008	24/2/2009	
BD-E485	Precast concrete block 4612S	K. Wah Construction Products Limited	120	120	UKAS	Warrington Fire Research Consultants (UK)	WARRES No.63257, 114792 & 146805	6/2/1995	1/6/2010	24/2/2009	
BD-E486	Firecut FM-900 Intumescent Paint	Yung Chi Paint & Varnish Mfg. Co., Ltd.	120	-	UKAS	Warrington Fire Research Bodycote Warrington Fire Testing	WFRC C125252 WF No. 164158	19/06/2002 08/05/2007	01/07/2007 01/06/2012	24/2/2009	
BD-E487	Promatect - H Fire Rated Enclosure	Promat International (Asia Pacific) Ltd.	120	120	UKAS	Warrington Fire Research Centre	169576	19/12/2007	1/1/2013	24/2/2009	
BD-E488	YTong AAC Block	Daido Home Int'l Ltd.	240	240	UKAS	Warrington Fire Research Centre	68302 135393	3/10/1996 20/10/2003	- 1/11/2008	24/2/2009	
BD-E489	Promat-H Board	Promat Int. Asia Pacific Ltd.	120	-	UKAS	Building Research Establishment (BRE)	CC90190A	14/2/2007	21/2/2012	24/2/2009	
BD-E490	Castle Cube concrete block	Castle Cube Const. Products Ltd.	264	264	HOKLAS	Research Engineering Development Facase Consultants Ltd.	R05D23	30/5/2005	-	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E491	Firecut FM-900	Yung Chi Paint & Varnish Mfg Co Ltd	60	-	UKAS	Warrington Fire Research Centre	WFRC No. C110854 WF Report No. 145918 WFRC No. C125331 WF No. 164159	01/11/1999 27/07/2006 19/06/2002 08/05/2007	01/12/2001 01/07/2011 01/07/2007 01/06/2012	24/2/2009	
BD-E492	Promatect H 9mm Light weight concrete Block wall	Promatect China Jiangmen Nanjian New Walling Materials Co. Ltd.	240 202	- 202	BRE UKAS	BRE Warrington Fire Research Centre Ltd.	CC91465A WFRA No. 40924	24/2/2003 29/8/2002	24/2/2008 1/11/2007	24/2/2009	
BD-E493	Firecut FM-900 intumescent paint	IRE	60	-	UKAS	Warrington Fire Research	WFRC No. C125331	18/8/2000	1/6/2012	24/2/2009	
BD-E494	Durasteel Mandolite CP2	Alliances Marketing (HK) Ltd	240	240	UKAS	WFRC	136396 C52252	22/3/2004 19/11/1990	1/4/2009 -	24/2/2009	
BD-E495	Promatect H steel duct systems (20mm thk)	Promat International (Asia Pacific) Ltd	240	240	UKAS	BRE Testing	CC89769 Review 3	22/9/2006	22/9/2011	24/2/2009	
BD-E497	Precast Concrete Solid Block	Kin Ching Besser Co Ltd	120	120	UKAS	Warringtonfire Research Centre Ltd	WARRES R12780 WFRC C132518	26/4/1996 29/5/2003	1/6/2008 -	24/2/2009	
BD-E498	Light Weight Concrete Block	Huizhou Xinye Building Material Co. Ltd.	240	240	HOKLAS	Research Engineering Development Façade Consultants Ltd	R05H02A1	14/9/2005	-	24/2/2009	
BD-E499	Promatech-H Fire Rated Board	Promat International (Asia Pacific) Ltd.	120	-	UKAS	Warrington Fire Research Centre	169576	19/12/2007	1/1/2013	24/2/2009	
BD-E500	Mandolite CP2	Sherex Fire Proof Material Co.	120	-	UKAS	Warrington Fire Research Ltd.	CP92117 C80520	05/03/1992 17/12/1992	01/04/1994 01/06/2008	24/2/2009	
BD-E501	Firex Board	Kwok Chi Construction Materials Ltd.	240	-	Standards Australia	Branz Limited, New Zealand	FAR2103	3/4/2003	-	24/2/2009	
BD-E502	Steel fire roller shutter	Suzuki Shutter Co. (HK) Ltd.	240	-	UKAS	Warrington Fire Research	C81766 WF172760 Review	13/7/1995 21/04/2008	01/08/1997 01/06/2013	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E503	YTONG Aerated Concrete Block 100mm	Daido Home International Limited	240	240	UKAS	Warrington Fire Research Ltd.	WARRES No. 68302	15/8/1996	1/11/2008	24/2/2009	
BD-E504	Promatect H 15 mm	Sunny Fire Building Materials Limited	240	-	UKAS	BRE & Warrington Fire Research Centre	BRE cc 83299 WFRC no. C80092	23/2/2007	23/2/2008	24/2/2009	
BD-E505	YTONG BLOCK	DAIDO HOME INTERNARTIONAL LTD.	240	240	UKAS	Warrington Fire Research Centre	68302 135393	15/8/1996	1/11/2008	24/2/2009	
BD-E506	Nullifire S605 Intumescent Coating for Columns	Nullifire Limited	60	60	UKAS	Warrington Fire	165959	22/1/2008	1/2/2013	24/2/2009	
BD-E507	Firecut FM-900	Yung Chi Paint Varnish Mfg. Co. Ltd	60	-	UKAS	Warrington Fire Research Centre Ltd	WF No 164160	1/11/1999	1/6/2012	24/2/2009	BD-F036
BD-E508	Fire Shutter	Sanwa Shutter (HK) Ltd	120	-	UKAS	Bodycote Warrington Fire Testing	WFRC No C80427 WF No. 164754	27/7/2007	1/8/2012	24/2/2009	
BD-E509	Cafco Mandolite CP2	Promat UK Ltd.	240	240	UKAS	Warrington Fire Research	WF Report No. 173530/A Issue 2 CP 92117 Rev. 1	28/5/2008 5/3/1992	1/6/2013 1/4/1994	24/2/2009	
BD-E510	Ytong Block Promat	Daido Home Int'l Ltd Promat Int'l (Asia Pacific) Ltd.	240 120	240 -	UKAS	Warrington Fire Research BRE	WFRC 68302, 135393 CC91456A Review3	15/8/1996 20/10/2003 27/2/2008	1/11/2008 27/2/2013	24/2/2009	
BD-E511	Sleev-It	SLEEV-IT Fire Systems (UK) Ltd	240	60	UKAS	Warrington Fire Research Centre Bodycode Warringtonfire	WFRC No. C126470 WF No. 166811	14/8/2002 22/8/2007	1/9/2012 -	24/2/2009	Extends validity of Report WFRC No. C125470
BD-E512	Monokote MK6.	WR. Grace Limited	242	-	UKAS	Warrington Fire Research Centre	WARRES 51843 WF165722	10/5/1991	1/8/2012	24/2/2009	
BD-E513	Durasteel Floor (system)	Durasteel 3DF2 panels Intumex Asia Pte. Ltd.	120	120	UKAS	Warrington Fire Research Centre	WFRC Assessment Report No. 136396	22/3/2004	1/4/2009	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E514	Firecut FM900	Yung Chi Paint & Varnish Mfg Co. Ltd.	60 120	60 120	UKAS	Warrington Fire Research Centre	C110854 WF145918 C125252 WF164158	27/7/2006 8/5/2007	1/7/2011 1/6/2012	24/2/2009	
BD-E515	Promatect H Board	Promat Fire Protection Ltd.	240	10	UKAS	LPC (BRE)	TE89437	19/6/1997	-	24/2/2009	
BD-E516	Nullifire S606	Nullifire Limited	120	60	UKAS	BRE Testing	CC92856A Review 3	19/3/2008	10/4/2013	24/2/2009	
BD-E517	Y Tong Block	Daido Home Int. Ltd	240	240	UKAS	Warrington Fire Research Centre	Warres No. 68302 (135393)	158/1996	1/11/2008	24/2/2009	
BD-E518	Promat H enclosure systems	Promat International (Asia Pacific) Ltd	120	-	UKAS	Bodycote Warrington Fire	WF Report No. 169576 Issue 2	19/12/2007	1/1/2013	24/2/2009	
BD-E519	Promatect H Enclosure System	Promat International (Asia Pacific) Ltd	120	120	UKAS	Warrington Fire Research Centre Ltd	169576	19/12/2007	1/1/2013	24/2/2009	
BD-E520	YTong AAC Block	Daido Home Int'l Ltd.	240	240	UKAS	WFRC WFRC	68302 135393	3/10/1996 20/10/2003	1/11/2008	24/2/2009	
BD-E521	Promat H	Promat Int'l (Asia Pacific Ltd)	120	120	UKAS	BRE Testing	CC 83071 Revised 2	29/1/1993	7/9/2008	24/2/2009	
BD-E522	CAFCO 300	Cafco	60	60	UKAS	BRE	TE 7041 TE 7043 TE 7110 TE 93878	30/4/2007	30/4/2012	24/2/2009	
BD-E523	4 hrs Fire Resistant Roller Shutter	Sanwa Shutter (HK) Ltd.	240	-	UKAS	Bodycote Warrington Fire	164762	12/5/2008	1/6/2013	24/2/2009	
BD-E524	YTONG	Daido Home International Ltd.	120	120	UKAS	Warringtonfire Research Warringtonfire global safety	54272 161791	16/08/1991 13/02/2007	01/03/2012 01/03/2012	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E525	Y-Tong Block	Daido Home International Ltd.	240 360	240 361	UKAS	Bodycote Warringtonfire	177704 175168	21/10/2008 17/07/2008	01/11/2013 01/08/2013	24/2/2009	Review of WF No.68302 Review of WF No.54273
BD-E526	100mm thk. Light weight block partition	Upright Trading Company	120	120	HOKLAS	Research Engineering Development Façade Consultants Limited	R05H02A	14/9/2005	-	24/2/2009	
BD-E527	"FIRECUT FM 900" Fire Intumescent Costing System	Yung Chi Ping and Vanish Manufacturer Co. Ltd.	60	60	UKAS	Warrington Fire Research Centre	WFRC No. C110854 Assessment Report No. 145918	01/11/1999 27/07/2006	01/12/2001 01/07/2011	24/2/2009	
BD-E528	Promatect-H	Promat International (Asia Pacific) Ltd.	120	120	UKAS	BRE Certification Ltd.	CC 91456A Review 3	27/2/2008	27/2/2013	24/2/2009	
BD-E529	TANDA AP25 FIRE PROTECTION PLASTER 9.5mm thick DURASTEEL BOARD	WARWICK BUILDING MATERIAL LTD. INTUMEX ASIA PACIFIC Pte Ltd.	240	-	HOKLAS	RESEARCH ENGINEERING DEVELOPMENT FAÇADE CONSULTANTS LTD.	R08C06	9/4/2008	8/4/2013	24/2/2009	
BD-E530	Promatect-H Board (9mm)	PROMAT INT'L	120	120	UKAS	BODYCOTE	TE 89437 WF169570	26/2/2003	1/1/2013	24/2/2009	
BD-E531	Nullifire S606	Nullifire Limited	60	-	UKAS	BRE	CC 92856B	19/3/2008	10/4/2013	24/2/2009	
BD-E532	Nullifire S605 Fire Intumescent Paint	Nullifire Limited	120	120	UKAS	Warrington Fire	165959	22/1/2008	1/2/2013	24/2/2009	
BD-E533	Fire Rated Brick	K. Wah Construction Products Ltd.	240	-	UKAS	Warrington	63257	14/3/1995	-	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E534	Fire Shutter	Suzuke	240	-	UKAS	Warrington Fire Research Centre Ltd.	172760 C81766	21/4/2008 14/7/1995	1/6/2013 1/8/1997	24/2/2009	
BD-E535	Unitherm 38091	Dupont Performance Coatings GmbH & Co.	60	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC Assessment Report No. C126392 Issue3 C105708 C125342 Issue 2 140896	22/7/2004 8/2/1999 13/8/2002 14/7/2004	1/4/2012	24/2/2009	
BD-E536	Hilti CP606	Hilti Corporation	240	130	UKAS	Warrington Fire Research Centre	WFRC No. 69754/C WFRC No. 175522C (Assessment Report)	14/11/1996 30/7/2008	- 1/8/2010	24/2/2009	
BD-E537	"Mandolite CP2" Spray On Fireproof Coating (Concrete Slabs)	"Cafco International "	240	-	UKAS	Warrington Fire Research Consultancy Testing	WFRC No. CP92117, C118989, C132081A WF No. 173530/A Issue 2	5/3/1992 10/5/2001 19/5/2003 28/5/2008	1/4/1994 1/6/2003 1/6/2008 1/6/2013	24/2/2009	
BD-E538	Fire Rated Damper	Ruskin	240	-	IANZ	BRANZ	16.7.1996	-	-	24/2/2009	
BD-E539	Promatech H, 9 mm thick board	Promat International (Asia Pacific) Ltd.	120	-	UKAS	Bodycote Warringtonfire	WF Report 169576 Issue 2	19/12/2007	1/1/2013	24/2/2009	
BD-E540	A/D Type 5 GP fire proff plaster	A/D Fire Protection Systems	60	60	UKAS	Warringtonfire	WF Assessment Report No. 163280	21/2/2008	June 2012	24/2/2009	
BD-E541	VERMITEX AF	L & A FAZZINI	120	-	HOKLAS	CSIRO	FCO-1299	1/7/2007	31/7/2012	24/2/2009	
BD-E542	Promatect H Board	Promat International (Asia Pacific) Ltd.	120	-	UKAS	BRE Certification Ltd	CC 242335 Review 1	4/4/2008	4/4/2013	24/2/2009	
BD-E543	SprayFilm WB3 Intumescent coating	Cafo Europe Group SA (Trading as) CAFCO International	120	-	UKAS	BODYCOTE WARRINGTONFIRE	144500: issue 3	25/4/2005	1/4/2010	24/2/2009	
BD-E544	Promatect-H	Promat International (Asia Pacific) Ltd.	120	120	UKAS	BRE Certification Ltd.	CC91456A Review 3	27/2/2008	27/2/2013	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E545	Nullifire S606	Nullifire Ltd.	60	60	UKAS	BRE	CC92856A	10/4/2003	10/4/2008	24/2/2009	
BD-E546	YTONG Autoclaved Aerated Concrete Blocks	Daido Home International Ltd	158 240	158 241	UKAS	Warrington Fire Research	WF Report - 161791 Warres 54272 WFRC - 135393 Warres 68302	16/08/1991 13/02/2007 15/08/1996 20/10/2003	01/03/2012 01/11/2008	24/2/2009	
BD-E547	Monokote Z106 Fireproofing Plaster	Grace Construction Products	120	-	UKAS	Bodycote Warringtonfire WFRC WFRC	165723 C127374 54282	12/07/2007 30/09/2002 14/11/1991	01/08/2012 01/10/2007 -	24/2/2009	
BD-E548	FIRE RATED ROLLER SHUTTER	FOCUS ROLLER SHUTTER CO LTD.	120	-	IANZ	BRANZ	FAR2117	6/5/2003	-	24/2/2009	
BD-E549	Nullifire S605 Fire Intumescent Paint	Nullifire Limited	120	120	UKAS	Warrington Fire	165959	22/1/2008	1/2/2013	24/2/2009	
BD-E550	2 Hr. FRP Shutter of size W600 X H650	JEC/ Tanda Vertical Curtain Dampers	120	-	IANZ	BRANZ	BRANZ- FR 3400	22/2/2005	-	24/2/2009	
BD-E551	Phoenix 270	Phoenix Fire Protection (Asia) Ltd.	120	-	PNAP 251	International Fire Consultants Ltd.	Field of A Application Report IFCA/05199	1/7/2005	valid until 2010	24/2/2009	
BD-E552	FIRECUT FM900	YUNG CHI PAINT & VARNISH MFG CO. LTD.	120	-	UKAS	WARRINGTON FIRE RESEARCH CENTRE LTD.	WFRC NO. C125252	19/6/2002	1/7/2007	24/2/2009	
BD-E553	Fire Shutter	Chung Tai Roller Shutters Co., Ltd.	240	-	HOKLAS	Branz	FAR 1659-1	7/11/2000	Indefinite	24/2/2009	
BD-E554	Firecut FM-900 Y-Tong Block Durasteel Floor Assembly	Yung Chi Paint & Varnish Mfg Co. Ltd Daido Home International Ltd. Intumex Asia Pacific Pte. Ltd.	60 240 60	- 240 60	UKAS	Warrington Fire Research Centre	WFRC No. C115007 & 164160 WFRC No. 135393 & 68302 WF Assessment Report No. 148104	31/7/2000 8/5/2007 20/10/2003 3/10/1996 12/9/2005	1/8/2002 1/6/2012 1/11/2008 1/10/2010	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E555	100mm thick autoclaved aerated concrete block wall	Wang Hoi construction and Material Trading (HK) Co.	260	260	HOKLAS	Red Façade Consultants Ltd	R06K15	31/102006	-	24/2/2009	
BD-E556	Fire Shutter	Chung Tai Roller Shutters Co. Ltd	240	-	IANZ	Branz	FAR1659-1	7/112000	-	24/2/2009	
BD-E557	Durasteel Panel	Intumex Asia Pacific	120	-	UKAS	Warrington Fire Research Centre Ltd	176906 C132908	29/9/2008 28/10/2008	1/10/2013	24/2/2009	
BD-E558	Concrete Brick	Wealth Bridge Trading Co. Ltd. (Falk Contry Ltd)	120	120	UKAS	Warrington Fire Research Centre	W00030B 178166	3/12/1998 6/11/2008	- 1/12/2013	24/2/2009	BD-E398 BD-E444
BD-E559	Cafco 280	Cafco Europe Sarl Foetz	120	-	UKAS	BRE	CC376.3	6/12/1997 17/3/2003	17/3/2008	24/2/2009	
BD-E560	Fire Shutter (Rolling)	Suzuki Shutter Company (HK) Limited	240	-	UKAS	Warringtonfire Research Ltd.	WFRC No. 136772	28/6/2004	1/7/2009	24/2/2009	
BD-E561	Unitherm 38091	Dupont Performance Coatings GmbH & Co.	60	-	UKAS	Warrington Fire Research Centre	WFRC 140896	14/7/2004	1/8/2009	24/2/2009	
BD-E562	"Monokote MK6" Spray On Fire Proof Coating	Grace Construction Products	240	-	UKAS	Bodycote Warringtonfire Warrington Fire Research Centre Ltd.	WF No. 165722 WARES No. 51843 WFRC No. C101583 WFRC No. C127373	12/7/2007 21/6/1991 10/12/1997 30/9/2002	1/8/2012 - 1/1/2003 1/10/2007	24/2/2009	
BD-E563	RUSKIN' IBD Fire Damper	Delta Pyramax Co Ltd	240	-	IANZ	BRANZ Limited	BRANZ Report No. FR 2230, FR 2317, 97/1057	16/7/1996 5/3/1997 18/4/1997	Indefinite	24/2/2009	
BD-E564	Durasteel' Sheet	Cape Durasteel Limited	240	-	UKAS	The Loss Prevention Council	TE83248	4/2/1993	-	24/2/2009	
BD-E565	100mm thick Y-Tong block	Daido Concrete (HK) Ltd.	240	240	UKAS	Warrington Fire Research Centre	Warres No. 68302 WF Report No. 135393	3/10/1996 20/10/2003	2/10/2001 1/11/2008	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E566	SprayFilm WB3	Cafco Int'l	60	-	UKAS	Bodycote Warrington	WF Assessment Report No. 152624 issue 3	29/3/2006	13/2011	24/2/2009	
BD-E567	Promatect H	Promat International (Asia Pacific) Ltd.	120	-	UKAS	Warringtonfire	WF No. 156468	29/8/2006	1/8/2011	24/2/2009	
BD-E568	HORIZONTAL SLIDING SHUTTER	SUZUKI SHUTTER COMPANY (H.K.) LIMITED	120	-	HOKLAS	RESEARCH ENGINEERING DEVELOPMENT FAÇADE CONSULTANTS LIMITED	R05B06 R05C23 R07E08	15/5/2007	14/5/2009	24/2/2009	
BD-E569	FRP Concrete Brick size 100x150x300mm	Wealth Bridge Trading Co. Ltd.	245	213	UKAS	Warrington Fire Research Centre Ltd.	WFRC No.135199 W0030B	07/10/2003 03/12/1998	01/11/2008 03/12/2003	24/2/2009	
BD-E570	YTONG	DAIDO HOME INTERNATIONAL LTD.	120	120	UKAS	Warrington Fire Research Consultancy Testing WARRINGTON FIRE RESEARCH CONSULTANT	54272/ 161791	16/08/1991 13/02/2007	- 01/03/2012	24/2/2009	
BD-E571	Promatect H Board	Promat International (Asia Pacific) Ltd.	120	120	UKAS	Bodycote Warringtonfire	169576.00	19/12/2007	1/1/2013	24/2/2009	
BD-E572	Fire Shutter	Suzuki Shutter Co. (H.K.) Ltd.	240	-	HOKLAS	Warrington Fire Research consultancy	172760 132345 C81766	21/04/2008 20/05/2003 14/07/1995	01/06/2013 01/06/2008 01/08/1997	24/2/2009	
BD-E573	Phoenix 167	Phoenix Fire Protection (Asia) Ltd.	60	60	UKAS	Warrington Fire Research Centre	WFRC Assessment Report No. 143912	20/12/2004	1/1/2010	24/2/2009	
BD-E574	Firecut FM-900	Yung Chi Paint & Varnish Mfg. Company Ltd.	60	60	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C115007	31/7/2000	-	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E575	Firecut FM-900	Yung Chi Paint & Varnish Mfg. Company Ltd.	60	60	UKAS	Warrington Fire Research Centre Ltd.	WFRC No. C115007	31/7/2000	1/6/2012	24/2/2009	
BD-E576	Unitherm 38091	Dupont Performance Coatings GmbH & Co.	120	-	UKAS	Warrington Fire Research Centre Ltd.	C125126	3/7/2002	-	24/2/2009	
BD-E577	100 mm thick "AUGREEN" Gypsum Block	Caso (HK) Engineering Co. Ltd	120	120	HOKLAS	Research Engineering Development Façade Consultants Ltd	R07L11	3/12/2007	2/12/2010	24/2/2009	
BD-E578	Promatech H (9mm thk)	Promat International (Asia Pacific) Ltd	261	148	UKAS	BRE Testing	CC 84607 Review 4	13/2/2007	21/2/2012	24/2/2009	
BD-E579	Promatech H smoke barrier	Promat International (Asia Pacific) Ltd	60	60	UKAS	BRE Certification	CC 84607 Review 4	13/2/2007	21/2/2012	24/2/2009	
BD-E580	Firecut FM-900	Yung Chi Paint & Varnish Mfg. Co. Ltd	-	-	UKAS	WFRC	C125252 WF No. 164158	21/6/2002 8/5/2007	1/7/2007 1/6/2012	24/2/2009	
BD-E581	FRP Enclosure Partition	Promat International (Asia Pacific) Ltd	240 120 120	240 120 120	UKAS NATA UKAS	BRE Warrington Fire Research Bodycote	CC242335 C80082 WF No 168263A WF No. 177939	4/4/2008 17/11/1992 28/2/2008 20/11/2008	4/4/2013 1/12/1994 1/3/2009 1/12/2013	24/2/2009	
BD-E582	Y Tong Concrete Block	Daido Concrete (HK) Ltd	-	-	UKAS	Warrington Fire Research Centre	68302 135393 161791	15/8/1996 20/10/2003 13/2/2007	1/3/2012	24/2/2009	
BD-E583	Promatect - H Fire Rated Board	Promat Int'l (Asia Pacific) Ltd	240	240	UKAS	Bodycote Warringtonfire	WF Assessment Report 164275	23/5/2007	1/5/2012	24/2/2009	
BD-E584	100mm Y-TONG BLOCK	DAI DO CONCRETE (HK) LTD	240	240	UKAS	WARRINGTON FIRE RESEARCH	WTRC No. 135393	20/10/2003	1/11/2008	24/2/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E585	PROMINA 60	HUNG TEAM (CHINA) LIMITED	120	120	UKAS	BRE	CC86481	22/9/2006	22/9/2011	24/2/2009	
BD-E586	Monokote MK6	Grace Construction Products W.R. Grace & Co.	60	-	UKAS	Warrington Fire Research	WFRC No. C111709	11/1/2000	1/1/2002	24/2/2009	
BD-E587	Monokote MK6	Grace Construction Products W.R. Grace & Co.	61	-	UKAS	Warrington Fire Research	WFRC Report No. 136861	12/1/2004	1/2/2009	24/2/2009	
BD-E588	PROMATECT - H	Promat International (Asia Pacific) Limited	120	120	UKAS	BRE Testing	CC 83300 Rev 4	12/1/2007	12/1/2012	24/2/2009	
BD-E589	Nullifire S605 Fire Intumescent Paint	Nullifire Ltd.	60	-	UKAS	Warrington Fire	WF Assessment Report No. 165959	22/1/2008	1/2/2013	24/2/2009	
BD-E590	Promatect H Board	Wai Fai Ceiling Building Material Co.	120	-	UKAS	Warrington-fire global safety	WF report no.169576	19/12/2007	1/1/2013	2/11/2009	
BD-E591	100mm thick YTong Block	Sun Fat Materials Limited/ Daido Home Int'l Ltd	240	240	UKAS	Warrington Fire Research	Test Report No. 68302	Test on 15/8/1996 issued on 3/10/1996	1/11/2013	2/11/2009	
BD-E592	Promatech-H	Promat Int'l (Asia Pacific) Ltd.	60	-	UKAS	BRE Testing	BRE cc84975 Review 5	9/1/2007	9/1/2012	2/11/2009	
BD-E593	FIRECUT FM-900	TAI HING HONG	60	-	UKAS	Warrington Fire Research Centre Ltd.	WFRC No.C125331 WF No.164159	19/6/2002	1/6/2012	2/11/2009	
BD-E594	FireCut FM-900 [for hollow steel beams (rectangular)]	Yung Chi Paint & Varnish Mfg. Company Ltd.	60	-	UKAS	Warrington Fire Research Centre Ltd. Bodycote Warringtonfire Testing	C115007 C126749 164160	31/07/2000 27/08/2002 08/05/2007	1/8/2001 1/9/2007 1/6/2012	2/11/2009	
BD-E595	Firex Enclosure	New City Resources Inc	120	120	UKAS	BRE Testing	CC212613	24/9/2008	29/1/2011	2/11/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E596	Firecut FM-900	Varnish Mfg Co Ltd	-	60	UKAS	Warrington Fire Research	WFRC No. C110854 WF Rep No. 145918	1/11/1999 27/7/2006	1/12/2001 1/7/2011	2/11/2009	
BD-E597	Evo-Stik Intucrylic Sealant	Paul Y (E&M) Contractors Ltd	240	240	UKAS	Warrington Fire Research Centre Ltd	154655	26/7/2006	25/7/2008	2/11/2009	
BD-E598	Firecut FM-900 to Hollow Section	Greatec Engineering Ltd	60	-	UKAS	Warrington Fire Research Ltd	WFRC No. C125331 WFRC No. 164159 Review Assessment	19/6/2002 8/5/2007	1/6/2012	2/11/2009	
BD-E599	YTONG Autoclaved aerated concrete block	Daido Home International Ltd	240	240	UKAS	Warrington Fire Research Ltd	Warres No. 68302	21/10/2008	1/11/2013	2/11/2009	
BD-E600	Partition	Promat International (Asia Pacific Ltd)	242	240	UKAS	Bodycote Warringtonfire	WF Report 164275	25/5/2007	1/5/2012	2/11/2009	
BD-E601	Firecut FM-900 Intumescent Paint	Greatec Engineering Ltd	120	120	UKAS	Warrington Fire Research	C125252 164158 (Appraisal to C125252) C115007 164160 (Appraisal to C115007)	19/6/2002 8/5/2007 31/7/2000 8/5/2007	1/7/2007 1/6/2012 1/8/2002 1/6/2012	2/11/2009	
BD-E602	Tak Shing Shutter	Tak Shing Shutter Limited	264	-	HOKLAS	Research Engineering Development Façade Consultants Limited	12K11	13/1/2003	-	2/11/2009	
BD-E603	Pyrok CV27	Pyrok Building Products Limited	120	120	UKAS	Warrington Fire Research Centre	WFRC No. 41664 139153	25/6/1987 21/4/2004	- 1/5/2009	2/11/2009	
BD-E604	Phoenix 167	Phoenix Fire Protection (Asia) Ltd.	60	-	UKAS	Warrington Fire Research	143911	20/12/2004	1/1/2010	2/11/2009	
BD-E605	Ytong Block	Daido Home International Limited	240	240	UKAS	Warrington Fire Research Centre Limited	Warres No. 68302	20/10/2003	1/11/2008	2/11/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E606	Nullifire S606 Fireproofing Paint	Carboline Co.	60	-	UKAS	BRE Testing	CC92856B	20/5/1999	10/4/2013	2/11/2009	
BD-E607	Ytong Block	Daido Home Int'l Ltd.	240	240	UKAS	Warrington Fire Research Centre	WFRC 68302 135393	15/8/1996 20/10/2003	1/11/2008	2/11/2009	
BD-E608	Knauf Plasterboard	Knauf	60	60	UKAS	Bodycote Warringtonfire	122835 Issue 2	22/2/2007	1/3/2012	2/11/2009	
BD-E609	"Promatect-H" F.R. Board	Promat International (Asia Pacific) Ltd	120	120	UKAS	BRE	CC91456A Review 3	27/2/2008	27/2/2013	2/11/2009	
BD-E610	Promatect-H fire resisting board (9mm tk. in 2 layers all around; i.e., 18mm tk. in total)	Promat Int (Asia Pacific) Ltd.	60	-	UKAS	Building Research Establishment Ltd.	CC84975 Review 5	9/1/2007	9/1/2012	2/11/2009	
BD-E611	Promatect - H board	Promat Int'l (Asia Pacific) Ltd.	120	120	UKAS	Building Research Establishment Ltd.	BRE CC 91456A Review 3	23/10/1999	27/2/2013	2/11/2009	
BD-E612	9mm thk. Promatect-H fire rated Board for smoke barrier system	Promat Int'l (Asia Pacific) Ltd.	60	-	UKAS	BRE Certification Ltd.	CC 84607 Review 4	13/2/2007	21/2/2012	2/11/2009	
BD-E613	PROMATECT -H	PROMAT INTERNATIONAL (ASIA PACIFIC) LIMITED	240	240	UKAS	Bodycote Warrington Fire	WF174649	27/10/2008	1/11/2013	2/11/2009	
BD-E614	FIRECUT FM900	YUNG CHI PAINT & VARNISH MFG. CO LTD.	120	-	UKAS	WARRINGTON FIRE	C125252 WF 164158	8/5/2007	1/6/2012	2/11/2009	
BD-E615	ARMAPLATE enclosure system	Knauf	120	-	UKAS	BRE Certification Ltd.	CC234355	12/2/2007	12/2/2012	2/11/2009	
BD-E616	Y-Tong 100mm thick	Daido Home International Ltd	240	240	HKAS	Warrington fire Research	135393 (Review of 68302)	20/10/2003	1/11/2008	2/11/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E617	Y-Tong AAC Block	Daido Home International Ltd	360	360	UKAS	Warrington	54273	2/9/1991 3/10/1991	1/8/2013	2/11/2009	
BD-E618	Monokote MK6	W.R. Grace & Co. Construction Products Division	120	-	UKAS	Warrington Fire Research Centre	WFRC No. C111709	11/1/2000	1/2/2009	2/11/2009	BD-FP021
	9mm thk. Promatec H Board	Promat Int. Asia Pacific Ltd.	120	-	UKAS	BRE	CC84607 Review 4	21/2/2002	21/2/2012		BD-D149
BD-E619	MONOKOTE MK-6 (Fire Proofing Material)	Grace Construction Product	120	-	UKAS	Warrington Fire Research Centre	WFRC No. C127373 WF Report No. 165722	30/9/2002 12/7/2007	1/10/2007 1/8/2012	2/11/2009	
BD-E620	Pyrok CV 25	Pyrok Building Products Limited	120	-	UKAS	The Loss Prevention Council (BRE) Laboratory	TE 7002	31/8/2004	-	2/11/2009	(BD-E049)
BD-E621	Ytong block wall 100mm thick	Daido Home International Ltd	240	240	UKAS	Bodycote Warringtonfire	68302	21/10/2008	1/11/2013	2/11/2009	
BD-E622	Focus (Brightview) 2 hr FRP Fire Shutter	Focus (Brightview)	120	-	IANZ	BRANZ Limited	FAR 2117	06/05/2003	Indefinite	16/12/2009	
			242	-	CNACL	Far East Fire Testing Centre	FT02084	28/07/2002			
BD-E623	YTONG Block	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Bodycote Warrington Fire	WARRES No.68302 WR Report No. 177704	3/10/1996 21/10/2008	3/10/2001 1/11/2013	16/12/2009	
BD-E624	Promatect H Board	Promat Int. (Asia Pacific) Ltd.	240	10	UKAS	LPC (BRE) Laboratory	TE 89437 Supplement & Original Report TE 89437	26/2/2003 7/1/1998	Indefinite	16/12/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E625	"Forbes" FRP glass frame system & "Contraflam" fire rated glass door-set	Sherex Engineering Ltd.	120	60	HOKLAS	Research Engineering Development Facade Consultants Ltd.	RED Test Report no. R06D08E	18/5/2007	-	16/12/2009	
BD-E626	Fire Rated Paint	Cafco Spray Film	120	120	UKAS	WFRC	152624: Issue 2	29/3/2006	1/3/2011	16/12/2009	
BD-E627	100mm Y-Tong Block	Daido Home International Ltd.	240	240	UKAS	Bodycote Warringtonfire Testing	WF Report No. 177704	21/10/2008	1/11/2013	16/12/2009	
BD-E628	Promatect-H Enclosures to General Building Services	Promat International (Asia Pacific) Ltd.	120 240	-	UKAS	Bodycote Warringtonfire	Assessment Report: 169576 Issue 2 Test Report: BFTC No. 98/27, LPC No. TE89437, CSIRO No. FSH 1212	19/12/2007 11/12/1998 26/02/2003 30/08/2006	01/01/2013 - 26/02/2008 -	16/12/2009	
BD-E629	Firecut FM-900 Intumescent Paint	Yung Chi Paint & Varnish Mtg. Co.	60	-	UKAS	Warringtonfire	WF Report No. 145918	27/7/2006	1/7/2011	16/12/2009	
BD-E630	Promatect-H	Promat International (Asia Pacific) Ltd.	120	120	UKAS	BRE	CC242335 REVIEW 2	19/2/2008	16/6/2013	16/12/2009	
BD-E631	1 hr FRP Y-Tong Block	Daido Home	158	158	UKAS	Bodycote Warringtonfire	Warres No. 54272 & WF Report No. 161791	13/2/2007	1/3/2012	16/12/2009	
BD-E632	Promatect H Partition	Promat International (Asia Pacific) Ltd.	120	120	UKAS	Warringtonfire	177939	20/11/2008	1/12/2013	16/12/2009	
BD-E633	"YTONG" Autoclaved Aerated Concrete Block	Daido Home International Ltd.	158	158	UKAS	Bodycote Warringtonfire	161791	13/2/2007	1/3/2012	16/12/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E634	Promatect-H Insulated Enclosures	Promat International (Asia Pacific) Ltd.	60	60	UKAS	BRE	CC 242335 REVIEW 2	19/2/2008	16/6/2013	16/12/2009	
BD-E635	Promatect-H	Promat Int. Asia Pacific Ltd	120	120	UKAS	Bodycote Warringtonfire	WF177939	20/11/2008	1/12/2013	16/12/2009	
BD-E636	Coopers Smoke Curtains	Coopers Blinds Limited	60 60	- -	UKAS	Bodycote Warringtonfire Testing Warringtonfire Research Centre Warringtonfire Research Centre Warringtonfire Research Centre Bodycote Warringtonfire	WF REPORT No. 175984 (Issue 3) WARRES No. 104732 WARRES No. 106113 WF REPORT No. 127654 WARRES No. 167511	4/9/2008 26/11/1998 18/5/1999 17/10/2002 24/9/2006	1/9/2013 25/11/2003 1/6/2001 1/11/2007 1/10/2012	16/12/2009	
BD-E637	Nullifire S606	Nullifire Limited	60	60	UKAS	Building Research Establishment	CC92856A Rev. 3	19/3/2008	10/4/2013	16/12/2009	
BD-E638	Suzuki Shutter	Suzuki Shutter Co. (HK) Ltd.	240	-	UKAS	Warrington Fire Research Centre	WFRC No. C81766 WFRC No. C132345	14/7/1995	1/6/2008	16/12/2009	
BD-E639	75mm thick Ytong Autoclaved Aerated Concrete Block	Daido Home International Ltd	158	158	UKAS	Warrington Fire Research Bodycote Warrington Fire	54272 161791	16/8/1991 13/2/2007	- 1/3/2012	16/12/2009	
BD-E640	100mm thick autoclaved aerated concrete block	Shenzhen Hong Kai Lightly Wall Material Co, Ltd	260	260	HOKLAS	Research Engineering Development Façade Consultants Ltd	R06K15	31/10/2006	-	16/12/2009	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E641	Promatect H	Promat International (Asia Pacific) Ltd	120	-	UKAS IANZ UKAS UKAS	BRE Branz Bodycote Bodycote	81584A Rev 4 96/876 WF177939 WF174649	6/3/2008 14/8/2002 20/11/2008 27/10/2008	6/3/2013 Indefinite 1/12/2013 1/11/2013	16/12/2009	
BD-E642	Mandolite CP2	Mandoval Ltd	60	-	UKAS	Warrington Fire Research Consultants	WFRC C52252	1/11/1990	1/11/2011	16/12/2009	
BD-E643	CAFECO Sprayfilm WB3	Cafco Europe Group SA	60	-	UKAS	Warrington Fire Research Centre	139823	27/5/2004	1/6/2009	16/12/2009	
BD-E644	Promatect H Solid Partition System	Promat International (Asia Pacific) Ltd.	60	60	UKAS	BRE	CC 86480A Review 3	19/2/2007	21/2/2012	23/2/2010	
BD-E645	9mm thk. Promat-H Board	Promat International (Asia Pacific) Ltd	60	-	UKAS	BRE	Report No.CC84607 Review 4	13/2/2007	21/2/2012	23/2/2010	
BD-E646	Pyrok CV 25 Fire Rated Cementations Plaster	Pyrok Building Products Ltd.	120	120	UKAS	BRE	Supplementary report to Report: TE-7002	31/8/2004	-	23/2/2010	
BD-E647	Ruskin IBD Fire Damper	Delta Pyramax Company Limiteds	253	-	IANZ	BRANZ	FR2230 FR2317 FR2072	16/07/1996 05/03/1997 01/04/2003	-	23/2/2010	
BD-E648	Promatect H insulated enclosures to general building services	Promat International (Asia Pacific) Ltd.	240	240	UKAS	Bodycote Warringtonfire	CC242335 Review 1	4/4/2008	4/4/2013	23/2/2010	
BD-E649	Promatect-H 9mm Board	Promat International (ASIA PACIFIC) LTD.	120	-	UKAS	Warringtonfire	169576	19/12/2007	1/1/2013	23/2/2010	
BD-E651	PROMATECT-H	Promat International (Asia Pacific) Limited	120	120	UKAS	Warringtonfire	WF No. 169576	19/12/2007	1/1/2013	23/2/2010	
BD-E652	Promatect H-Board	Promat International (Asia Pacific) Ltd	120	-	UKAS	BRE	CC 90190A Review 3	14/2/2007	21/2/2012	23/2/2010	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E653	Autoclaved Aerated Concrete Block	Shenzhen Hong Kai Lightly Wall Material Company Ltd.	260	260	HOKLAS	Research Engineering Development Facade Consultants Limited (RED)	R06K15	1/12/2006	-	23/2/2010	
BD-E654	Firecut FM900 Intumescent Paint	Tai Hing Hong	60	60	UKAS	Warrington Fire Global Safety	145918	27/7/2006	1/7/2011	23/2/2010	
BD-E655	9mm thk. "Promatect H" Board	Promat International (Asia Pacific) Limited	120	-	UKAS	BRE	CC83300 Rev 4	12/1/2007	12/1/2012	23/2/2010	
BD-E656	Ytong autoclaved aerated concrete block	Daido Home Int. Ltd	240	240	UKAS	Warrington Fire Research Centre Ltd	68302 & 177704(Issue 2)	15/8/1996 21/8/2008	1/11/2013	23/2/2010	
BD-E657	Firesteel Classic 120	Firetherm Intumescent & Insulation Supplies Ltd	60	60	UKAS	Bodycote Warrington Fire Research	C155649/B C130414	15/6/2006 6/3/2003	1/7/2011 1/4/2008	23/2/2010	
BD-E658	Steel Fire Roller Shutter	Suzuki Shutter Co. (HK) Ltd	240	-	UKAS	Warrington Fire Research Centre Ltd BRE Global Bodycote Warringtonfire Testing	C81766 CC91702 Rev 3 172760 165264	13/7/1995 23/7/2008 21/4/2008 26/6/2007	1/8/1997 23/7/2013 1/6/2013 1/7/2012	23/2/2010	
BD-E659	Ytong Autoclaved Aerated Concrete Block	Daido Home International Ltd.	360	360	UKAS	Bodycote Warringtonfire Warrington Fire Research centre	WF175168 WA No. 54273	17/7/2008 2/9/1991	1/8/2013 -	23/2/2010	
BD-E660	Fire Resisting Rolling Fascia	Suzuki Shutter Co. (HK) Ltd	240	-	UKAS	Warrington Fire Research Centre	WF Report No. 165264	26/6/2007	1/7/2012	23/2/2010	
BD-E661	Sanwa Fire Shutter	Sanwa Shutter (HK) Ltd.	120	-	UKAS	Bodycote Warrington Fire	164762	12/5/2008	1/6/2013	23/2/2010	
BD-E662	Fire Shutter	Chung Tai Roller Shutter Co Ltd.	120	-	IANZ	BRANZ	FAR2291 Issue 3	13/4/2007	13/4/2012	23/2/2010	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E663	Sanwa Fire Shutter	Sanwa Shutter (HK) Ltd.	120	-	UKAS	Bodycote Warringtonfire	164762	12/5/2008	1/6/2013	23/2/2010	
BD-E664	Hilti CP606	Hilti	240	216	UKAS	Warrington	175522C 69754/C	30/7/2008 14/1/1996	1/8/2010 16/1/1997	23/2/2010	
BD-E665	Horizontal Sliding Shutter	Suzuki Shutter Company (HK) Limited	240	-	HOKLAS	Research Engineering Development Facade Consultants Limited	R08D23	8/5/2008	7/5/2010	23/2/2010	
BD-E666	Monokote MK6	Grace Construction Products	120	120	UKAS	Warrington Fire Research Centre Ltd.	Warres No.51843, C127373 & 165722	21/6/1991 30/9/2002 12/7/2007	- 1/10/2007 1/8/2012	23/2/2010	
BD-E667	"FIRECUT" FM-900	Easy Smart Engineering Limited	60	-	UKAS	Warrington	145918	27/7/2006	1/7/2011	23/2/2010	
BD-E668	Nullifire S605 Intumescent Coating	Nullifire Limited	120	120	UKAS	Warrington Fire Research Centre Ltd.	165959	22/1/2008	1/2/2013	23/2/2010	
BD-E670	Nullifire S605	Nullifire Ltd	120	-	UKAS	Bodycote Warrington Fire	165959	22/1/2008	1/2/2013	23/2/2010	
BD-E671	Fire Paint Nullifire S606	Proactive Engineering (HK) Co Ltd	120	120	UKAS	BRE	CC 92856A(Rev 3)	19/3/2008	10/4/2013	23/2/2010	
BD-E672	Non-Loadbearing Insulated Lightweight Block Partition Wall Systems	Wealth Bridge Trading Co. Ltd.	120 240	120 240	HOKLAS	Research Engineering Development Facade Consultants Limited	R07M05	10/1/2008	9/1/2010	23/2/2010	
BD-E673	Firecut FM-900	Yung Chi Paint & Varnish Mfg Co Ltd	60	-	UKAS	Warrington Fire Research Centre Warringtonfire	WFRC No.C110854 WF Report No.145918	01/11/1999 27/07/2006	1/12/2001 1/7/2011	23/2/2010	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E674	Ytong AAC Block (100mm Thick)	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Warrington	68302 177704	15/8/1996 21/10/2008	- 01/11/2013	23/2/2010	
BD-E675	Nullifire S605 Intumescent Paint	Nullifire Limited	120	120	UKAS	Warringtonfire	165959 CC93058B Rev.3	22/1/2008 20/3/2008	1/2/2013 20/3/2013	23/2/2010	
BD-E676	100mm thk. light weight block partition	Upright Trading Company	240	240	HOKLAS	Research Engineering Development Facade Consultants Limited	R05H02A	14/9/2005	-	23/2/2010	
BD-E677	Sanwa Fire Shutter	Sanwa Shutter (HK) Ltd.	240	-	UKAS	Bodycote Warrington Fire	164762	12/5/2008	1/6/2013	23/2/2010	
BD-E678	Firecut FM-900	Greatec Engineering Ltd	60	-	UKAS	Warrington Fire Research Consultancy	WFRC C110854 WFRC 145918	01/11/1999 27/07/2006	- 1/7/2011	23/2/2010	
BD-E679	75mm "Y-Tong" Block	Daido Home Int'l Ltd.	120	120	UKAS	Warrington Fire Research Centre	54272 161791	16/8/1991 13/2/2007	- 1/3/2012	23/2/2010	
BD-E680	Promatect-H Steel Duct Protection System	Promat International (Asia Pacific) Ltd.	120	120	UKAS	BRE Global Ltd.	CC89273 Review 4	28/8/2008	28/8/2013	23/2/2010	
BD-E681	"Supalux" Ceiling System	Intumex Asia Pacific	120	120	UKAS	BRE	CC85383 Review 4	14/1/2008	13/1/2013	23/2/2010	
BD-E682	Nullifire S606 (Intumescent Coating)	Nullifire Limited	60	60	UKAS	BRE	CC 92856A Rev.3 CC 92856B Rev.3	19/3/2008 19/3/2008	10/4/2013 10/4/2013	23/2/2010	
BD-E683	Firecut FM-900 Fire Intumescent Paint	Yung Chi Paint & Varnish Mfg. Co. Ltd	120	120	UKAS	Warrington Fire Research Consultancy Warringtonfire	C125252 WF 164158	21/6/2002 8/5/2007	21/6/2007 1/6/2012	23/2/2010	
BD-E684	Y-Tong Blockwall	Daido Concrete (HK) Ltd	240	240	UKAS	Warrington	68302 C121622 135393 177704	3/10/1996 19/10/2001 20/10/2003 21/10/2008	3/10/2001 1/11/2003 1/11/2008 1/11/2013	23/2/2010	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E685	Firecut FM-900	Yung Chi Paint & Varnish Mfg Co. Ltd.	120	-	UKAS	Bodycote Warringtonfire	WF No.164159	8/5/2007	1/6/2012	23/2/2010	
BD-E686	Uninsulated, multi-blade damper assembly mounted within a masonry wall construction	Trox (U.K.) Limited in conjunction with Trox (Malaysia) Sdn. Bhd.	240	-	UKAS	Bodycote Warringtonfire Warrington Fire Research Centre	WF.155894/E WARRES.119361	27/06/2006 26/07/2001	01/07/2011 26/07/2006	23/2/2010	
BD-E687	Fire Shutters	Suzuki Shutter Co. (HK) Ltd	240	-	UKAS	Bodycote Warringtonfire Warrington Fire Research	WF Report No.172760 WFRC No.C81766	21/04/2008 13/07/1995	01/06/2013 01/08/1997	23/2/2010	
BD-E688	Firecut FM-900	Yung Chi Paint & Varnish Mfg. Co. Ltd.	60	-	UKAS	Warrington Fire Research Centre	WF Report No.145918	27/7/2006	1/7/2011	23/2/2010	
BD-E689	Promatech-H Partition	Promat International (Asia Pacific) Ltd.	120	-	UKAS	BRE	CC91456A Review 3	27/2/2008	27/2/2013	23/2/2010	
BD-E690	Promatect H	Promat International Asia Pacific Limited	240	240	IANZ	BRANZ	96/876 Issue 2	14/8/2002	Indefinite	23/2/2010	
BD-E691	Durasteel ceiling membrane	Intumex Asia Pacific Pte Ltd.	120	120	UKAS	Warrington Fire Research Centre Ltd.	C132908 176906	28.10.2003 29.9.2008	1/10/2013	25/5/2010	
BD-E692	YTONG Autoclaved Aerated Concrete Block	Daido Home International Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	WR Report No. 177704	21/10/2008	1/11/2013	25/5/2010	
BD-E693	Mandolite CP2 on steel member	SHEREX ENGINEERING LTD.	120	-	UKAS	Bodycote Warringtonfire	WF NO. 158522	11/10/2006	1/11/2011	25/5/2010	
BD-E694	Fire Shutter	Finetec Shutter Company Limited	240	-	UKAS	Bodycote Warringtonfire	WF Report No. 162611	12/3/2007	1/4/2012	25/5/2010	
BD-E695	Firesteel Classic 120	Firetherm Intumescent & Insulation Supplies Limited	60	-	UKAS	Bodycote Testing Group	WFRA Report C155649/A	15/6/2006	1/7/2011	25/5/2010	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E696	Monokote MK-6 Fire Protection Plaster	Gold Hero	242	-	UKAS	Bodycote Warrington	165722	12/7/2007	1/8/2012	25/5/2010	
BD-E697	Nullifire S606	Nullifire Limited	60	60	UKAS	BRE Testing	CC92856B Review 3	19/3/2008	10/4/2013	25/5/2010	
BD-E698	Ytong Block Wall 100mm thk.	DAIDO HOME (H.K.) LTD.	240	240	UKAS	Warrington Research Centre Ltd.	WFRC No. 177704	21/10/2008	1/11/2013	25/5/2010	
BD-E699	Promatech-H Fire Rated Board	Sherex Fireproof Material Factory	120	120	UKAS	BRE	CC91456A (Rev3)	27/2/2008	27/2/2013	25/5/2010	
BD-E700	Solid Supalox Partition Systems	Intumex Asia Pacific Pte Ltd.	120	120	UKAS	Building Research Establishment	CC239919	28/1/2008	28/1/2013	25/5/2010	
BD-E701	Phoenix 270 Intumescent Paint Coating	Phoenix Fire Technologies (UK) Ltd.	120	120	PNAP APP-118	International Fire Consultants Ltd.	IFCA/ 05199	1/7/2005	1/7/2010	25/5/2010	
BD-E702	Nullifire S605 Intumescent coating	Nullifire Ltd.	60	60	UKAS	Bodycote Warringtonfire	WF 165959	22/1/2008	1/2/2013	25/5/2010	
BD-E703	Knauf Fireshield Plasterboard	Knauf Hong Kong Ltd	60	60	UKAS	Bodycote Warringtonfire	WF no. 122835 Issue 2	22/2/2007	1/3/2012	25/5/2010	
BD-E704	Cafco 300 Fireproofing Plaster	Cafco International	120	-	UKAS	Building Research Establishment	CC206998 Review 1	30/4/2007	30/4/2012	25/5/2010	
BD-E705	2 hrs Promatect H 9mm tk. fire protection board	Promat International (Asia Pacific) Ltd.	120	120	UKAS	Bodycote Warringtonfire	WF 177939	20/11/2008	1/12/2013	25/5/2010	
BD-E706	Monokote MK-6	W. R. Grace	242	-	UKAS	Warrington Fire Research Centre Bodycote Warringtonfire	C127373 165722	30.9.2002 12.7.2007	1.10.2007 1.8.2012	25/5/2010	
BD-E707	Cafco SprayFilm WB3	Cafco Europe Group SA (Trading as) Cafco International	60	-	UKAS	Bodycote Warringtonfire	WF Report No. 152624 Issue 3	29/3/2006	1/3/2011	25/5/2010	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E708	Firecut FM-900	Yung Chi Print & Varnish Mfg Co Ltd.	60	-	UKAS	Warrington Fire Research Centre Warringtonfire	WFRC C110854 WF 145918	1.11.1999 27.7.2006	1.12.2001 1.7.2011	25/5/2010	
BD-E709	Light Weight Concrete Block	Kwok Chi Construction Materials Limited	264	264	UKAS	Bodycote Warringtonfire	173470 Issue 3	7/7/2008	-	25/5/2010	
BD-E710	Durasteel loaded floor assemblies	Zuraida Ahmad Danial Intumex Asia Pacific	120	120	UKAS	Warrington Fire Research Centre Ltd.	WF 136396 WF 181794A	22.3.2004 25.3.2009	1.4.2009 1.4.2014	25/5/2010	
BD-E711	WINS-N09 Magnesium oxide board	WINS Consultants Ltd	243	185	HOKLAS	Research Engineering Development Facade Consultants Ltd	13E10	2/7/2003	-	25/5/2010	
BD-E712	Promatect- H steel duct protection system	Promat International (Asia Pacific) Limited.	120	120	UKAS	BRE Global Ltd.	CC 89273 Review 4	28/8/2008	28/8/2013	25/5/2010	
BD-E713	Promatect-H Board	Promat International (Asia Pacific) Ltd.	120	-	UKAS	BRE	CC84975 Review 5	9/1/2007	9/1/2012	25/5/2010	
BD-E714	Unitherm 38091	Proactive Engineering (HK) Co., Ltd	120	-	Bodycote Warringtonfire	Warrington Fire Research Centre	WF 162163 WFRC C105561 WFRC C125126 WRFC 133000 WRFC 133394 WFRC C128560 WFRC C117433	19.3.2007 8.2.1999 3.7.2002 20.6.2003 10.7.2003 27.11.2002 13.2.2001	1.4.2012 1.3.2001 1.8.2007 1.7.2008 - 1.12.2007 1.3.2003	25/5/2010	
BD-E715	Firecut FM-900 Intumescent Paint Coating	Yung Chi Paint & Varnish Mfg. Co. Ltd	120	-	UKAS	Warrington Fire Research Centre Bodycote Warrington	C125252 WF 164158	19.6.2002 8.5.2007	1.7.2007 1.6.2012	25/5/2010	
BD-E716	Fire Damper	Delta Pyramax Co. Ltd.	253 255 240	- - -	IANZ	BRANZ	FR 2230 FR 2317 97/1057	16.7.1996 5.3.1997 18.4.1997	-	25/5/2010	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E717	Tanda AP25	Warwick Building Material Ltd.	120	120	HOKLAS	Research Engineering Development Facade Consultants Limited	R09F19	20/6/2009	19/6/2014	25/5/2010	
BD-E718	Promatect-H 2hr. FRP Enclosure	Promat International (Asia Pacific) Ltd.	120	120	UKAS	Bodycote Warrington	WF No. 169576	19/12/2007	1/1/2013	25/5/2010	
BD-E719	"Supalux" Ceiling System	Intumex Asia Pacific	120	120	UKAS	BRE	CC85383 Review 4	14/1/2008	13/1/2013	25/5/2010	
BD-E720	12 mm Promatect-H	Promat International (Asia Pacific) Ltd.	120	120	UKAS	BRE	CC224611	19/5/2006	19/5/2011	25/5/2010	
BD-E721	Ytong Block	Daido Home International Ltd.	360	360	UKAS	Bodycote Warringtonfire Warrington Fire Research centre	WF 175168 54273	17.7.2008 2.9.1991	1.8.2013 -	25/5/2010	
BD-E722	FRP Access Panel	Power Creation Eng. Ltd.	120	-	HOKLAS	Research Engineering Development Facade Consultants Ltd.	R09E11	26/5/2009	25/5/2011	25/5/2010	
BD-E723	2 hr FRP Fire Shutter	Sanwa Shutter (HK) Ltd.	120	-	UKAS	Warringtonfire Bodycote Warringtonfire Bodycote Warringtonfire	C80427 164754 164762	10.12.1992 27.7.2007 12.5.2008	1.1.1995 1.8.2012 1.6.2013	25/5/2010	
BD-E724	2 HRs Fire Rolling Shutter	Suzuki	120	-	UKAS	Warrington Fire Research Ltd. Bodycote Warringtonfire	WFRC 136772 WF 184260	28.6.2004 23.6.2009	1.7.2009 1.7.2014	25/5/2010	
BD-E725	Fire rated roller shutter	Chung Tai Roller Shutter Co. Ltd.	240	-	IANZ	BRANZ	FAR 1659-1	7/11/2000	Indefinite	25/5/2010	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E726	Fire Shutter	Sanwa Shutter	240	-	HOKLAS	Research Engineering Development Facade Consultants Ltd.	R09J12	8/10/2009	7/10/2011	25/5/2010	
BD-E727	2 hrs FRP Ceiling Membrane (System 1)	Promat Int'l (Asia Pacific) Ltd.	120	120	UKAS	BRE Global	CC 90656A Review 2	25/9/2008	25/9/2013	25/5/2010	
BD-E728	Firesteel Classic 120	Firetherm Intumescent & Insulation Supplies Ltd.	60 60	- -	UKAS	Bodycote Warringtonfire	WF C155649/A WF C155649/B	15.6.2006 15.6.2006	1.7.2011 1.7.2011	25/5/2010	
BD-E729	Durasteel Enclosure	Intumex Asia Pacific Pte Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd.	WFRC C132908 WF 176906	28.10.2003 29.9.2008	1.11.2008 1.10.2013	25/5/2010	
BD-E730	TANDA AP25 Fire Protection Plaster	Chund Shun Chemical (H.K.) Co. Ltd.	120	-	HOKLAS	Research Engineering Development Facade Consultants Ltd.	R08C06	9/4/2008	8/4/2013	25/5/2010	
BD-E731	Steel Stud & Promina 60 Smoke Barrier System	Promat International (Asia Pacific) Ltd.	120	-	UKAS	BRE	CC206010 Review 1	4/10/2006	31/10/2011	25/5/2010	
BD-E732	Promatect H Enclosures to General Building Services	Promat Int'l (Asia Pacific) Ltd	120/240	-	UKAS	Bodycote Warringtonfire	WF 169576 Issue 2	19/12/2007	1/1/2013	25/5/2010	
BD-E733	AUGREEN 100mm Thick Block Wall System	CaSo (HK) Engineering Co. Ltd	240	240	HOKLAS	RED	R07L11A	3/12/2007	2/12/2010	25/5/2010	
BD-E734	12 mm Promatect-H	Promat Int'l (Asia Pacific) Ltd	240	240	UKAS	BRE	CC224611	19/5/2006	19/5/2011	25/5/2010	
BD-E735	Intumex Fire Collar	Intumex Asia Pacific Pte Ltd.	240	-	NATA	Bodycote Warringtonfire Warrington Fire Research	BWA 22994-01 WFRA 45712.2	26.08.2008 18.06.2003	31.08.2013 30.06.2008	25/5/2010	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E736	Promatect-H for Spandrel Wall System	Promat Int. Asia Pacific Ltd.	120	-	UKAS	Building Research Establishment (BRE)	CC90190A Review 3	14/2/2007	21/2/2012	7/7/2010	
BD-E737	Lateral sliding roller shutter	Chung Tai Roller Shutters Co. Ltd.	240	-	IANZ	BRANZ	FAR 2296 Issue 2	29/4/2006	29/4/2011	7/7/2010	
BD-E738	13mm Thai Gypsum Firestop Board	BPB Thai Gypsum	120	120	UKAS	The Building Test Centre	BTC 16141 FA	03/12/2008	02/12/2013	7/7/2010	
						UKAS	The Building Test Centre	BTC 12474F	16/01/2003		
BD-E739	2 hrs Promatect-H fire resistant board (12mm THK.)	Promat International (Asia Pacific) Ltd.	120	120	HKAS	BRE	CC 242335 Review 2	16.6.2008	16.6.2013	25/8/2010	
BD-E740	100mm thick Falk Country Light Weight Block Wall System	Wealth Bridge Trading Co. Ltd.	255	255	HOKLAS	RED	R07K23B Assessment Report R09M10	24/10/2007 14/12/2009	- 13/12/2011	25/8/2010	
BD-E741	Fire Shutter	Brightview Engineering Co Ltd	120	-	IANZ	BRANZ	FAR 3355	1.9.2009	Indefinite	20/10/2010	
BD-E742	HORIZONTAL SLIDING SHUTTER	SUZUKI SHUTTER COMPANY (HK) LTD.	240	-	HOKLAS	RESEARCH ENGINEERING DEVELOPMENT FAÇADE CONSULTANTS LIMITED	R09G06A R05B06	7/8/2009 21/3/2005	6/8/2011	20/10/2010	
BD-E743	Promatect H Steel Duct Protection Systems	Promat International (Asia Pacific) Ltd	120	120	UKAS	BRE Global Ltd	CC89273 Review 4 Test Report WARRES No. 37767	28.8.2008 12.6.1986	28.8.2013 -	16/12/2010	
BD-E744	Fireshield Type 5 Fire Resistant Wallboard	Knauf	120	120	UKAS	BRE Global Ltd.	CC263211	13 Jul 2010	13 Jul 2015	17/2/2011	
BD-E745	Fire damper	BSB Engineering Limited	240	-	IANZ	Building Research Association of New Zealand (BRANZ)	FP 3261 FAR 2239	8-Dec-2003 8-Dec-2003	- -	22/3/2011	Assessment Assessment

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E746	"Ruskin" IBD curtain type fire damper	Delta Pyramax Co. Ltd.	240	-	IANZ	BRANZ	Test Report FAR 2072 Issue 2, FR 2230, FAR 1713, FR 2317 Assessment Report 97/1057 Opinion No. FAR 1694 Opinion No.FAR1694-2	1.4.2003 16.7.1996 3.9.2001 5.3.1997 18.4.1997 7.8.2000 14.8.2000	Indefinite Indefinite Indefinite Indefinite Indefinite - -	22/3/2011	
BD-E747	Vertical Barrier	Knauf Drywall Ltd.	60	60	UKAS	BRE Testing	CC92939 Review 2	5.10.2007	5.10.2012	31/8/2011	
BD-E748	Durasteel	Intumex Asia Pacific Pte. Ltd.	120	120	UKAS	BRE Global	CC89388C REVIEW 4	19.8.2008	19.8.2013	31/8/2011	
BD-E749	Fire Shutter	Sanwa Shutter (HK) Limited	240	-	UKAS	Exova Warrington-fire	WF no. 306713	18/4/2011	1/5/2016	31/8/2011	
BD-E750	Durasteel Enclosures	Intumex Asia Pacific Ltd.	240	240	UKAS	Exova Warringtonfire	WF Assessment Report No. 196169	28-Sep-2010	1-Oct-2015	13/10/2011	
BD-E751	Durasteel Partition System	GELEC (HK) limited	120	120	HOKLAS	Research Engineering Development Façade Consultants	R10M02	15.12.2010	14.12.2012	13/10/2011	
BD-E752	Fire Shutters	Hang Yick Gate Engineering Ltd.	240	-	UKAS UKAS UKAS UKAS	Warrington Fire Research Bodycote Warringtonfire Warrington Fire Research Exova Warringtonfire	WFRC No. C107382 WF Report No. 179216 WFRC No. 139548 WF No. 188548	9/12/1998 12/12/2008 11/11/2003 17/11/2009	1/4/2001 1/1/2014 1/7/2009 1/12/2014	13/10/2011	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E753	"Janford" Mild steel Fire damper	Janford Air Flow Co. Ltd.	270	-	HOKLAS (Hong Kong)	Research Engineering Development Façade Consultants Ltd.	R07M12	21/01/2008	NIL (As per RED's 01/02/2008 letter)	13/10/2011	
BD-E754	Promatect-H (9mm thk.)	Promat International (Asia Pacific)	120	-	UKAS	Ecova Warringtonfire	WF 196073	24.8.2010	1.6.2015	13/10/2011	
BD-E755	Dura Steel Smoke Barrier	Intumex Asia Pacific Pte Ltd.	120	-	UKAS	Bodycote Warringtonfire Exova Warringtonfire	156469 310697B	14.08.2006 24.08.2011	01.09.2016	29/12/2011	
BD-E756	"Augreen 80mm thk. Block Wall	CaSO(HK) Engineering Company Limited	120	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R10G14	26.07.2010	25.07.2013	17/9/2012	
BD-E757	Fire Shutter	Sanwa Shutter Ltd.	240	-	HOKLAS	Research Engineering Development Façade Consultants Ltd	R11J27	7/10/2011	6/10/2013	17/9/2012	
BD-E758	Wins Board-M09 Ceiling System	Wins Consultants Limited	120	120	HOKLAS	Research Engineering Development Façade Consultants Limited	R11A17	14/2/2011	13/2/2013	26/10/2012	
BD-E759	DURSTEEL ENCLOSURES	Intumex Asia Pacific Ltd.	240	240	UKAS	Exova Warringtonfire	196169	28/9/2010	1/10/2015	19/2/2013	
BD-E760	Rolling Fabric Fire Shutter	Suzuki Shutter Company (HK) Limited	120	120	HOKLAS	Forte Testing and Consultants Company Ltd.	IA12-076	1/8/2012	1/8/2017	19/2/2013	
BD-E761	"Supalux" Enclosure System (Integrity only)	Intumex Asia Pacific Ltd.	120	-	UKAS	Exova Warringtonfire	WF Report No. 323548	12/11/2012	1/12/2017	2/4/2013	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E762	KNAUF Superpanel Board	KNAUF Hong Kong Ltd.	60	60	HOKLAS	Forte Testing and Consultants Co Ltd	1A12-027	30/4/2012	30/4/2017	2/7/2013	
BD-E763	Promatect-H	Promat International (Asia Pacific Limited)	120	120	UKAS	Exova Warringtonfire	WF Report No. 323701B WF Report No. 168263(Issue 2)	12.12.2012 22.2.2008	1.1.2018 1.03.2013	25/10/2013	
BD-E764	75mm Y-Tong Autoclaved Aerated Concrete Block	Daido Home International Limited	158	158	UKAS	Exova Warringtonfire (Aus) Pty Ltd	26990-00	20/2/2012	28/2/2017	25/10/2013	
BD-E765	Promatect-H Enclosure	Promat International (Asia Pacific) Ltd.	120/240	-	UKAS	Exova Warringtonfire	323710C	12/12/2012	1/1/2018	25/10/2013	
BD-E766	Lateral Sliding Composite Fire Shutter	LIXIL Suzuki (HK) company Limited	261 240	38 30	HOKLAS	Forte Testing and Consultants Co. Ltd	IT 12-107 IA 13-020	10.01.2013 19.4.2013	19.4.2018	25/10/2013	
BD-E767	Composite Vertical Rolling Shutter	LIXIL Suzuki (HK) Co. Ltd.	240	30	HOKLAS	Forte Testing and Consultants Co., Limited	IA 13-066	19.4.2013	19.4.2018	6/1/2014	
BD-E768	'Meilux' Access Hatch System	Hung Team Building Material Company Limited	120	120	HOKLAS	Reasearch Engineering Development Façade Consultants Limited	Assessment Report No. R12G06	7.8.2012	6.8.2014	6/1/2014	
BD-E769	3M Panagraphics II Flexible Substrate	Media Link Technologies Ltd.	-	-	HOKLAS	RED	R13F35	8/7/2013	7/7/2015	6/1/2014	Non-combustible Display Surface
BD-E770	Fire Shutter (Vertical Drop Type)	Sanwa Shutter (HK) Ltd.	240	-	UKAS	Exova Warringtonfire	WF Report No. 328081	12.04.2013	01.05.2018	11/4/2014	
BD-E771	Fire Shutter (Vertical Drop Type)	Sanwa Shutter (HK) Ltd.	240	-	UKAS	Exova Warringtonfire	WF Report No. 328081	12.04.2013	01.05.2018	11/4/2014	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E772	Cafco Sprayfilm WB3	Promat International (Asia Pacific) Ltd.	120	-	UKAS	Bodycote Warrington Exova Warrington	176738B 319718B	19.9.2008 4.7.2012	1.10.2013 1.10.2014	11/4/2014	
BD-E773	"Lyrids-Pro" fire rated board	Golden Lyrids Construction Materials Ltd.	120	-	CNACL - China	Building Engineering Testing Centre China Academy of Building Research	BETC-NHPG-2013-50	22.10.2013	21.10.2016	18/7/2014	
BD-E774	"Lyrids-Pro" fire rated board	Golden Lyrids Construction Materials Ltd.	120	120	CNACL - China	Building Engineering Testing Centre China Academy of Building Research	BETC-NHPG-2012-47	21.12.2012	20.12.2015	18/7/2014	
BD-E775	Promatect-H	Promat International (Asia Pacific Ltd.)	120	120	UKAS	Exova Warringtonfire Bodycote Warringtonfire Fire	WF 323701D WF 177939 Issue 2	12.12.2012 20.11.2008	1.1.2018 1.12.2013	18/7/2014	
BD-E776	Durastee (9.5mm thk)	Intumex Asia Pacific Pte Ltd.	240	-	UKAS	Exova Warringtonfire	WF No. 310697B and WF No. 156469	24.8.2011 14.8.2006	1.9.2016 1.8.2011	22/9/2014	
BD-E777	Promatect H Ceiling Membrane System	Promat International (Asia Pacific) Ltd.	240	-	UKAS	Exova Warrington Fire	196073	24.08.2010	1/9/2015	24/3/2017	
BD-E778	Y-Tong Block (Symmetrical, non-load bearing concrete block wall)	Daido Home Int'l Ltd.	240	240	UKAS	Warrington Fire Research Centre Ltd. Bodycote Warrington Fire Exova Warrington	WARRES no. 68302 WF Report No. 177704 (Issue 2) EWA Report No. 28906-00	15.8.1996 21.10.2008 9.9.2013	- 1.11.2013 30.9.2018	24/3/2017	
BD-E779	"SUPALUX" Enclosure System	Intumex Asia Pacific Ltd.	120	120	UKAS	Bodycote Warringtonfire Exova Warringtonfire	WF Assessment Report No. 171662 Issue 2 WF Report No. 323702A	13.3.2008 14.12.2012	1.4.2013 1.1.2018	24/3/2017	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E780	2-hr FRR Concrete Block	King Stream (H.K.) Limited	120	120	HOKLAS	Research Engineering Development Façade Consultants Limited	R09J18_issue 1	2.8.2011	-	24/3/2017	
BD-E781	Durasteel – 6mm 2 hr FRP panel	Intumex Asia Pacific Pte Ltd.	240	240	UKAS	Warrington Fire Research Centre Exova Warringtonfire	WFRC no. C132908 WF no. 328513A (Assessment) WFRC no. 137687 (Assessment) WF No. 341270B (Assessment) CC91702 Review 4 (Assessment)	28.10.2003 30.5.2013 18.3.2004 5.6.2014 20.5.2013	1.11.2008 1.7.2018 1.3.2009 1.7.2019 20.5.2018	24/3/2017	
BD-E782	Rolling Fabric Fire Shutter	Suzuki Shutter Company (HK) Limited	248 240	193 120	HOKLAS	Forte Testing and Consultants Co. Ltd.	IT 12-016 IA 12-076-R1	16.5.2012 19.11.2012	- 1.8.2017	24/3/2017	
BD-E783	“PROMATECT-H” 9mm Fire Rated Board and 15mm Fire Rated Board	Promat International (Asia Pacific) Limited	60 120	60 120	UKAS	BRE Global Ltd.	CC285449	19.4.2013	19.4.2018	24/3/2017	
BD-E784	Precast Concrete Brick	Fook Wah Construction Material Ltd.	121	121	CNAS	Guangzhou Building Material Institute Limited Company	V01-1000085	12.4.2010	-	24/3/2017	
BD-E785	Lightweight Concrete Block	Kwok Chi Construction Materials Ltd.	264	264	UKAS	Bodycote Warringtonfire Exova Warringtonfire	WF 173470 Issue 3 EWA Report no. 28472B-00	19.5.2008 6.5.2013	- 31.5.2018	24/3/2017	
BD-E786	Promina 60 (Insulation Partition System)	Promat International (Asia Pacific) Ltd.	120	120	UKAS	Exova Warringtonfire	WF 318311	25.6.2012	1.6.2017	24/3/2017	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E787	Hilti CP606 (Gap Sealing System)	Hilti	120	-	UKAS	Warrington Fire Research Centre Ltd. Exova Warringtonfire	69754/C 342981d	16.1.1997 22.7.2014	15.1.1999 1.8.2016	24/3/2017	
BD-E788	PROMATECT-H Board	Promat International (Asia Pacific) Ltd.	120	120	UKAS	BRE Global Ltd.	CC 224611 Review 1	12.4.2011	12.4.2016	24/3/2017	
BD-E789	Concrete Block	K. Wah Construction Products Ltd.	240	233	UKAS	Warrington Fire Research Centre Exova Warringtonfire	63257 EWA Report no. 25566-00	14.3.1995 28.1.2011	- 31.1.2016	24/3/2017	
BD-E790	Monokote Z106 Fireproofing Plaster	Grace Construction Products	240	-	UKAS	Warrington Fire Research Centre Ltd. Warrington Fire Research Centre Ltd. Exova Warringtonfire	54282 C127374 FP320326	10.9.1991 30.9.2002 10.7.2012	- 1.10.2007 1.8.2017	24/3/2017	
BD-E791	K.W. Fusible Link	K-Win Metal Works Manu Co	-	-	FSD acceptance letter	-	FP(LC)316/18	20/7/2015	1/7/2020	8/3/2019	
BD-E792	100mm Thick FRR Concrete Block	Ho Tin Marterials Trading Limited	135	135	HOKLAS	Research Engineering Development Façade Consultants Limited	R15F23-3	20.10.2015	-	8/3/2019	
BD-E793	Firex board 6mm without insulation	New City Resources Inc.	240	-	IANZ	BRANZ	FR2647 FAR2058	28.7.1999 6.1.2003	Indefinite Indefinite	8/3/2019	
BD-E794	Promatect -H	Promat International (Asia Pacific) Ltd	60	60	UKAS	Warrington Fire Research	177939 Issue 2	20.11.2008	1.12.2013	8/3/2019	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E795	"Hi-Tech Pro" Fire Rated Rolling Fabric Shutter System (FRSG3-E240/EI30)	Intumescent Systems (Greater China) Ltd	261	40	Interational Accreditation Service	Leading Edge Construction Materials Teting Company Limited	Q16A103 A17-004rl A17-017	15.8.2016 1.3.2017 20.10.2017	- 29.1.2022 19.10.2022	8/3/2019	
BD-E796	Laser Fire & Smoke Damper	Laser Resources (Asia) Co Limited	250	-	IANZ	BRANZ	(1) BRANZ report no.FR3547 Issue 2 (2) BRANZ report no. FAR 4589 (3) BRANZ report no.FAR 2908 Issue 3	29.1.2007 12.10.2016 27.7.2007	- 12/10/2021 -	8/3/2019	
BD-E797	Y-TONG BLOCK	Daido Home International Ltd.	240	240	NATA	EXOVA WARRINGTON Aus Pty Ltd 2013-2014	EWA Report No. 28906-01 WARRES NO.68302	2014.07.30 1996.10.03	2018.09.30 2001.10.02	8/3/2019	
BD-E798	Insulated Vertical Sliding Roller Shutter	Sanwa Shutter (H.K.) Limited	240	30	HOKLAS	Research Engineering Development Façade Consultants Limited	Assessment Report No. R16H30-1A Test Report No. R13K43	14/9/2016 22/1/2014	13/9/2018 -	8/3/2019	
BD-E799	Promatect H	Promat Int' (Asia Pacific) Ltd.	120	120	UKAS	Exova Warringtonfire	WF Report No. 393837D	03 Jan 2018	31 Dec 2022	8/3/2019	
BD-E800	Promat -H	Promat International (Asia Pacific) LTD	60	-	UKAS	BRE Global Bodycote Warringtonfire	Report No. CC 91456A Review 5 Issue 1 WF Assessment Report No. 169576 Issue 2	19-May-2016 19-Dec-2007	19-May-2021 01-Jan-2013	8/3/2019	
BD-E801	Falk Country Branch Precast Concrete Block Wall 150mm thk	Wealth Bridge Trading Co. Ltd.	240	240	NATA	Exova Warringtonfire Aus Pty Ltd	Assessment Report 3002502B-00 (assessment referenced W00030B+ supplement 1)	25/1/2016	31/1/2021	8/3/2019	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E802	Guang Ming AAC Block Wall System	King Stream (HK) Limited	250	250	HOKLAS	Research Engineering Development Façade Consultants Limited	Test Report R09J18B_issue 1	2/8/2011	-	8/3/2019	
BD-E803	Promatect-H Board	Promat International (Asia Pacific Ltd)	120	120	UKAS	Warrington Research Centre	Explanatory fire tetsts 37300 Warres No. 35023 Warres No. 35024 Warres No. 37129 Warres No. 36188 WRCSI No. 35992 WRCSI No. 35993	16/10/1985 2/10/1985 2/10/1985 25/10/1985 17/10/1985 14/2/1985 14/2/1985	-	8/3/2019	
BD-E804	Multigip FRP block wall 100mm thk	Kwan Tai Engineering Company Limited	240	240	NATA HOKLAS	Exova Warringtonfire Aus Pty Ltd Forte testing and consultants Ltd.	EWA Report No. 3002759-00 Test report no. IT 12-111	22/4/2016 15/1/2013	30/4/2021 -	8/3/2019	
BD-E805	Y-TONG FRP BLOCK	Daido Concrete (H.K.) Ltd	240	240	NATA	EXOVA WARRINGTONFire Aus Pty Ltd 2013	EWA Report No. 28906-00	9-Sep-13	30-Sep-18	8/3/2019	
BD-E806	YTONG Block Wall	Daido Home International Ltd.	158	158	NATA	Exova Warrington Aus Pty Ltd 2011-2012	EWA Report No. 26990-01	8/2/2017	28/2/2022	8/3/2019	
BD-E807	Wins H-Tec Fire Protection Panel	Wisma Tung Nam Ltd.	120	120	CNAS L0230	Building Engineering Testing Center, China Academy of Building Research	BETC-NH-2012-3189	19/2/2013	-	8/3/2019	
BD-E808	Intumescent Paint Caico SPRAYFILM WB3	Promat International (Asia Pacific) Ltd.	120	-	UKAS	Exova Warringtonfire	WF Report No. 338496B	10.3.2014	1.4.2019	8/3/2019	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E809	Guang Ming AAC Block Wall System	King Stream (H.K.) Limited	250	250	HOKLAS	Research Engineering Development Façade Consultants Limited (RED)	R09J18B_issue 1	2.8.2011	-	8/3/2019	
BD-E810	YTONG AAC BLOCK	Daido Home International Limited	240	240	NATA UKAS	Exova Wattrington Aus Pty Ltd Warrington Fire Research Centre Ltd.	EWA Report No. 300603-00 WARRES No. 54273	24.04.2018 03.10.1991	24.04.2023 -	8/3/2019	
BD-E811	Greentech Gypsum Block	Greentech Building Material Ltd.	240	240	HOKLAS	Forte Testing and Consultants Co., Ltd.	IT 16-209	10.11.2016	-	8/3/2019	
BD-E812	100mm thk Y tong block	Daido Home International Ltd	240	240	NATA	Exova Warringtonfire Aus Pty Ltd 2013-2014	28906-01	30/7/2014	30/9/2018	8/3/2019	
BD-E813	Vertical rolling composite fire shutter	LIXIL Suzuki (H.K.) Company Limited	253	57	HOKLAS	Forte Testing and Consultants Company Limited	IT 12-099	17/10/2012	-	8/3/2019	
BD-E814	Y-Tong Block	Daido Home International Ltd	360	360	NATA	Exova Warrington Aus Pty Ltd 2018	EWA Report No. 3004603-00	24/4/2018	30/4/2023	8/3/2019	
BD-E815	Promatect H (12mm)	Promat International (Asia Pacific) Ltd.	120	120	UKAS	Exova Warringtonfire	WF Report No. 323107B	12.12.2012	1.1.2018	8/3/2019	
BD-E816	Falk Country' Fire-rated block wall	PRC	264	264	HOKLAS	RED Façade Consultants Limited	R13M29-2 R17K42-1A	18.6.2014 15.12.2017	- 14.12.2020	8/3/2019	
BD-E817	Y-tong Block	Daido Home International Ltd	240	240	NATA	Exova Warrington Aus Pty Ltd.	EWA Report No. 28906-02	13.8.2018	31.8.2023	8/3/2019	
BD-E818	Wins M09 Fire Protection Board Partition	Wisma Tung Nam Ltd.	241	218	CNAS	Fire Test Lab CABR	CABR-NH-2017-01774	22.11.2017	-	8/3/2019	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E819	Composite Vertical Rolling Shutter	LIXIL Suzuki (HK) Co. Ltd.	240	30	HOKLAS	Forte Testing and Consultants Co. Ltd.	IT 12-099 IT 13-066 (Version 3) IT 13-123 (Version 2)	10.01.2013 10.03.2016 09.06.2017	- 01.12.2019 09.06.2022	8/3/2019	
BD-E820	Firecut FM900	Yung Chi Paint & Varnish Mfg. Company Limited	120	-	UKAS	Bodycote Warringtonfire Exova Warringtonfire	WF Report no. 167317 WF Report no. 316831 WF Report no.354492	20.12.2007 23.03.2012 28.07.2015	01.01.2013 01.04.2017 30.06.2019	1.8.2019	
BD-E821	"PROMATECT-H" insulated enclosure systems	Promat International (Asia Pacific) Ltd.	120	120	UKAS	BRE Global	Assessment Report CC 285449 Review 1 Issue 1	6/02/2018	6/02/2023	1.8.2019	
BD-E822	Fire Shutters	Bell Roller Shutter Ltd	242	-	IAS	United Testing Limited	Assessment Report UTL-A004-2017	3/01/2017	3/01/2021	1.8.2019	
BD-E823	Lateral Sliding Composite Fire Shutter	Lixil Suzuki (HK) Company Ltd.	255 261 240	31 38 30	HOKLAS	Forte Testing and Consultants Company Ltd. (Forte)	Test Report IT 12-067 Assessment Report IA 13-020-A_Ver 3	15.12.2012 25.4.2018	- 25.4.2023	1.8.2019	
BD-E824	Fire Shutter	Sanwa Shutter (HK) Limited	120	30	Research Engineering Development Façade Consultants Ltd	HOKLAS	Assessment Report R14C35_ Issue 1 R17B26-1A R19B10-1A	10/11/2017 12/4/2017 28/2/2019	9/11/2019 11/4/2019 10/4/2021	1.8.2019	
BD-E825	Knauf Fireshield Plasterboard	Knauf Hong Kong Limited	128	120	UKAS	BRE Global Ltd.	Report No: CC282247.	20/6/2014	20/6/2019	1.8.2019	
		Knauf UK GmbH	128	120	UKAS	Chiltern International Fire Ltd (CIFL)	Report No: Chilt/RF11036	15/6/2011	14/6/2016		

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E826	Durasteel Enclosure	Intumex Asia Pacific Pte Ltd.	120	-	UKAS	Exova Warringtonfire	401396D	10.7.2018	1.7.2023	13.12.2019	Assessment Report for WFRC No. C132908
BD-E827	Fire Damper	Yuen Fong Air-Condition Products (HK) Ltd.	246	3	HOKLAS	Research Engineering Development Façade Consultants Limited - Fire and Façade Testing Laboratory	R17F35-1A	28.8.2017	-	13.12.2019	
BD-E828	-/120/120 FRR access panel	Promat International (Asia Pacific) Ltd.	120	120	UKAS	BRE Global Ltd.	CC 262940 Review 1	6.2.2015	6.2.2020	13.12.2019	
BD-E829	Knauf Fireshield plasterboard	Knauf Drywall Ltd.	60	60	UKAS	BRE Global Ltd.	Assessment Report CC 91503 (Review4)	29.7.2014	29.7.2019	13.12.2019	
BD-E830	Promatech-H enclosure system	Promat International (Asia Pacific) Ltd.	120	120	UKAS	Exova Warringtonfire	Assessment Report WF 382587B	27.7.2017	31.7.2022	13.12.2019	
BD-E831	Concrete Block Wall 4612S (100mm thk)	K. Wah Construction Products Limited	120	120	NATA	Exova Warringtonfire	Assessment Report 24715-03	23.4.2015	30.4.2020	13.12.2019	Assessment report for WARRES No.63257
BD-E832	Promatect H FRP Enclosure for Ducts	Promatect International (Asia Pacific) Ltd.	240	240	UKAS	Exova Warringtonfire	Test Report WF No. 178825 Issue 2 Assessment Report WF No.393838	25.10.2013 3.1.2018	1.1.2019 31.12.2022	13.12.2019	
BD-E833	Promatect-H with mineral wool fiber	Promat International (Asia Pacific) Ltd.	60	60	UKAS	Exova Warringtonfire	Assessment Report WF 168263 Issue 3	30.9.2016	30.9.2021	13.12.2019	
BD-E834	"GDG" Autoclaved Aerated Concrete Block (100mm)	Guangzhou Development Green Building Materials Co. Ltd.	271	271	HOKLAS	Fugro Technical Services (Guangzhou) Limited	G13208FU130081A	10.11.2016	-	13.12.2019	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E835	100mm thick Guang ming AAC block wall system	King Stream (HK) Ltd.	240	240	HOKLAS	Research Engineering Development Façade Consultants Limited	Assessment Report RED R13L16 Review Letter R18A22-1A	11.12.2013 22.1.2018	- 22.11.2020	13.12.2019	Assessment Report for R09J18B_issue 1+R836
BD-E836	100mm thick Concrete Block	King Stream (HK) Ltd.	240	240	HOKLAS	Forte Testing and Consultants Co Ltd	IT17-201	5.9.2017	-	13.12.2019	
BD-E837	Fire Resistance Roller Shutter	Proactive Engineering (HK) Co., Ltd.	240	204	CNAL	Far East Testing Centre	FT04167	30.11.2004	-	22.06.2020	
		Focus Roller Shutter Ltd.	120	120	IAS	United Testing Limited	UTL-A015-2017	10.12.2017	09.12.2022		
BD-E838	Promet-H Board	Promat International (Asia Pacific) Ltd.	120	-	UKAS	Exova Warringtonfire	323701C	12.12.2012	01.01.2018	22.06.2020	
BD-E839	75mm Thk. Non-loadbearing, Fully Insulated Lightweight Block Wall System	Shun Shing Trading Company	120	120	HOKLAS	Research Engineering Development Façade Consultant Limited	R14L21-2	29.01.2015	-	22.06.2020	
BD-E840	Un-insulated Mild Steel Fire Damper with Fusible Link	Luen Ming Pengsha Air Conditioning Factory Ltd.	245	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R09M20	02.02.2010	-	22.06.2020	
BD-E841	Curtain Type Fire Damper, "Laser" 9020 series	Laser Resources (Asia) Co., Ltd.	240	-	IANZ	BRANZ	FR3675	18.12.2006	-	22.06.2020	
							FR4309	12.05.2010	-		
							FAR4604	12.10.2016	12.10.2021		
BD-E842	Uninsulated Steel Fire Damper	Colmun Airflow Co. Ltd.	243	-	HOKLAS	RED Façade Consultants Limited	R16E30-1A	11.08.2016	-	13.07.2020	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E843	Un-insulated Vertical Mild Steel Fire damper	Teembase Development Ltd.	240	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R17F35-1B	28.08.2017	-	13.07.2020	
BD-E844	Promatech-H Enclosure	Promat International (Asia Pacific) Ltd.	120	-	UKAS	Bodycote Warringtonfire Exova Warringtonfire	169576 Issue 2 393837C	19.12.2007 03.01.2018	01.01.2013 31.12.2022	13.07.2020	
BD-E845	150mm Thick Autoclaved Aerated Concrete (AAC) Panel Wall Systems	Y-tong	240	240	HKAS SAC	Research Engineering Development Façade Consultants Limited TUV SUD PSB's Laboratory	R18A25-1A 7191077348-MEC13-DA	05.03.2018 09.01.2014	04.03.2020 -	13.07.2020	
BD-E846	Promatect-H ceiling membrane system	Promat Fire Protection Company Limited Promat International (Asia) Pacific Ltd	120	120	UKAS	The Loss Prevention Technical Centre Exova Warringtonfire	TE 5763 TE 89437 168263 Issue 3	18.04.1986 07.01.1998 22.02.2008	- - 30.09.2021	13.07.2020	
BD-E847	Single-screen Vertical Sliding Roller Shutter	Centaline Roller Shutter Limited	240	90	HOKLAS	RED Research Engineering Development Façade Consultants Limited	R17F44-1A R18D19-1A	30.01.2018 20.05.2018	- 21.05.2021	13.07.2020	
BD-E848	100mm thick Concrete Block Wall System	Shun Shing Trading Company	240	240	HKAS	Research Engineering Development Façade Consultants Limited	R14L21-1	29.01.2015	-	13.07.2020	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E849	Promatect-H Uninsulated Smoke Barriers	Promat International (Asia Pacific) Ltd.	120	-	UKAS	Exova Warringtonire	156468 Issue 2	17.08.2015	01.09.2020	13.07.2020	
BD-E850	Horizontal Sliding Shutter	Hang Yick Gate Engineering Ltd.	120	60	HOKLAS	Forte Testing & Consultants Co., Ltd.	IT 15-096 IA16-073	13.11.2015 13.04.2016	- 12.4.2021	26.02.2021	
BD-E851	Concrete Block Wall (75mm thick)	Guangzhou Development Green Building Materials Co., Ltd.	132	132	HOKLAS	FUGRO Technical Services (Guangzhou) Ltd.	G16377FU160034	18.05.2016	-	26.02.2021	
BD-E852	Cavity Barrier	Promat Building Systems Ptd Ltd.	60	60	UKAS	Warringtonfire Research Centre Ltd. EXOVA Warringtonfire	SC1282 SC2711D 329251D	31.05.1995 18.08.2003 24.05.2013	30.05.1997 31.08.2008 01.07.2018	26.02.2021	
BD-E853	75mm thick light-weight block partition system	Huizhou Xinye Building Material Co., Ltd.	120	120	HOKLAS	Researching Engineering Development Façade Consultants Limited	R05H02B	14.09.2005	-	26.02.2021	
BD-E854	Lateral Sliding Composite Fire Shutter	Lixil Suzuki (H.K.) Company Ltd.	240	30	HOKLAS	Forte Testing and Consultants Company Limited	IT 12-107 IA14-056 (Version 5) IA13-020-A Version 3	10.01.2013 25.04.2016 25.04.2018	- 07.06.2020 24.04.2023	26.02.2021	
BD-E855	Falk Country / GDG 發展建材' Lightweight Block Wall Systems	Greenway Building Materials Limited	242 240 246 240	242 240 246 240	HOKLAS	Research Engineering Development Façade Consultants Ltd.	R12E22-2 R17D12-1A R17H19-1A R17K42-1A	16.08.2012 11.05.2017 27.10.2017 15.12.2017	- 10.05.2020 - 14.12.2020	26.02.2021	
BD-E856	75mm thick Non-loadbearing Light-weight Block Partition System	Upright Trading Company	132	132	HOKLAS	Research Engineering Development Façade Consultants Ltd.	R12K11-1	23.01.2013	-	26.02.2021	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E857	75mm thick Fully Insulated Light-weight Block Wall System	Zhongshan Jianhong New Building Material Co., Ltd.	132	132	HOKLAS	Researching Engineering Development Façade Consultants Limited	R18E27-4A	22.10.2018	-	26.02.2021	
BD-E858	Polycarbonate sheet	Palram	-	-	UKAS	Exova Warringtonfire	315543	23.02.2012	-	26.02.2021	
BD-E859	Non-loadbearing 80mm thick "AUGREEN" Block Wall System	Jinan Jin Lu Yuan New Building Material Company Limited	120	120	CNAL HOKLAS	CNCF Research Engineering Development Façade Consultants Ltd.	2004-3291 R13A23 R18F21-1A	18.11.2004 04.02.2013 15.06.2018	- 03.02.2016 04.02.2022	26.02.2021	
BD-E860	75mm thick concrete block wall	Daido Home International Limited	120	120	UKAS	Warrington Fire Research Centre Ltd. Exova Warrington	C107899 385121	07.05.1999 17.07.2017	01.06.2001 01.08.2022	26.02.2021	
BD-E861	75mm thk. non-loadbearing fully insulated lightweight block wall system	Ho Tin Materials Trading Limited & Troop Investment Limited	60	60	HOKLAS	Research Engineering Development Façade Consultants Ltd.	R15F23-2	20.10.2015	-	26.02.2021	
BD-E862	75mm thick non-loadbearing fully insulated concrete block wall system	Ho Tin Materials Trading Limited	60	60	HOKLAS	Research Engineering Development Façade Consultants Ltd.	R15F23-4	20.10.2015	-	26.02.2021	
BD-E863	Non-loadbearing Blockwall Assembly	Daido Concrete (H.K) Ltd.	240	240	UKAS NATA	Warringtonfire Research Centre Ltd. Exova Warringtonfire	68302 C107898 28906-01 26956-01	03.10.1996 07.05.1999 30.07.2014 08.02.2017	02.10.2001 01.06.2001 29.09.2018 27.02.2022	26.02.2021	
BD-E864	Promatect-H Ceiling Membrane Systems	Promat International (Asia Pacific) Limited	120	120	UKAS	Exova Warringtonfire	174649 382587B 404022A	27.10.2008 27.07.2017 29.08.2018	01.11.2013 31.07.2022 31.08.2023	26.02.2021	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E865	Delta Ruskin IBD (G.M.S.) interlocking blade fire damper assembly	Delta Pyramas Co., Ltd.	250	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R07M18A	10.3.2008	-	26.02.2021	
BD-E866	Non-loadbearing concrete block wall partition system	Greenway Building Materials Ltd.	120	120	HOKLAS	Research Engineering Development Façade Consultants Ltd.	R11J18-1 R11K11A R11K11B	26.10.2011 02.11.2011 02.11.2011	- 31.10.2013 31.10.2013	26.02.2021	
BD-E867	Promatect-H steel stud partition system	Promat International (Asia Pacific) Limited	120	-	SAC-SINGLAS UKAS	PSB Corporation BRE Global Ltd.	54S053839/A/MW CC 83300 Review 6 Issue 1	30.07.2005 04.10.2016	- 09.10.2021	26.02.2021	
BD-E868	Promatect H	Promat International (Asia Pacific) Ltd.	60	60	UKAS	Warrington Fire Research Centre LPC Laboratories RED Façade Consultants Ltd. Bodycote Warringtonfire Exova Warringtonfire	WARRES No. 38435 TE 89437 R06L23 WF Assessment Report No. 177939 Issue 2 WF Assessment Report No. 168263 Issue 3 WF Report No. 393837D	15.08.1986 07.01.1998 20.03.2007 20.11.2008 30.09.2016 03.01.2018	- - - 01.12.2013 30.09.2021 31.12.2022	26.02.2021	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E869	BSB FD curtain fire damper	BSB Engineering Services Ltd.	240	-	UKAS	BRE Global Ltd.	263471 CC 269587 P106540-1000	23.12.2010 28.04.2011 04.11.2016	- 27.04.2016 -	26.02.2021	
BD-E870	Rolling Shutter	Sanwa Shutter (H.K.) Limited	120	-	UKAS	Bodycote Warringtonfire Exova Warringtonfire	WF Report No.: 164762 EWA Report No.: 3004529-00	12.05.2008 27.03.2018	01.06.2013 31.03.2023	26.02.2021	
BD-E871	Un-insulated Vertical Mild Steel Fire Damper	Unicom Engineering & Trading Company Limited	240	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R17B08-1A	02.06.2017	-	26.02.2021	
BD-E872	TANDA Fire Damper	Tanda International Co., Ltd	240	-	IANZ	BRANZ	FAR 3595 FR 3400 Issue 2 FR 3437 Issue 2 FAR 2570 Issue 2	08.06.2011 19.03.2015 19.03.2015 19.03.2015	- - - -	04.05.2021	
BD-E873	IBD Fire Damper	Delta Pyramax Co., Ltd.	240	-	IANZ	BRANZ	FR2230 FR2317 97/1057 FAR1694 FAR1694-2 FAR1713 FAR2072 Issue2 FAR3756 FAR4407Issue2	16.07.1996 05.03.1997 18.04.1997 07.08.2000 14.08.2000 03.09.2001 01.04.2003 13.01.2012 18.04.2015	- - - - - - - - 18.04.2025	04.05.2021	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E874	Firex Board	New City Resources Inc.	120	120	IANZ	BRANZ	FR2647	28.07.1999	-	04.05.2021	
					CNAL	Far East Fire Testing Centre	FT04091	25.06.2004	-		
					HOKLAS	Forte Testing And Consultants Ltd.	IA 10-033_Version 2	05.02.2016	04.02.2019		
BD-E875	Concrete block	K.Wah Construction Products Limited	240	233	UKAS	Warrington Fire Research Centre	63257	14.03.1995	13.03.2000	04.05.2021	
						Exova Warringtonfire	24715-03	23.04.2015	30.04.2020		
							25566-01	15.01.2016	30.01.2021		
BD-E876	Precast Concrete Solid Block Wall	Kin Ching Beser Co., Ltd.	240	139	UKAS	Warrington Fire Research Centre	R12780	26.04.1996	25.04.2001	04.05.2021	
					NATA	Exova Warringtonfire Aus Pty Ltd.	28641-02	02.08.2018	29.06.2023		
BD-E877	Vertical Rolling Shutter	Suzuki Shutter (Hong Kong) Limited	240	60	HOKLAS	Forte Testing and Consultants Co., Ltd.	IA19-267	12.12.2019	11.12.2022	04.05.2021	
BD-E878	Wins MO9 Fire Protection Board Ceiling System	Wisma Tung Nam Ltd.	241	241	CNAS	China Academy of Building Research Co., Ltd.	CABR-NH-2018-01681	16.01.2019	15.01.2024	04.05.2021	
BD-E879	Autoclaved Aerated Concrete Block Wall System (75mm thick)	Guangzhou Development Green Building Materials	120	120	HOKLAS	Fugro Technical Services (Guangzhou) Ltd.	G16377FU160034	18.05.2016	-	04.05.2021	
BD-E880	Precast Concrete Brick Wall	Fook Wah Construction Material Ltd.	120	120	HOKLAS	Forte Testing and Consultants Co., Ltd.	IA15-253_Ver.2	02.01.2019	30.12.2020	04.05.2021	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E881	Vertical Sliding Roller Shutter	Sanwa Shutter (H.K.) Ltd.	240	30	HOKLAS	Research Engineering Development Façade Consultants Limited	R17B26-1A R14C35_issue 1 R19B10-1A R19F29-1A	12.04.2019 10.11.2017 28.02.219 26.06.2019	11.04.2019 09.11.2019 10.04.2021 10.11.2021	04.05.2021	
BD-E882	Smoke Barrier System	Master Fire Protected Glazing Door & Window Co., Ltd.	60	-	CNAS	China Academy of Building Research	CABR-NH-2016-02317	07.02.2017	06.02.2022	04.05.2021	
BD-E883	Firex Fire-Rated Enclosure System	New City Resources Inc.	120	120	HOKLAS	Forte Testing and Consultants Co., Ltd.	IA15-092	10.07.2015	09.07.2020	04.05.2021	
BD-E884	Non-loadbearing Insulated 'Augreen' Blocks Wall System (100mm thick)	Guangzhou Qiao Da Building Materials Company Limited	120	120	HOKLAS	Research Engineering Developemnt Façade Consultants Limited	R13C13_Issue 1	17.06.2013	-	04.05.2021	
BD-E885	Concrete Block Wall System	King Stream (H.K.) Limited	120	120	HOKLAS	Research Engineering Development Façade Consulants Limited	R17J36-1A R19C44-1A	17.10.2017 16.04.2019	- 15.04.2021	04.05.2021	
BD-E886	YTONG Autoclaved Aerated Concrete Block (100mm thick)	Ytong (Hong Kong) Limited	240	240	UKAS NATA	Warrington Fire Research Centre Ltd. Exova Warringtonfire Aus Pty Ltd	Warres No.68302 EWA Report No.28906-02	03.10.1996 13.08.2018	- 30.08.2023	23.08.2021	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E887	'Falk Country' Concrete Block Wall Systems	Greenway Building Materials Limited	120	120	HOKLAS	Research Engineering Development Façade Consultants Limited	R15K19 R17J10-1A	09.11.2015 14.09.2017	- 12.09.2020	23.08.2021	
BD-E888	Prefco 5000 series modular damper	Prefco-JohnsonTech Air Control Inc.	240	-	UKAS	The Loss Prevention Council BRE Global Ltd	TE 87808A CC 87874 Review 5 Issue 1	02.09.1996 12.01.2018	01.09.2001 11.01.2023	23.08.2021	
BD-E889	Smoke Curtain Assembly	GELEC (HK) Limited	125	-	UKAS	Exova Warringtonfire	323133A 323133B	19.11.2012 19.11.2012	- -	23.08.2021	
BD-E890	Vertical Drop Metallic Panel Shutter	Hang Yick Gate Engineering Limited	120	120	HOKLAS	Forte Testing and Consultants Co., Ltd.	IT13-103 IA16-014	10.09.2013 03.03.2016	- 02.03.2021	23.08.2021	
BD-E891	Fire Resistance Concrete Block	K. Wah Construction Products Limited	60	60	UKAS	The Loss Prevention Council LPC Laboratories	TE 92757	11.08.1999	-	23.08.2021	
BD-E892	Promatect H	Promat International (Asia Pacific) Limited	240	-	UKAS	Exova Warringtonfire Bodycote Warringtonfire	WF Report No. 380239 WF Assessment Report No. 159773 Issue 2	21.02.2017 07.12.2006	27.02.2022 31.12.2011	23.08.2021	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E893	Y-Tong Block Wall (150mm thick)	Daido Home International Limited	360	360	UKAS	Warrington Fire Research Centre Ltd.	54273	03.10.1991	-	23.08.2021	
					NATA	Exova Warringtonfire Aus Pty Ltd	28459-00	06.05.2013	30.05.2018		
BD-E894	Concrete Block (100mm thick)	Zhong Jia Xing Cement Products Manufactory	120	120	HOKLAS	Research Engineering Development Façade Consultants Limited	R17F12-1A	30.08.2017	-	23.08.2021	
BD-E895	WINS Fire Protection Board (MO9)	Wisma Tung Nam Ltd	67	67	CNAS	China Academy of Building Research	CABR-NH-2017-00630	27.06.2017	-	23.08.2021	
BD-E896	TANDA Curtain Type Fire Damper	Tanda International Company Ltd.	240	-	IANZ	BRANZ	FR 3400 Issue 2	19.03.2015	-	23.08.2021	
							FR 3437 Issue 2	19.03.2015	-		
							FAR 2570 Issue 2	19.03.2015	-		
							FAR 2577 Issue 2	20.04.2015	-		
							FAR 3595 Issue 2	19.03.2015	-		
					HOKLAS	Research Engineering Development Façade Consultants Limited	R11E08 - Issue 1 R20C35-1A	02.06.2011 24.03.2020	31.05.2014 22.03.2025		
BD-E897	Promatect H Ceiling Membrane System	Promat International (Asia Pacific) Limited	120	120	UKAS	Warrington Fire Research Centre Ltd	58350	25.05.1993	-	23.08.2021	
					NATA	CSIRO Manufacturing & Infrastructure Technology	FSH 1126	17.06.2005	-		
					UKAS	BRE Global Ltd	CC90656A Review 3 CC90656A Review 4 Issue 1	15.07.2013 06.07.2018	14.07.2018 05.07.2023		

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E898	Fire Damper System	Delta Pyramax Company Limited	240	-	HOKLAS	Research Engineering Development Façade Consultants Limited Forte Testing and Consultants Company Limited	R19G25-2A IT19-130 IT19-200 IA20-086	02.10.2019 06.12.2019 06.12.2019 17.06.2020	- - - 16.06.2025	23.12.2022	
BD-E899	Smoke Barrier System	Master Fire Protected Glazing Door & Window Co., Ltd.	91 60	- -	CNAS	China Academy of Building Research	CABR-NH-2016-02317 CABR-NHPG-2018-15	07.02.2017 24.04.2018	06.02.2022 23.04.2021	23.12.2022	
BD-E900	Gypsum Block (80mm thick)	King Stream (H.K.) Limited	278	278	HOKLAS	Forte Testing and Consultants Company Limited	IT 14-267	27.01.2015	-	23.12.2022	
BD-E901	100mm Thick Fully Insulated Concrete Block Wall System	Fook Wah Construction Material Limited	121	121	CNAS HOKLAS	Guangzhou Building Material Institute Limited Company Research Engineering Development Façade Consultants Limited	V01-1000085 R20B13-1A	12.04.2010 04.03.2020	- -	23.12.2022	
BD-E902	'GREENTECH' Gypsum Block Wall System	GREENTECH Building Material Limited	267	267	HOKLAS	Forte Testing and Consultants Company Limited	IT19-247	21.01.2020	-	23.12.2022	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E903	Lateral Sliding Composite Fire Shutter	LIXIL Suzuki (H.K.) Company Limited Suzuki Shutter (HK) Limited	240	30 60	HOKLAS	Forte Testing and Consultants Company Limited	IT12-107 IA20-082	10.01.2013 18.05.2020	- 17.05.2023	23.12.2022	
BD-E904	Roller Shutter Door Assembly	Suzuki Shutter Company (HK) Limited	240	-	UKAS	Warrington Fire Research Centre Limited	43176	24.10.1988	-	23.12.2022	
BD-E905	Promatect H Ceiling Membrane Systems	Promat International (Asia Pacific) Limited	120	120	UKAS	Warrington Fire Research Centre Ltd. Exova Warringtonfire	58350 168263 Issue 3	25.05.1993 30.09.2016	- 30.09.2021	23.12.2022	
BD-E906	100mm thick Concrete Block Wall System	King Stream (H.K.) Limited	260	260	HOKLAS	Forte Testing and Consultants Company Limited	IT17-201_Version 2	15.07.2019	-	23.12.2022	
BD-E907	Lateral Sliding Composite Fire Shutter	LIXIL Suzuki (H.K.) Company Limited Suzuki Shutter (HK) Limited	120	30	HOKLAS	Forte Testing and Consultants Company Limited	IT12-067 IT12-107 IA20-082	15.10.2012 10.01.2013 18.05.2020	- - 17.05.2023	23.12.2022	
BD-E908	Autoclaved Aerated Concrete Block (120mm thick)	中山市建宏新型建材有限公司	240	240	HOKLAS	Fugro Technical Services (Guangzhou) Limited	186478FU190103	25.06.2019	-	23.12.2022	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E909	PROMATECT-H partition system	Promat Fire Protection Company Limited	125	124	UKAS	The Loss Prevention Technical Centre	TE 5957	03.02.1987	-	23.12.2022	
		Promat International (Asia Pacific) Limited	120	120		BRE Global Ltd	CC 81584A Review 6 Issue 1	03.05.2017	02.05.2022		
BD-E910	Concrete Block Wall System	King Stream (H.K.) Limited	120	120	HOKLAS	Research Engineering Development Façade Consultants Limited	R17J36-1A R20M09-1A	17.10.2017 14.04.2021	- 13.04.2023	23.12.2022	
BD-E911	Smoke Curtain Assembly	Coopers Fire Limited	60	-	COFRAC	EFFECTIS France	10-V-428-Rev.1	05.04.2011	-	23.12.2022	
					HOKLAS	Research Engineering Development Façade Consultants Limited	R17A07-1A	06.01.2017	04.01.2022		
					UKAS	Exova Warringtonfire	WYC399605/04	17.10.2018	-		
BD-E912	100mm Thick Fully Insulated AAC Block Wall System with Lintel	Jetway Building Material Limited	241	241	HOKLAS	Research Engineering Development Façade Consultants Limited	R17C31-2A	16.05.2017	-	23.12.2022	
BD-E913	Un-insulated Vertical Mild Steel Fire Damper	Wysermann Company Limited	240	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R19M18-1A	06.07.2020	-	23.12.2022	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E914	MultiGips High Density Gypsum Block Wall System	Kwan Tai Engineering Co., Ltd.	240	240	HOKLAS	Forte Testing and Consultants Company Limited	IT 12-111	15.01.2013	-	23.12.2022	
					NATA	Warringtonfire Australia Pty Ltd	3002759-01	01.04.2019	29.04.2024		
BD-E915	Non-loadbearing partition systems	Knauf UK GmbH Knauf Hong Kong Limited	78	67	UKAS	Fulmer Yarsley Limited BRE Global Limited	J82131/17	20.01.1989	-	23.12.2022	
			60	60			CC 282247 Review 1 Issue 1	20.06.2019	19.06.2024		
BD-E916	100mm Thick Fully Insulated Lightweight Block Wall System	Zhongshan Jianhong New Building Material Co., Ltd.	242	242	HOKLAS	Research Engineering Development Façade Consultants Limited	R18E27-3A	22.10.2018	-	23.08.2024	
BD-E917	Fire Resistance Block Wall Assembly	Jiangmen Xinhui Yue Fung Cement Products Manufactory	257	257	IAS	Leading Edge Construction Materials Testing Company Limited	Q17A174	02.11.2017	-	23.08.2024	
BD-E918	'DEGO' Cement Block Wall	東莞市迪高水泥製品有限公司	260	260	HOKLAS	Fugro Technical Services (Guangzhou) Limited	186478FU190124	19.07.2019	-	23.08.2024	
BD-E919	'Greentech' Gypsum Block Wall	Greentech Building Material Limited	180	180	HOKLAS	Forte Testing and Consultants Company Limited	IT16-172	14.11.2016	-	23.08.2024	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E920	WINS MO9 Fire Protection Board Ceiling System	Wisma Tung Nam Ltd.	121	121	CNAS	China Academy of Building Research Co., Ltd.	CABR-NH-2019-01373	06.01.2020	05.01.2025	23.08.2024	
BD-E921	Composite Vertical Rolling Shutter	LIXIL Suzuki (Hong Kong) Company Limited Suzuki Shutter (Hong Kong) Limited	120	30	HOKLAS	Forte Testing and Consultants Co., Ltd.	IT12-099 IA19-267_Version 2	10.01.2013 15.05.2021	- 11.12.2022	23.08.2024	
BD-E922	100mm thick non-loadbearing fully insulated lightweight block wall system	Jiangmen Xinhui JIN YU MANUFACTURING LTD.	264	264	HOKLAS	Research Engineering Development Façade Consultants Limited	R15F23-1	20.10.2015	-	23.08.2024	
BD-E923	Wins Fire Protection Board Partition	Wins Consultants Limited	245	12	CNAS	Building Engineering Testing Center, China Academy of Building Research China Academy of Building Research Co., Ltd	BETC-NH-2003-408 CABR-NHPG-2020-54	20.11.2003 01.06.2020	- 31.05.2025	23.08.2024	
BD-E924	Un-insulated vertical mild steel fire damper	Kai Hang Air-Cond. Eng Co. Ltd.	242	5	HOKLAS	Research Engineering Development Façade Consultants Limited	R18L19-1A	23.11.2018	-	23.08.2024	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E925	Un-insulated vertical mild steel fire damper	Sun Chun Bo Trading Company Limited	240	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R20K05-1A	15.12.2020	-	23.08.2024	
BD-E926	Fire Damper System	Goodway Air Conditioning Equipment Limited	132	-	HOKLAS	Forte Testing and Consultants Company Limited	IT16-251	21.03.2017	-	23.08.2024	
BD-E927	'Falk Country / GDG 發展建材' Lightweight Block Wall Systems	Wealth Bridge Trading Company Limited Greenway Building Materials Limited	260 180 or 240	214 180 or 240	HOKLAS	Research Engineering Development Façade Consultants Limited	R15B09-1 R17K42-1A R20L14-1A	11.05.2015 15.12.2017 20.11.2020	- 13.12.2020 14.12.2023	23.08.2024	
BD-E928	Concrete Block Wall Systems	K. Wah Construction Products Limited	240	240	UKAS NATA	The Loss Prevention Council LPC laboratories Warringtonfire Australia Pty Ltd	TE 92757 24715-04	11.08.1999 06.04.2020	- 29.04.2025	23.08.2024	
BD-E929	Gypsum Block Wall	Greentech Building Material Limited	120	120	HOKLAS	Forte Testing and Consultants Company Limited	IT16-172	14.11.2016	-	31.10.2024	
BD-E930	Glazed Smoke Barrier System	Master Fire Protected Glazing Door & Window Co., Ltd. Fullview Holding (HK) Limited	91 60	- -	CNAS HOKLAS	China Academy of Building Research Forte Testing and Consultants Company Limited	CABR-NH-2016-02317 IA20-248	07.02.2017 17.11.2020	- 16.11.2022	31.10.2024	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E931	'AER BLOCK' Precast Concrete Blocks	Jiangmen Nanjian New Walling Materials Company Limited	300	300	HOKLAS	Forte Testing and Consultants Company Limited	IT13-184	26.12.2013	-	31.10.2024	
BD-E932	Insulated Single-Screen Vertical Sliding Roller Shutter Systems	LIXIL Suzuki (Hong Kong) Company Limited / Suzuki Shutter (Hong Kong) Limited	120	120	HOKLAS	Research Engineering Development Façade Consultants Limited	R19H23-1A R20C02-1A	01.11.2019 04.05.2020	- 02.05.2025	31.10.2024	
BD-E933	Insulated Vertical Sliding Roller Shutter Systems	Chung Tai Roller Shutters Co., Ltd.	240	80	HOKLAS	Research Engineering Development Façade Consultants Limited	R14C25-2 R14J16_Issue 1	24.06.2014 31.03.2020	- 29.03.2022	31.10.2024	
BD-E934	JIAN LI Autoclaved Aerated Concrete (AAC) Block	Zhongshan Jianhong New Building Material Co., Ltd.	270	270	HOKLAS	Research Engineering Development Façade Consultants Limited	R20E34-1A	03.08.2020	-	31.10.2024	
BD-E935	Fire Damper System	Tai Fung Air-Conditioning Engineering Company Limited	245	-	HOKLAS	Forte Testing and Consultants Company Limited	IT21-051	15.05.2021	-	31.10.2024	
BD-E936	DEGO Cement Block	東莞市迪高水泥制品有限公司	93	93	HOKLAS	Fugro Technical Services (Guangzhou) Limited	186478FU180195	26.03.2019	-	31.10.2024	
BD-E937	DEGO Autoclave Aerated Concrete Blocks	中山市建宏新型建材有限公司	60	60	HOKLAS	Fugro Technical Services (Guangzhou) Limited	202693FU206180	27.10.2020	-	31.10.2024	
BD-E938	Autoclaved Aerated Concrete (AAC) Block Wall	Master Connion Building Materials Limited	250	208	HOKLAS	Research Engineering Development Façade Consultants Limited	R09F02	03.08.2009	-	31.10.2024	
			240	240	NATA	Warringtonfire Aus Pty Ltd	24058-02	06.08.2019	30.08.2024		

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E939	PROMATECT-H partition system	Promat Fire Protection Co. Ltd.	370	370	UKAS	The Loss Prevention Council	TE 6371	11.12.1987	-	31.10.2024	
		Promat International (Asia Pacific) Limited	240	-		BRE Global Ltd	CC 91456 Review 5 Issue 1	05.07.2018	04.07.2023		
BD-E940	'GUANG MING' Auto-clave Aerated Concrete (AAC) Block Wall Systems	King Stream (H.K.) Limited	250	250	HOKLAS	Research Engineering Development Façade Consultants Limited	R09J18B_issue 1	02.08.2011	-	31.10.2024	
			240	240			R13L16 R20A22-1A	11.12.2013 04.02.2020	09.12.2015 04.02.2023		
BD-E941	'Forbes' Fire Rated Metal Shutter (FRMS-E120)	Sherex Engineering Ltd.	120	-	IAS	Leading Edge Construction Materials Testing Company Limited	Q14A21 A17-11	04.09.2019 23.09.2019	- 02.06.2022	31.10.2024	
BD-E942	Fire Damper System	Delta Pyramax Company Limited	240	-	HOKLAS	Forte Testing and Consultants Company Limited	IT19-130 IT19-200 IA20-086_Version 2	06.12.2019 06.12.2019 13.05.2021	- - 16.06.2025	31.10.2024	
BD-E943	Concrete Block Wall System	K. Wah Construction Products Limited	120	120	UKAS	Warrington Fire Research Centre Ltd.	63257	14.03.1995	13.03.2000	31.10.2024	
						NATA	Warringtonfire Australia Pty Ltd	24715-04	06.04.2020		
BD-E944	'Falk Country' Concrete Block Wall Systems	Wealth Bridge Trading Company Limited	120	120	HOKLAS	Research Engineering Development Façade Consulants Limited	R15K19 R20D23-1A	09.11.2015 24.08.2020	- 22.02.2023	31.10.2024	
BD-E945	Laser 9010 Model G Horizontal Fire Damper	Laser Resources (Asia) Co. Ltd.	245	-	IANZ	BRANZ	FR14147-001 Issue 1	17.12.2021	-	31.10.2024	
BD-E946	100mm Thick Fully Insulated Concrete Block Wall System	Dong Guan City Zhong Tong Dong Sheng Cement Products Factory	126	126	HOKLAS	Research Engineering Development Façade Consulants Limited	R17C29-1A	15.08.2017	-	31.10.2024	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E947	'KNAUF' Superpanel Board Uninsulated Partition Systems	Hinrich International Limited	130	9	HOKLAS	Research Engineering Development Façade Consultants Limited	R07A10	09.02.2007	-	31.10.2024	
		Knauf Hong Kong Limited	120	-			R14F04	26.06.2014	24.06.2019		
BD-E948	Fire Damper	Lung Ming Peng Shan Air Conditioning Factory Ltd.	120	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R07D23	07.08.2007	-	31.10.2024	
BD-E949	Promatect-H board	Promat International (Asia Pacific) Ltd.	241	241	NATA	CSIRO Manufacturing & Infrastructure Technology	FSH 1124	15.06.2005	-	31.10.2024	
			240	240	HOKLAS	Research Engineering Development Façade Consultants Limited	R22C10-1A	17.05.2022	15.05.2027		
BD-E950	Laser 9021 Series Horizontal Curtain Fire Damper	Laser Resources (Asia) Co., Ltd.	264	-	IANZ	BRANZ Limited	FR13582-001 Issue 1	14.06.2021	-	31.10.2024	
BD-E951	Concrete Block Wall 4612S (100mm thick)	K. Wah Construction Products Limited	120	120	UKAS	Warrington Fire Research Centre Ltd.	WARRES No. 63257	14.03.1995	13.03.2000	31.10.2024	
					NATA	Warringtonfire Australia Pty Ltd.	24715-04	06.04.2020	29.04.2025		
BD-E952	JIAN LI Autoclaved Aerated Concrete (AAC) Block	Zhongshan Jianhong New Building Material Co., Ltd.	135	135	HOKLAS	Research Engineering Development Façade Consultants Limited	R20E34-2A	03.08.2020	-	31.10.2024	
BD-E953	Un-insulated vertical mild steel fire damper	State Rich Air Conditioning Products Limited	240	-	HOKLAS	Research Engineering Development Façade Consultants Limited	R21C07-1A	12.04.2021	-	31.10.2024	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E954	Knauf Fireshield partition system	Knauf UK GmbH	78	67	UKAS	Fulmer Yarsley Limited	J82131/17	20.01.1989	-	31.10.2024	
			76	60		Building Research Establishment (BRE)	208415	11.07.2002	10.07.2007		
		Knauf Hong Kong Limited	60	60	HOKLAS	Forte Testing and Consultants Company Limited	IA12-009_Version 3	12.06.2020	11.06.2023		
BD-E955	Lyrids Fire Protection Board	Golden Lyrids Construction Materials Ltd.	120	120	CNAS	Building Engineering Testing Center, China Academy of Building Research	BETC-NH-2005-303	04.07.2005	03.07.2010	31.10.2024	
						China Academy of Building Research Co., Ltd.	CABR-NHPG-2021-33	25.05.2021	24.05.2026		
BD-E956	Fire Shutter	Sherex Engineering Ltd.	120	120	IAS	Leading Edge Cosntruction Materials Testing Company Limited	Q20A402	15.01.2021		31.10.2024	
						Leading Edge Cosntruction Materials Testing Company Limited	A22-01	17.01.2022	15.01.2027		
BD-E957	'Ytong' Lightweight Block Wall System	UBlok New Building Materials (Changxing) Co., Ltd.	121	121	HOKLAS	Research Engineering Development Façade Consultants Limited	R22A28-1A	01.03.2022	-	31.10.2024	
BD-E958	150mm thick non-loadbearing 'GREENTECH' gypsum block wall	Greentech Building Material Limited	240	240	HOKLAS	Forte Testing and Consultants Company Limited	IT22-025	02.03.2022	-	31.10.2024	
							IA22-032	10.05.2022	09.05.2025		
BD-E959	WINS 9mm H-TEC FIRE PROTECTION PANEL PARTITION SYSTEM	Wisma Tung Nam Ltd. Wins Consultants Ltd.	120	120	CNAS	China Academy of Building Research Co., Ltd.	CABR-NH-2019-01374 CABR-NHPG-2021-21	07.01.2020 07.04.2021	06.01.2025 06.04.2026	31.10.2024	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E960	Concrete Block Wall System	Wealth Bridge Trading Company Limited	260	226	HOKLAS	Research Engineering Development Façade Consultants Limited	R15B09-2	15.04.2015	-	31.10.2024	
BD-E961	Lloyd FSD-111 Series Damper	Lloyd Asia	128	-	IANZ	BRANZ Limited	FR 4218	20.04.2009	-	31.10.2024	
BD-E962	'Ytong' 150mm Thick Fully Insulated AAC Block Wall System with Lintel	Jetway Building Material Limited	264	264	HOKLAS	Research Engineering Development Façade Consultants Limited	R17C31-1A	16.05.2017	-	31.10.2024	
BD-E963	Fire Damper System	Ludar Metal Products (Shenzhen) Company Limited	132	-	HOKLAS	Forte Testing and Consultants Company Limited	IT17-272	28.12.2017	-	31.10.2024	
BD-E964	'Falk Country / GDG 發展建材' Lightweight Block Wall Systems	Wealth Bridge Trading Company Limited Greenway Building Materials Limited	246 180 or 240	246 180 or 240	HOKLAS	Research Engineering Development Façade Consultants Limited	R17H19-1A R17K42-1A R20L14-1A	27.10.2017 15.12.2017 20.11.2020	- 13.12.2020 14.12.2023	31.10.2024	
BD-E965	'Go Smooth' 75mm Thick Fully Insulated Concrete Block Wall System	Dong Guan City Zhong Tong Dong Sheng Cement Products Factory	60	60	HOKLAS	Research Engineering Development Façade Consultants Limited	R17C29-2A	15.8.2017	-	31.10.2024	
BD-E966	Steel framed curtain type rolling shutter	Focus Roller Shutter Limited	120	30	CNAS	Shenzhen Academy of Metrology & Quality Inspection	WT205100278 SMQ-A023-2021	20.05.2020 09.03.2021	- 08.03.2026	31.10.2024	
BD-E967	Lloyd FSD-111-Series Fire Damper System	Lloyd Asia Company Limited	245	-	IANZ	BRANZ Limited	FR 4217 Issue 2	23.11.2017	-	31.10.2024	
BD-E968	DEGO Cement Block Wall	東莞市迪高水泥制品有限公司	260	260	HOKLAS	Fugro Technical Services (Guangzhou) Limited	186478FU190124A	01.03.2022	-	31.10.2024	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E969	'Go Smooth' 100mm Thick Fully Insulated Concrete Block Wall System	Dong Guan City Zhong Tong Dong Sheng Cement Products Factory	126	126	HOKLAS	Research Engineering Development Façade Consultants Limited	R17C29-1A	15.8.2017	-	31.10.2024	
BD-E970	FRP Ceiling/Enclosure (1hr FRR - M&E Enclosure)	Promat International (Asia Pacific) Ltd.	60	60	UKAS NATA IANZ SAC-SINGLAS UKAS	Blackburn Fire Test Centre CSIRO Manufacturing and Infrastructure Technology BRANZ Limited PSB Corporation Warrington Fire Testing and Certification Limited	BFTC No. 98/27 (Test Report) CSIRO No.FSH 1212 (Test Report) FR 3829 (Test Report) 54S053839/A/MW (Test Report) WF382587A Issue 2 (Assessment Report)	26.5.2006 30.08.2006 14.08.2007 30.07.2005 05.09.2019	-- -- -- -- 31.08.2024	03.04.2025	
BD-E971	Un-Insulated Vertical Mild Steel Fire Damper	Luen Ming Pengshan Air Conditioning Factory Ltd/ ShenZhen	240	-	HOKLAS	Research Engineering Development Façade Consultants Limited- Fire and Façade Testing Laboratory	R20L31-1A	11.01.2021	--	03.04.2025	
BD-E972	Control Cabinet for Elenessa Lift	Guangdong Ryoden Lift & Escalator Co., Ltd.	120	N/A	CNAS	Far East Fire Testing Centre	FT10245	23.08.2010	--	03.04.2025	
BD-E973	DEGO Autoclave Aerated Concrete Blocks	Digao Building Materials Co., Ltd. / 中山市建宏新型建材有限公司	60	60	HOKLAS	Furgo Technical Services (Guangzhou) Ltd.	186478FU190104	25.06.2019	-	03.04.2025	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E974	ROCKWOOL RockSafe (60 kg/m ³) Rockwool Board	Rockwool Building Materials (Hong Kong) Ltd.	60	60	SAC	TUV SUD PSB's laboratory	7191067828-MEC13-KKC	12.09.2013	-	03.04.2025	
BD-E975	Non-loadbearing partition boards wall system with an access panel	Wins Consultants Limited	60	60	HOKLAS	Research Engineering Development Façade Consultants Limited	R18J02-1A	12.10.2018	-	03.04.2025	
BD-E976	Fire Shutter	Focus Roller Shutter Limited	120 mins	-	CNACL IAS	Far East Fire Testing Centre United Testing Limited	FT02084 ULT-A005-2020	28.07.2002 10.02.2020	- 09.02.2025	03.04.2025	
BD-E977	Fire Shutter	Golden Marco Development Company Limited	240	30	HOKLAS	Furgo Technical Services (GUANGZHOU) Limited	124540FU130005	25.04.2013	-	03.04.2025	
BD-E978	Lateral Sliding Roller Shutter Systems	Suzuki Shutter (HK) Ltd.	120	30	HOKLAS	Research Engineering Development Façade Consultants Ltd	R20C03-1A R19F07-1A	19.03.2020 01.11.2019	18.03.2025 -	03.04.2025	

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E979	Uninsulated Vertical Sliding Roller Shutter Systems	Sanwa Shutter (HK) Ltd. (HKSAR)	240	-	UKAS	Warrington Fire Research Centre Ltd.	WARRES 53350	13.09.1991	-	03.04.2025	
						HOKLAS	Research Engineering Development Facade Consultants Limited	WARRES 53353	13.09.1991		
								R22L16-1A	17.03.2023		
BD-E980	"Lyrids" Fire Rated Board Ceiling System	Golden Lyrids Construction Materials Ltd.	60	60	CNAS	Building Engineering Testing Center, China Academy of Building Research	BETC-NH-2007-335(A)	08.06.2007	07.06.2012	03.04.2025	
						CABR Fire Technology Co. Ltd	CABRFIRE-NHPG-2022-77	22.08.2022	21.08.2027		
BD-E981	CFS-SP WB Firestop Joint Spray	Hilti (Hong Kong)	120	120	HOKLAS	Research Engineering Development Façade Consultants Ltd.	R16J25-1A	06.10.2016	05.10.2018	03.04.2025	
							R23G16-1A Issue 1 (Review Letter)	17.07.2023	17.07.2026		
							R16E18-1A	30.08.2016	-		
BD-E982	Ruskin IBD Fire Damper	Delta Pyramax Company Limited (Hong Kong)	120	-	HOKLAS	Forte Testing and Consultants Co., Ltd	Test Report No. IA20-136	31.07.2020	31/07/2025	03.04.2025	
							Test Report No. IT19-200	06.12.2019	-		
BD-E983	9mm/12mm thick Promatect H Board (For Ceiling)	Promat International (Asia Pacific) Ltd (Malaysia)	120	120	Standards Malaysia	SIRIM	2022FE0251	30.05.2022	30.05.2027	03.04.2025	
						LPTC	TE5763	18.04.1986	-		
						WRC	WRCSI No. 34789	18.05.1984	-		
						FSRG	FSRG 2018/029	12.07.2018	-		

BD's Reference List under Central Data Bank

(E) Other Fire Resisting Products (e.g. fire shutter, etc)

Ref. No.	Product Name	Name of Manufacturer	Fire Resisting Performance (minutes)		Details of Test or Assessment Report					Date of Posting on CDB	Remarks/ Comments
			Integrity	Insulation	Name of laboratory accreditation body	Name of laboratory / assessing organization	Report no.	Date of test / assessment report	Validity Date		
BD-E984	100mm thick fully insulated lightweight block wall system	Dado Home International Ltd. (PRC)	240	240	HOKLAS	Research Engineering Development Façade Consultants Limited	R22A28-2A	28.07.2023	-	03.04.2025	
BD-E985	Guang ming AAC block wall system	King Stream (HK) Ltd.	240	240	HOKLAS	Research Engineering Development Façade Consultant Ltd	Assessment Report RED R13L16 Review Letter R23B07-1A	11.12.2013 07.02.2023	10.12.2015 06.02.2028	03.04.2025	
BD-E986	Non-loadbearing drywall partition system	Knauf (Hong Kong) LTD	120	120	UKAS	Exova Warringtonifre	WFS 01936-00 EWA3003398-00 Chit/RF11036 R16F19-4A	27.05.2022 06.03.2017 11.03.2011 10.11.2016	31.05.2027 31.03.2022 - -	03.04.2025	