

**Summary of Decisions of the Building Committee
Building Committee I 38/2004 held on 28.9.2004**

BCI 1 38/2004

- Issue : Projection of vertical and horizontal architectural features from an existing building approved under volume regulations.
- Decision : The committee noted that the sizes of the projections vary from 200mm to 300mm and that the projections would be wholly over the existing pavement. The committee accepted that the proposed features would not adversely affect the provision of lighting and ventilation and that the proposal would improve the external façade of the existing building and help to beautify the cityscape. The committee agreed to the recommendation subject to no adverse comments from outside departments.