

Summary of Decisions of the Building Committee
Building Committee I 38/2012 held on 3.10.2012

(a) BCI 1 38/2012

Issue : Exclusion of covered walkways on private flat roofs from GFA calculation.

Decision : Noting the advice of relevant outside departments and that the proposal was not in line with PNAP APP-42, the committee agreed not to permit the proposed exclusion of covered walkways on private flat roofs from GFA calculation.