

**Summary of Decisions of the Building Committee**  
**Building Committee I 33/2014 held on 19.8.2014**

(a) BCI 1 33/2014

Issue : Exclusion of vertical greenery from GFA and SC calculations.

Decision : Having studied the design, the committee agreed to exclude the vertical greenery from GFA and SC calculations subject to further substantiations.

(b) BCI 2 33/2014

Issue : Exclusion of voids from GFA calculations.

Decision : Noting that the voids located in a shopping arcade generally met the acceptance criteria under PNAP APP-2 and there was no objection from relevant departments, the committee agreed to exclude the voids from GFA calculations.