

**Summary of Decisions of the Building Committee
Building Committee I 7/2015 held on 17.2.2015**

(a) BCI 1 7/2015

Issue : Exclusion of architectural features from GFA and SC calculations.

Decision : Having considered that the architectural features were genuine design features and there was no objection from relevant departments, the committee agreed to exclude the architectural features from GFA and SC calculations.

(b) BCI 2 7/2015

Issue : Exclusion of A/C condensate recycling plant rooms from GFA calculations.

Decision : Having considered the design and the function of the proposed A/C condensate recycling system, the committee agreed to exclude the plant rooms from GFA calculations.