

Summary of Decisions of the Building Committee
Building Committee I 30/2015 held on 18.8.2015

(a) BCI 1 30/2015

Issue : Formal appeal against the decision of the Building Authority.

Decision : Having considered the case, the committee agreed to contest the appeal.

(b) BCI 2 30/2015

Issue : Exclusion of carpark and the associated driveways/ramps from GFA calculations.

Decision : Having considered the level of the street on which the site abutted and the existing topography of the site, the committee agreed that the proposed carpark could be accepted as an underground carpark and be disregarded from GFA calculations in accordance with paragraph 16(b)(vii)(4) of PNAP APP-2, subject to some modifications to the design.