

**Summary of Decisions of the Building Committee**  
**Building Committee I 42/2016 held on 22.11.2016**

(a) BCI 1 42/2016

Issue : Exclusion of rainwater and greywater recycling plant rooms from GFA calculation.

Decision : Having considered the design and the function of the proposed rainwater and greywater recycling systems, the committee had no objection in principle to exclude the plant rooms from GFA calculation subject to the acceptance on the greywater recycling system by relevant government department.