

Summary of Decision of the Building Committee
Building Committee II 5/2026 held on 23.6.2026

(a) BCII 1 5/2026

- Issues : Non-provision of fire separation between EV battery storage and charging room, and the rest of an EV battery swapping station
- Decisions : Having considered the case circumstance and there was no objection from relevant department, the committee had no objection to the proposed arrangement.