

Summary of Decision of the Building Committee
Building Committee II 7/2026 held on 1.9.2026

(a) BCII 1 7/2026

Issues : Performance-based approach to assess the provision of natural lighting and ventilation for habitable rooms and open kitchens.

Decisions : Noting that the simulation conducted was generally in line with the guidelines in PNAP APP-130 and the relevant conditions in the PNAP were met, the committee had no objection to adopt the performance-based approach.