Summary of Decision of the Building Committee
Building Committee II 8/2026 held on 22.9.2026

(a) BCII 1 8/2026

Issues	:	(i)		Fire service access points not situated on the ground storey.
		(ii)		Ground storey not served by fireman's lift.
Decisions	:	(i)	&	Having regard to the site circumstances and no adverse comment from the D of FS, the committee had no objection to the proposed arrangement subject to refinement of design.
		(ii)		