

Summary of Decisions of the Building Committee
Building Committee II 1/2005 held on 11.1.2005

(a) BCII 1 1/2005

Issue : Proposed A&A works to an existing hotel that a drain pipe passing through the compartment floor was not in compliance with the FRC Code.

Decision : The committee, having considered the AP's justification, agreed to the proposal subject to the CBS's satisfaction on the submitted test report.