

**Summary of Decisions of the Building Committee
Building Committee II 18/2005 held on 25.5.2005**

(a) BCII 1 18/2005

Issue : Window openings of proposed semi-detached single-family buildings with common structural wall have not been properly separated.

Decision : The committee agreed that each single-family structure was being an independent building. The committee did not accept the justifications put forward by the AP for relaxation of the requirement of the FRC Code.

(b) BCII 2 18/2005

Issue : Proposed 25-story industrial building with EVA not serving two opposite facades and of width less than 13.5m as required under MOA code.

Decision : The committee, having considered the existing site situation and FSD's advice, accepted the proposal.