

**Summary of Decisions of the Building Committee  
Building Committee II 27/2005 held on 26.7.2005**

(a) BCII 1 27/2005

Issue : Proposed restoration of the existing pre-war temple buildings without the provision of EVA.

Decision : The committee, having considered the site situation and FSD's advice, accepted the non-provision of EVA subject to enhancement of fire safety measures as required by FSD.

(b) BCII 2 27/2005

Issue : Proposed hotel with the provision of EVA not in compliance with the requirements in MOA Code.

Decision : The committee, having considered the site constraints and FSD's advice, accepted the proposal.

(c) BCII 3 27/2005

Issue : The free louvre area less than 1/20 of the floor area of the internal bathrooms.

Decision : The committee, having considered the AP's substantiation, accepted the proposal.