

**Summary of Decisions of the Building Committee
Building Committee II 29/2005 held on 9.8.2005**

(a) BCII 1 29/2005

Issue : Proposed single-storey temple building without provision of EVA.

Decision : The committee, having considered the site constraints and FSD's advice, accepted the proposal subject to the provision of enhanced fire safety measures.

(b) BCII 2 29/2005

Issue : Proposed 21-storey domestic building with portion of EVA of inadequate width within the turning circle.

Decision : The committee, having considered FSD's advice, accepted the proposal.