

**Summary of Decisions of the Building Committee  
Building Committee II 31/2005 held on 23.8.2005**

(a) BCII 1 31/2005

Issue : The total length of the façade of the proposed commercial/residential building served by the EVA was less than 1/4 of the total perimeter of the building.

Decision : The committee, having considered the FSD's advice, accepted the proposal subject to the provision of enhanced fire safety measure.

(b) BCII 2 31/2005

Issue : Proposed single-family development with inadequate turning circle for the proposed EVA.

Decision : The committee, having considered the deficiencies were minimum and FSD's advice, accepted the proposal.