

Summary of Decisions of the Building Committee
Building Committee II 32/2005 held on 29.8.2005

(a) BCII 1 32/2005

Issue : Proposed low-rise residential development with the width of the EVA less than 7.3m.

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement.

(b) BCII 2 32/2005

Issue : Proposed school extension to be served by an existing sub-standard EVA.

Decision : The committee, having considered the existing constraint and FSD's advice, accepted the proposed EVA arrangement.