

**Summary of Decisions of the Building Committee
Building Committee II 36/2005 held on 27.9.2005**

(a) BCII 1 36/2005

Issue : Proposed composite building to be served by abutting streets as EVA of a steeper gradient as required in MOA Code.

Decision : The committee, having considered the existing site constraint and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.

(b) BCII 2 36/2005

Issue : Proposed low-rise single-family houses to be served by an EVA of inadequate width

Decision : The committee, having considered the existing site constraint and FSD's advice, accepted the proposed EVA arrangement.

(c) BCII 3 36/2005

Issue : Proposed 2-storey single-family houses to be served by an existing EVA of inadequate loading capacity and turning space.

Decision : The committee, having considered the existing site constraint and FSD's advice, accepted the proposed EVA arrangement.