

**Summary of Decisions of the Building Committee
Building Committee II 37/2005 held on 4.10.2005**

(a) BCII 1 37/2005

Issue : Proposed open kitchen design for a residential development.

Decision : The AP was required to further demonstrate the adequate provision of FRP protection for the open kitchen design.

(b) BCII 2 37/2005

Issue : Proposed office building with less than 25% of the main facade served by an EVA.

Decision : The committee, having considered the existing site constraint and FSD's advice, accepted the proposed EVA arrangement.

(c) BCII 3 37/2005

Issue : Proposed composite building with less than 25% of the main facade served by an EVA.

Decision : The committee, having considered the existing site constraint and FSD's advice, accepted the proposed EVA arrangement.