

**Summary of Decisions of the Building Committee  
Building Committee II 39/2005 held on 18.10.2005**

(a) BCII 1 39/2005

Issue : Non-provision of natural lighting and ventilation to the internal offices of an institutional building.

Decision : The committee, having studied the design and noting that central A/C and artificial lighting would be provided, accepted the proposal.

(b) BCII 2 39/2005

Issue : Proposed single-storey substation and water tank plant facility with EVA of inadequate loading capacity.

Decision : The committee, having considered the existing situation and FSD's advice, accepted the proposed EVA arrangement.

(c) BCII 3 39/2005

Issue : Less than 25% of the building facade of the proposed single-storey plant buildings would be served by an existing EVA and the EVA was of inadequate loading capacity.

Decision : The committee, having considered the existing situation and FSD's advice, accepted the proposed EVA arrangement.

(d) BCII 4 39/2005

Issue : Proposed conversion of the existing office into shop with the existing building was not in compliance with the current MOE in terms of the interchange of staircases and the provision of refuse floor or roof.

Decision : The committee accepted the proposed conversion subject to the provision of interchange of staircase on the first to third floors.