

**Summary of Decisions of the Building Committee  
Building Committee II 42/2005 held on 8.11.2005**

(a) BCII 1 42/2005

Issue : Less than 25% of the facade of the single family houses would be served by an existing EVA and the EVA would be located at a distance more than 10m from the building facade.

Decision : The committee, having considered the existing situation and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.

(b) BCII 2 42/2005

Issue : Non-compliance with the requirement in terms of width and gradient for the EVA for a proposed 4-storey residential building.

Decision : The committee, having considered the existing situation, accepted the proposed EVA arrangement subject to acceptance of the same by FSD.