

**Summary of Decisions of the Building Committee
Building Committee II 46/2005 held on 7.12.2005**

(a) BCII 1 46/2005

Issue : Less than 25% of the facade of an industrial building would be served by an existing EVA which was of inadequate width and there was no additional EVA to be provided within the site.

Decision : The committee, having considered the existing situation and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.

(b) BCII 2 46/2005

Issue : Non-provision of EVA for a single-family house.

Decision : The committee, having considered the existing situation and FSD's advice, accepted the non-provision of EVA subject to the provision of a sprinkler system.

(c) BCII 3 46/2005

Issue : Non-provision of EVA for a single-family house.

Decision : The committee, having considered the existing situation and FSD's advice, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures including a sprinkler system.