

**Summary of Decisions of the Building Committee
Building Committee II 47/2005 held on 14.12.2005**

(a) BCII 1 47/2005

Issue : Less than 25% of the facade of an commercial building would be served by an existing EVA.

Decision : The committee, having considered the existing situation and FSD's advice, accepted the proposed EVA arrangement.

(b) BCII 2 47/2005

Issue : Proposed building served by an EVA located at a distance of more than 10m.

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement.

(c) BCII 3 47/2005

Issue : Less than 25% of the facade of an commercial building would be served by an existing EVA.

Decision : The committee, having considered the existing situation and FSD's advice, accepted the proposed EVA arrangement.

(d) BCII 4 47/2005

Issue : Proposed domestic building with part of the area of the living rooms located at a distance of more than 9m from the prescribed windows.

Decision : The committee agreed that the proposal did not comply with the restriction on distance any part of the habitable room might be from the prescribed windows.