

**Summary of Decisions of the Building Committee
Building Committee II 48/2005 held on 21.12.2005**

(a) BCII 1 48/2005

Issue : Proposed gradient of 1 in 12 for benchings in manhole.

Decision : Noting that the proposal was in line with the draft code of practice for drainage works under preparation, the committee agreed to the proposed gradient.

(b) BCII 2 48/2005

Issue : Proposed reduction in the provision of the openable windows to the guestrooms.

Decision : The committee noted that same modification had been granted to the existing building in the past. Hence, the committee agreed to grant the modification on the reduction of openable windows.

(c) BCII 3 48/2005

Issue : Proposed 3-storey temple building with EVA of inadequate width.

Proposed swing type security gate instead of emergency crash gate for the EVA.

Decision : The committee having considered the existing situation and FSD's advice, accepted the proposed EVA arrangement.

(d) BCII 4 48/2005

Issue : Non-compliance with the requirement in terms of width, turning circle and gradient for the two existing EVAs.

Decision : The committee having considered the existing situation and FSD's advice, accepted the proposed EVA arrangement subject to the acceptance of the enhanced fire safety measures by FSD.