

**Summary of Decisions of the Building Committee
Building Committee II 1/2006 held on 3.1.2006**

(a) BCII 1 1/2006

Issue : Less than 25% of the facade of a single-storey building would be served by the extension of an existing EVA having inadequate loading capacity.

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement.

(b) BCII 2 1/2006

Issue : Proposed domestic building with part of dining room located at a distance of more than 9m from prescribed window.

Decision : The committee did not identify any sound justifications and did not accept the proposed design.

(c) BCII 3 1/2006

Issue : Less than 25% of the facade of a commercial building would be served by an existing EVA.

Decision : The committee having considered the existing situation and FSD's advice, accepted the proposed EVA arrangement.

(d) BCII 4 1/2006

Issue : Non-compliance with the FRP requirement for an alteration project.

Decision : The committee considered that the proposal should comply with the current requirements and did not accept the proposal.

(e) BCII 5 1/2006

Issue : Non-provision of EVA.

Decision : The committee having considered the existing situation and FSD's advice, accepted the non-provision of EVA.