

**Summary of Decisions of the Building Committee**  
**Building Committee II 2/2006 held on 10.1.2006**

(a) BCII 1 2/2006

Issue : Proposed building served by an EVA located at a distance of more than 10m.

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.

(b) BCII 2 2/2006

Issue : Less than 25% of the facade of a composite building would be served by the existing EVA.

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement.

(c) BCII 3 2/2006

Issue : Cinema situated in basement and cinema situated at more than 12m above pavement level for committee's information.

Proposed cinemas with capacity over 750 persons.

Decision : The committee, having studied the design, accepted the proposed MOE arrangement.

(d) BCII 4 2/2006

Issue : Less than 25% of the facade of an industrial building would be served by an existing EVA.

Decision : The committee having considered the existing situation and FSD's advice, accepted the proposed EVA arrangement.