

Summary of Decisions of the Building Committee
Building Committee II 3/2006 held on 17.1.2006

(a) BCII 1 3/2006

Issue : Proposed building served by an EVA which width was less than 6m and located at a distance of more than 10m.

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.

(b) BCII 2 3/2006

Issue : Proposed building served by an EVA which width was less than 6m and located at a distance of more than 10m.

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.

(c) BCII 3 3/2006

Issue : Proposed building served by an EVA of inadequate loading capacity.

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement.