

**Summary of Decisions of the Building Committee**  
**Building Committee II 4/2006 held on 24.1.2006**

(a) BCII 1 4/2006

Issue : Proposed building served by an EVA which was not in compliance with the requirements of the current EVA Code.

Decision : The committee deferred a decision a decision pending comment from FSD.

(b) BCII 2 4/2006

Issue : Proposed building served by an EVA with inadequate turning circle.

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.

(c) BCII 3 4/2006

Issue : Non-provision of insulation for lift landing doors for dump waiters of a hospital development.

Decision : The committee, having considered the use of the dump waiters and the comment in the fire safety review report, accepted the proposal.

(d) BCII 4 4/2006

Issue : Non-provision of EVA.

Decision : The committee, having noted the existing site condition, accepted the proposed EVA arrangement subject to no adverse comment from FSD.

(e) BCII 5 4/2006

Issue : Proposed building served by an EVA located at a distance of more than 10m.

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.