

**Summary of Decisions of the Building Committee
Building Committee II 6/2006 held on 7.2.2006**

(a) MAII 1 6/2006

Issue : Proposed industrial building served by an EVA with inadequate width, loading capacity and less than 25% of the building façade would be served by the EVA.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.

(b) BCII 1 6/2006

Issue : Non-provision of EVA to a changing room block for a residential development

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement.

(c) BCII 2 6/2006

Issue : Proposed building served by an EVA with inadequate width and turning circle.

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement.

(d) BCII 3 6/2006

Issue : Non-provision of EVA.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to the compliance with the requirements set out by FSD.

(e) BCII 4 6/2006

Issue : Proposed refuse storage and material recovery chamber without vehicular access.

Decision : The committee noted that the AP's justification on site constraints and design constraint, agreed to the proposal subject to no adverse comment from FEHD.

(f) BCII 5 6/2006

Issue : TBE room of inadequate size for a conversion project for a hotel.

Decision : Having considered AP's justifications, the committee accepted the proposal subject to no adverse comment from OFTA.