

**Summary of Decisions of the Building Committee
Building Committee II 7/2006 held on 14.2.2006**

(a) BCII 1 7/2006

Issue : The percentage of the facade of the proposed composite building served by an existing EVA was less than 25%.

Decision : The committee, having considered the existing situation and FSD's advice, accepted the proposed EVA arrangement.

(b) BCII 2 7/2006

Issue : Non-provision of EVA to a single-storey structure in a golf course.

Decision : The committee, having considered FSD's advice and the use of the proposed structure, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures.

(c) BCII 3 7/2006

Issue : The percentage of the facade of 4 nos. of houses of a residential development served by an EVA was less than 25%.

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement.