

**Summary of Decisions of the Building Committee
Building Committee II 8/2006 held on 21.2.2006**

(a) BCII 1 8/2006

Issue : The percentage of the facade of the proposed houses served by an EVA was less than 25% and the EVA was located at a distance of more than 10m.

Decision : The committee, having considered the existing situation and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.

(b) BCII 2 8/2006

Issue : Proposed filtration plant building served by an EVA with inadequate width, turning radius and space.

Decision : The committee, having considered the nature of the proposed building and FSD's advice, accepted the proposed EVA arrangement.