

**Summary of Decisions of the Building Committee
Building Committee II 9/2006 held on 28.2.2006**

(a) BCII 1 9/2006

Issue : The distance from the fire service access point to a fireman lift was more than 18m.

Decision : The committee, having considered the design and FSD's advice, accepted the proposed arrangement.

(b) BCII 2 9/2006

Issue : The percentage of the facade of the proposed shop building served by an EVA was less than 25%.

Decision : The committee noted that the whole building was proposed for shop use. The committee, having noted the FSD's advice, agreed that the AP should submit Fire engineering report for consideration of the Fire Safety Committee.