

**Summary of Decisions of the Building Committee
Building Committee II 10/2006 held on 7.3.2006**

(a) BCII 1 10/2006

Issue : Non-provision of EVA to a kiosk.

Decision : The committee, having considered FSD's advice, accepted the non-provision of EVA.

(b) BCII 2 10/2006

Issue : The fall of the surface channel in a fuel tank farm was less than 1:100 required under B(SSFPDW&L)R 61(1).

Decision : The committee noted that the minimum flow velocity of the channel would comply with DSD standard. Having considered the design and the constraints, the committee accepted the proposal subject to the channel being designed with a minimum flow velocity of 1 m/s.