

**Summary of Decisions of the Building Committee**  
**Building Committee II 13/2006 held on 28.3.2006**

(a) BCII 1 13/2006

- Issue : The percentage of the facade of the proposed 3-storey single family house served by an EVA was less than 25%.
- Decision : The committee, having noted FSD's advice, accepted the EVA arrangement.