

**Summary of Decisions of the Building Committee
Building Committee II 14/2006 held on 4.4.2006**

(a) BCII 1 14/2006

Issue : Proposed buildings served by an EVA of inadequate width, loading capacity and turning circle.

Decision : The committee, having noted the site circumstances and FSD's advice, accepted the EVA arrangement.

(b) BCII 2 14/2006

Issue : Proposed multi-purpose hall used as PPE mixed with other uses.

Decision : The committee noted (i) the Fire Safety Committee had accepted the proposal (ii) the independent escape staircases had been provided for the proposed hall and (iii) the hall was separated from the remainder of the building by compartment walls and fire shutters. Having studied the design of the proposal hall, the committee agreed to the proposal subject to no adverse comment from FEHD.