

Summary of Decisions of the Building Committee
Building Committee II 17/2006 held on 25.4.2006

(a) BCII 1 17/2006

Issue : Less than 25% of the major façade of a composite building to be served by the EVA.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.

(b) BCII 2 17/2006

Issue : Proposed temporary sale office building to be served by an EVA without the provision of turning space.

Decision : The committee, having considered the nature of the building and FSD's advice, accepted the proposed EVA arrangement.

(c) BCII 3 17/2006

Issue : Proposed single-family house served by an existing EVA of inadequate width.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.