

Summary of Decisions of the Building Committee
Building Committee II 19/2006 held on 9.5.2006

(a) BCII 1 19/2006

Issue : Proposed low-rise development to be served by an EVA of inadequate width, steeper gradient and inadequate turning space.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to acceptance of the enhanced fire safety measures by FSD.

(b) BCII 2 19/2006

Issue : Proposed residential development to be served by an EVA of inadequate width and turning space.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to provision of enhanced fire safety measures.