

**Summary of Decisions of the Building Committee
Building Committee II 23/2006 held on 14.6.2006**

(a) BCII 1 23/2006

- Issue : (i) Proposed buildings served by an EVA of inadequate width and loading capacity.
- (ii) Determination of the number and the width of thoroughfare for place of public entertainment accommodating less than 500 persons.
- (iii) Inadequate width for door leaf of the existing double leaf exit doors.
- Decision : (i) The committee, having noted the site circumstances and FSD's advice, accepted the EVA arrangement subject to the provision of enhanced fire safety measures.
- (ii) Having studied the plans, the committee invited the AP to present his case to the committee for further consideration.
- (iii) Having noted that the proposal was for an existing historical building and the provision of extra exit route for the premises, the committee agreed to accept the width of the door leaf.

(b) BCII 2 23/2006

- Issue : The percentage of the façade of the building served by an EVA less than 25%.
- Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to provision of the enhanced fire safety measure.