

**Summary of Decisions of the Building Committee
Building Committee II 24/2006 held on 20.6.2006**

(a) BCII 1 24/2006

Issue : The percentage of the major façade of a residential building served by an EVA less than 25% and the façade of the building in a distance of more than 10m from the EVA.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement.

(b) BCII 2 24/2006

Issue : The percentage of the façade of the building served by an EVA less than 25%.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.

(c) BCII 3 24/2006

Issue : Proposed building served by an EVA with non-provision of turning circle.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.

(d) BCII 4 24/2006

Issue : Proposed building served by an EVA with non-provision of turning circle.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.

(e) BCII 5 24/2006

Issue : Proposed residential development served by an EVA of inadequate width.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.