

Summary of Decisions of the Building Committee
Building Committee II 25/2006 held on 27.6.2006

(a) BCII 1 25/2006

Issue : Proposed warehouse and workshop development served by an EVA of inadequate width and with non-provision of turning circle.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement.

(b) BCII 2 25/2006

Issue : Less than 25% of the façade of the domestic building served by an EVA.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.

(c) BCII 3 25/2006

Issue : Non-provision of EVA for a transmission station building.

Decision : The committee, having considered the site situation and FSD's advice, accepted the non-provision of EVA.