

**Summary of Decisions of the Building Committee
Building Committee II 27/2006 held on 11.7.2006**

(a) BCII 1 27/2006

Issue : Proposed temporary building served by an EVA of inadequate width.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement.

(b) BCII 2 27/2006

Issue : Proposed temporary building served by an EVA of inadequate width.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement.

(c) BCII 3 27/2006

Issue : Less than 25% of the façade of a shop/restaurant/office building served by an EVA.

Decision : The committee, having noted the site situation and FSD's advice, accepted the proposed EVA arrangement.

(d) BCII 4 27/2006

Issue : Non-provision of FRP enclosed walls for a glass lift shaft in a single family house.

Decision : Accepting that the single family house formed one single compartment, the committee agreed to the proposal subject to the confirmation from AP that hydraulic lift would be installed.