

**Summary of Decisions of the Building Committee
Building Committee II 28/2006 held on 18.7.2006**

(a) BCII 1 28/2006

Issue : Proposed concrete batching plant served by an EVA of inadequate width.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement.

(b) BCII 2 28/2006

Issue : Proposed composite building served by an EVA of inadequate width.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement.

(c) BCII 3 28/2006

Issue : Proposed building served by an EVA of inadequate width, with loading capacity less than 30,000 kg and without the provision of turning circle.

Decision : The committee noted that the building was an un-manned building housing a ventilation system. Having noted the nature of the building and the advice of FSD, the committee accepted the proposed EVA arrangement.

(d) BCII 4 28/2006

Issue : Proposed building served by an EVA of inadequate width, with loading capacity less than 30,000 kg and without the provision of turning circle.

Decision : The committee noted that the building was an un-manned building housing a ventilation system. Having noted the nature of the building and the advice of FSD, the committee accepted the proposed EVA arrangement.