

**Summary of Decisions of the Building Committee  
Building Committee II 29/2006 held on 25.7.2006**

(a) BCII 1 29/2006

Issue : Non-provision of insulation in respect of FRP for lift landing doors of two hoisting lifts.

Decision : The committee, having noted the size and the nature of the hoisting lift, accepted the proposed arrangement subject to confirmation that such lift landing door with adequate insulation was not available in the market.

(b) BCII 2 29/2006

Issue : Less than 25% of the perimeter of a composite building to be served by an EVA.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement.