

**Summary of Decisions of the Building Committee
Building Committee II 30/2006 held on 1.8.2006**

(a) BCII 1 30/2006

Issue : Less than 25% of the perimeter of a residential building to be served by an EVA which was located at a distance of more than 10m.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement subject to the provision of enhanced fire safety measures.

(b) BCII 2 30/2006

Issue : Proposed data centre to be served by an EVA with portion of which less than 7.3m wide.

Decision : The committee noted that the width of the EVA would be locally reduced due to the installation of a electrical road blocker system. The committee, having considered AP's justification and no objection from FSD, accepted the EVA arrangement

(c) BCII 3 30/2006

Issue : Proposed residential development to be served by an EVA of width less than 6m wide.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement subject to the provision of enhanced fire safety measures.