

**Summary of Decisions of the Building Committee
Building Committee II 31/2006 held on 8.8.2006**

(a) BCII 1 31/2006

Issue : Proposed single-storey temporary building to be served by an EVA of width less than 6m wide.

Decision : The committee, having noted the site conditions and FSD's advice, accepted the EVA arrangement.

(b) BCII 2 31/2006

Issue : Proposed building served by an EVA with inadequate width and with no turning circle and a gradient greater than 1:10.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.